



City of Chipley

**Water Utilities Department
P. O. Box 1007
Chipley, Florida 32428
(850) 638-6347 - Fax: (850) 638-6052**

December 29, 2023

Water Utilities Department Report for December 2023

To: City Council and Administrator

Wastewater Treatment Facility: The analytical results of the Wastewater Reclamation Facility for the month of November 2023 show no violations. We have not received all the results from December 2023, but what have received show no violations. Continuing to plot sewer lines and cleanouts in diamond maps.

Collection System: Replaced 100 feet of sewer main and replaced (3) taps.

Lift Stations: Work underway at Jon Teal and Vo-Tech lift station to place generators. Repaired Pontiac lift station electronic controls. Repaired City Hall lift station.

Water Wells: The bacteriological samples for the month of December 2023 passed. Check generators weekly.

Spray Field: Monitoring wells sampled this month. Routine inspections.

Locates: 46

Work orders: 23

Sewer Stoppages: 15

Abonnement Sewer Lateral: 2

Replace Clean Out Caps: 8

Sewer Taps: 0

Replace/Repair Sewer Lateral: 3

Development Order: 1

Install Clean Out Boxes: 10

Replace Clean Outs: 6

Repair Sewer Main: 1

Manhole rain guards installed: 1

Recorded Rainfall for the month: 2.41 inches

Jimmy Cook
Water Utilities Director