



City of Chipley

**Water Utilities Department
P. O. Box 1007
Chipley, Florida 32428
(850) 638-6347 - Fax: (850) 638-6052**

October 1, 2024

Water Utilities Department Report for September 2024

To: City Council and Administrator

Wastewater Treatment Facility: The analytical results of the Wastewater Reclamation Facility for the month of August 2024 show no violations. We have not received all the results from September 2024, but what have received show no violations. Continuing to plot sewer lines and cleanouts in diamond maps (Ward 1 and 2 complete). Mowed at WWTF twice. 3rd quarter grease trap inspections complete. Smoke test ward three. Replaced section of asphalt at 7th street and Hwy 90. WWTF had high flows due to heavy rainfall.

Lift Stations: Work underway at Jon Teal and Vo-Tech lift station to place generators. Cut grass at all lift stations twice. Routine inspections. Pulled pump at Pontiac lift station cleaned and replaced.

Water Wells: The bacteriological samples for the month of September 2024 passed. Check generators weekly. Cut grass at all wells twice.

Spray Field: Routine inspections. Cut grass around holding ponds. Checked bypass pump at spray field weekly.

Locates: 40

Work orders: 11

Sewer Stoppages: 7

Abonnement Sewer Lateral: 1

Replace Clean Out Caps: 8

Sewer Taps: 3

Replace/Repair Sewer Lateral: 0

Development Order: 2

Install Clean Out Boxes: 4

Replace Clean Outs: 1

Repair Sewer Main: 0

Manhole rain guards installed: 0

Demolition Order: 1

Recorded Rainfall for the month: 10.72 inches

Jimmy Cook
Water Utilities Director