



City of Chipley

**Water Utilities Department
P. O. Box 1007
Chipley, Florida 32428
(850) 638-6347 - Fax: (850) 638-6052**

January 5, 2026

Water Utilities Department Report for December 2025

To: City Council and Administrator

Wastewater Treatment Facility: The analytical results of the Wastewater Reclamation Facility for the month of November 2025 showed no violations. We have not received all the results from December 2025, but what have received show no violations. Continuing to plot sewer lines and cleanouts in diamond maps. Continue smoke testing. We are still on single tank mode until new air valve is received and installed.

Lift Stations: Routine inspections. Cut grass at all lift stations. Working on installing a generator at Harrison lift station. Working with contractor on new Peach Street lift station project.

Water Wells: The bacteriological samples for the month of December 2025 passed. Check generators weekly. Cut grass at all wells.

Spray Field: Routine inspections of spray field. Found leak at pump station at Pike Pond spray field should be repaired in January 2026 we have received all the parts needed.

Main Jetted: 2

Locates: 37

Work orders: 7

Sewer Stoppages: 5

Abonnement Sewer Lateral: 0

Replace Clean Out Caps: 3

Sewer Taps: 0

Replace/Repair Sewer Lateral: 1

Development Order: 0

Install Clean Out Boxes: 2

Replace Clean Outs: 1

Demolition Order: 0

Rain Guards installed: 0

Raised manholes: 0

Recorded Rainfall for the month: 4.84 inches

Jimmy Cook
Water Utilities Director

