

ADDENDUM No. 1

City of Chipley

Peach Street Pumping Station Replacement

Bid No. 25-01

Mott MacDonald Project No. 502101554

November 25th, 2024

Specifications, Plans, and Contract Documents shall be amended in the following particulars:

I. SPECIFICATIONS

1. SECTION C-111 – ADVERTISEMENT FOR BIDS

A. DELETE the sentence

“Bids for the construction of the Project will be received at the Chipley City Hall located at 1442 Jackson Ave., Chipley, FL 32428 until Wednesday, December 4th, 2024 at 2 pm local time.”

and replace with the sentence

“Bids for the construction of the Project will be received at the Chipley City Hall located at 1442 Jackson Ave., Chipley, FL 32428 until Wednesday, December 11th, 2024 at 2 pm local time.”

2. ATTACHMENT A – LINE ITEM BID FORM

B. REMOVE Attachment A – Line Item Bid Form and **REPLACE** in its entirety with new Attachment A – Line Item Bid Form (Attachment 1).

3. SECTION 01000 MEASUREMENT AND PAYMENT

C. REMOVE SECTION 01000 Measurement and Payment and **REPLACE** in its entirety with new Section 01000 Measurement and Payment (Attachment 2).

4. SECTION 02570 PUMPING STATIONS

D. REMOVE SECTION 02570 Pump Stations and **REPLACE** in its entirety with new Section 02570 Pumping Stations (Attachment 3).

II. PLANS

None

III. CLARIFICATIONS

A. Pre-Bid Meeting Notes and Attendee List Attached. (Attachment 4)

B. Additional Information

1. BABA requirements will be enforced in this project. All materials must adhere to these rules and regulations. To demonstrate the impact of BABA to the cost of the project, a deductive bid item has been included on the bid form. This item will provide the contractor the opportunity to display what cost savings could be provided if BABA rules and regulations were not required.
2. The engineer and owner shall be provided a minimum of 2 weeks' notice prior to factory acceptance testing of the equipment. The FAT may be conducted via teams or other video service.

C. Requests for Information

1. **Question:** I do not see any specs regarding the standby pump (ieNG or Diesel). Can this be clarified or is it too late.
Answer: This bypass pump will be natural gas powered. See Specification Section 02578 Paragraph K for information on the drive unit.
2. **Question:** How many copies of the bid package will need to be submitted with our bid? 1 Original, 1 copy?
Answer: One original copy will be sufficient.
3. **Question:** Will this project require Owner-Paid Material/Tax Savings Agreement?
Answer: No. All taxes are to be included in the bid.

END OF ADDENDUM No. 1

Please see Addendum Acknowledgement on following page.

ADDENDUM No. 1

City of Chipley

Peach Street Pump Station Replacement

Bid No. 25-01

Mott MacDonald Project No. 502101554

November 25th, 2024

Addendum Acknowledgement

MM No. 502101554

Addendum No. 1 Received by: _____

Company Name: _____

Date: _____

Please return acknowledgement of Addendum No. 1 to: beverly.stephens@mottmac.com