



City of Chipley

Water Utilities Department
P. O. Box 1007
Chipley, Florida 32428
(850) 638-6347 - Fax: (850) 638-6052

October 1, 2025

Water Utilities Department Report for September 2025

To: City Council and Administrator

Wastewater Treatment Facility: The analytical results of the Wastewater Reclamation Facility for the month of August 2025 had two (2) violations for (Fecal) due to one SBR being offline. We have not received all the results from September 2025, but what have received show no violations. Continuing to plot sewer lines and cleanouts in diamond maps. Cut grass at WWTF twice. Continue smoke testing. Air Valve on SBR #1 is down we have ordered a replacement estimate of (14) weeks for delivery. We will remain on single tank mode until new air valve is installed Assisted Vo-Tech with sewer stoppages.

Lift Stations: Routine inspections. Cut grass at all lift stations twice. Working on installing a generator at Harrison lift station.

Water Wells: The bacteriological samples for the month of September 2025 passed. Check generators weekly. Cut grass at all wells twice. Well #5 down for repairs awaiting parts.

Spray Field: Routine inspection of spray field. Mowed Pike Pond spray field. Mowed Davison and Ind. Park spray fields. Found leak at pump station at Pike Pond spray field should be repaired in October.

Main Jetted: 13

Locates: 53

Work orders: 4

Sewer Stoppages: 1

Abonnement Sewer Lateral: 1

Replace Clean Out Caps: 9

Sewer Taps: 0

Replace/Repair Sewer Lateral: 1

Development Order: 5

Install Clean Out Boxes: 21

Replace Clean Outs: 3

Demolition Order: 1

Rain Guards installed: 0

Raised manholes: 0

Recorded Rainfall for the month: 3.01 inches

Jimmy Cook
Water Utilities Director