City of Chipley

Water Utilities Department
P. 0. Box 1007
Chipley, Florida 32428
(850) 638-6347 - Fax: (850) 638-6052

November 2, 2026

Water Utilities Department
Report for October 2026

To: City Council and Administrator

Wastewater Treatment Facility: The analytical results of the Wastewater Reclamation Facility for the month of September 2026 showed no violations We have not received all the results from October 2026, but what we have received shows no violations. Continue to smoke test North side of town. Cleaned problem main sewer lines. Smoke test North side. Cut grass at plant X2. Done 4th quarter grease trap inspections.

Lift Stations: Routine inspections. Cut grass at all lift stations.

Water Wells: The bacteriological samples for the month of October 2026 passed. Check generators weekly. Cut Grass at lift stations 77 well generator transfer switch was hit by lighting we have ordered a new one and should be in mid-December.

Spray Field: Routine inspections of spray field. Mowed and Bush hogged spray field. Serviced pumps at spray field. Capped line going into Industrial spray field.

Locate: 31
Work orders: 9
Sewer Stoppages: 4
Abonnement Sewer Lateral: 0
Replace Clean Out Caps: 3
Sewer Taps: 3
Replace/Repair Sewer Lateral: 1
Development Order: 3
Install Clean Out Boxes: 1
Replace clean Outs: 3
Demolition Order: 0
Camera lines: 8
Raised/Reset manholes: 0
Rainfall for the month: 5.99 inches

Jimmy Cook
Water Utilities Director