



1. Standard Reflectance of 80/50/20 unless noted otherwise
2. Not a Construction Document, for Design purposes only
3. Standard indoor calc points @ 30" A.F.F. unless noted otherwise
4. Standard outdoor calc points @ Grade unless noted otherwise
5. Egress calc points @ 0" A.F.F.
6. Mlazgar Associates assumes no responsibility for installed light levels due to field conditions, etc.

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
PROPOSED ASPHALT	Illuminance	Fc	0.52	5.9	0.0	N.A.	N.A.
SITE	Illuminance	Fc	0.00	0.3	0.0	N.A.	N.A.

Luminaire Schedule									
Symbol	Qty	Label	Manufacturer	Description	Arrangement	Lum. Lumens	Lum. Watts	LLF	
↔	3	A	COOPER LIGHTING SOLUTIONS - LUMARK (FORMERLY EATON)	XTOR2B	Single	2135	18.2	0.900	

#	Date	Comments
Revisions		

RLMA Project #: 147600  
 Drawn By: EP  
 Date: 8/31/2023  
 Scale: 1" = 6' 0"