

Anthony Arton Health Services Director

Craig Wetherbee Environmental Health Director

## Promoting an Optimal State of Wellness in Lake County

## Memorandum

**DATE:** 5/28/2024

**TO:** Mark Roberts

**FROM:** Christina Gearhart, EHS

**RE:** Conditional Use Permit CUP 2024-02 - CUPA comments

**APN:** APN: 039-550-50, -51 and -20

Lake County Environmental Health (LCEH) will require an Underground Storage Tank (UST) system installation permit application, payment, and submission of plans and supporting documentation for the proposed UST system installation.

If/when the applicant stores hazardous materials equal to or greater than 55 gallons of a liquid, 500 pounds of a solid or 200 cubic feet of compressed gas, the applicant will be required to submit a Hazardous Materials Inventory Disclosure Statement/ Business Plan to the Environmental Health Division via the California Electronic Reporting System (CERS) and it shall be renewed and updated annually or if quantities increase. Note that additional California Unified Program Agency (CUPA) requirements may apply depending on the amounts and types of hazardous materials stored onsite.

