

MONTHLY REPORT

From the Water Resources Department

Bradley Filaski

May 2026

Water Treatment

- Our city wells produced 16.4 MG.
- Purchased 5.8 MG from the County.
- Flushed 2 hydrants for water quality.
- Performed 195 laboratory tests on drinking water.
- Collected and shipped all required samples for the month to EPD's lab.
- Submitted all Monthly Operating Reports to EPD.
- Issued 2 boil water advisories to EPD.
- The water loss was 23.8%.
- Prepared the 2026 Consumer Confidence Report.
- Responded to 3 water quality work orders.

Water Reclamation

- Discharged 14.3 MG of treated effluent into the Tesnatee Creek.
- Performed 108 laboratory tests on the influent and effluent wastewater.
- Cleaned all UV lamps.
- Submitted the Discharge Monitoring Report to EPD.
- Filled potholes with gravel on the road around the pond.
- Greased blowers and cleaned air filters.

Industrial Pretreatment

- Reviewed Cobb-Vantress and NOK Self-Monitoring Reports.