

# MONTHLY REPORT

From the Water Resources Department

Bradley Filaski

## March 2026

### Water Treatment

- Our city wells produced 16.9 MG.
- Purchased 6.1 MG from the County.
- Flushed 5 hydrants for water quality.
- Performed 195 laboratory tests on drinking water.
- Collected and shipped all required samples for the month to EPD's lab.
- Submitted all Monthly Operating Reports to EPD.
- Issued 1 boil water advisory to EPD.
- The water loss was 34.9%.

### Water Reclamation

- Discharged 10.6 MG of treated effluent into the Tesnatee Creek.
- Performed 108 laboratory tests on the influent and effluent wastewater.
- Cleaned all UV lamps.
- Submitted the Discharge Monitoring Report to EPD.
- Reviewed and filed monthly grease trap manifests.
- Installed new chemical feed pump for magnesium hydroxide.

### Industrial Pretreatment

- Reviewed Cobb-Vantress and NOK Self-Monitoring Reports.