

MONTHLY REPORT

From the Water Resources Director

Scott Brown

August 2026

Water Treatment

- City Wells produce 16.7 MG.
- Purchased 6.1 MG from the County.
- Performed 195 laboratory tests on drinking water.
- Collected and shipped all required samples for the month to EPD's lab.
- Submitted all Monthly Operating Reports to EPD.
- The water loss was 26.1%.
- Issued 1 Boil Water Advisory.
- Flushed 2 hydrants for water quality.

Water Reclamation

- Discharged 11.7 MG of treated effluent into the Tesnatee Creek.
- Performed 108 laboratory tests on the influent and effluent wastewater.
- Cleaned all UV lamps.
- Submitted the Discharge Monitoring Report to EPD.
- Greased and changed filters on blowers.
- Responded to 1 sewer odor complaint call.

Industrial Pretreatment

- Reviewed Cobb-Vantress and NOK Self-Monitoring Reports.
- Semi Annual Industrial Pretreatment inspection by EPD.