

# MONTHLY REPORT

From the Water Resources Department

Bradley Filaski

## April 2026

### Water Treatment

- Our city wells produced 16.3 MG.
- Purchased 6.3 MG from the County.
- Flushed 3 hydrants for water quality.
- Performed 195 laboratory tests on drinking water.
- Collected and shipped all required samples for the month to EPD's lab.
- Submitted all Monthly Operating Reports to EPD.
- Issued 1 boil water advisory to EPD.
- The water loss was 25.2%.

### Water Reclamation

- Discharged 10.3 MG of treated effluent into the Tesnatee Creek.
- Performed 108 laboratory tests on the influent and effluent wastewater.
- Cleaned all UV lamps.
- Submitted the Discharge Monitoring Report to EPD.
- Filled potholes with gravel on the road around the pond.
- Greased blowers.
- Cleaned aerators at the influent.

### Industrial Pretreatment

- Reviewed Cobb-Vantress and NOK Self-Monitoring Reports.