

MONTHLY REPORT

From the Water Resources Department

Bradley Filaski

June 2026

Water Treatment

- Our city wells produced 17.2 MG.
- Purchased 5.2 MG from the County.
- Performed 195 laboratory tests on drinking water.
- Collected and shipped all required samples for the month to EPD's lab.
- Submitted all Monthly Operating Reports to EPD.
- Collected new line microbiological samples at the Talon Village development.
- The water loss was 29.3%.
- Responded to 1 water quality work order.

Water Reclamation

- Discharged 10.9 MG of treated effluent into the Tesnatee Creek.
- Performed 108 laboratory tests on the influent and effluent wastewater.
- Cleaned all UV lamps.
- Submitted the Discharge Monitoring Report to EPD.
- Greased blowers and changed oil.
- Sprayed weeds around the pond dike.
- Cleaned weeds off the air lines and curtains in the pond.

Industrial Pretreatment

- Reviewed Cobb-Vantress and NOK Self-Monitoring Reports.