

Exhibit A - Resolution No. PC2022-01
CONDITIONS OF APPROVAL
ARCHITECTURAL REVIEW NO. 21-13 SUNLINE TRANSIT HUB

General Conditions

1. Architectural Review 21-13 shall be valid for 12 months from the effective date of said Planning Commission approvals unless the applicant requests an extension of time and granted by the Planning Commission. The conditional use permit shall expire and shall become void one year following the date on which the conditional use became effective, unless prior to the expiration of one year a building permit is issued and construction is commenced and diligently pursued toward completion, or a certificate of occupancy is issued.
2. The applicant shall defend, indemnify and hold harmless the City of Coachella, its officials, officers, employees, and agents from and against any claim, action, or proceeding against the City, its officials, officers, employees or agents to attack, set aside, void or annul any project approval or condition of approval of the city concerning this project, including but not limited to any approval or condition of approval or mitigation measure imposed by the City Council or Planning Commission. The City shall promptly notify the applicant of any claim, action, or proceeding concerning the project and the City shall cooperate fully in the defense of the matter. The City reserves the right, at its own option, to choose its own attorney to represent the City, its officials, officers, employees and agents in the defense of the City Attorney, within five days of the effective date of this approval.
3. Within five business days of project approval, the applicant shall submit to the Planning Division a check made payable to the County of Riverside in the amount of \$50 for filing the CEQA Notice.
4. All plans, as shown, are considered “conceptual,” subject to revisions as called out by the conditions of this resolution. The plans shall not be stamp-approved until all conditions requesting revisions have been satisfied during the building plan check process. Any substantial changes to the plans, including changes shown on future building permit plans deemed by Staff to not be within substantial conformance with this approval, will require an amendment to the approval of the conditional use permit or architectural review.
5. All plan submittals are the responsibility of the developer; this includes plan submittals to the City of Coachella, the Riverside County Fire Department or to other agencies for whom plan review and approval is required.
6. The working drawings shall include within the first four pages a list of all conditions of approval included in this resolution.

Architectural Design

7. The applicant shall include project architectural design modifications prior to building permit submittal that include:
 - a. Ensuring sufficient window and door recesses on breakroom building.
 - b. Add stucco pattern that encapsulate the tile at the roof gables to create attractive shadow patterns to the breakroom building.
 - c. Incorporate date palm tree with the landscape design and substitute trees and plants with the types recommended in the Pueblo Viejo design guidelines.
 - d. Remove existing retention basin chain link fence and replace with decorative wrought iron fencing.
 - e. Utilize decorative window grilles and incorporate light green window color.
 - f. Add decorative lighting to the breakroom building.
8. Utilize two-piece clay tile roofing with booster tiles on the edges and random mortar packing. The mortar shall packed on 100 percent of the tiles in the first two rows of tiles and along any rake and ridgeline, and packed on 25 percent of the tiles on the remaining field. Mortar packing shall serve as a bird stop at roof edges. The volume of mortar pack to achieve the appropriate thickness shall be equivalent to a 6 inch diameter sphere of mortar applied to reach tile.
9. Stucco walls shall consist of 'steel, hand trowel', smooth Mission finish and slight undulations (applied during brown coat) and bull-nose corners and edges.
10. Any proposed trash enclosures installed for the project shall be compatible architecturally with the building. The enclosure shall be constructed to Burrtec Waste Management Standards and an open trellis shall be incorporated on all three proposed trash enclosures.

Public Realm/Streetscape

11. Setback the sidewalk along Cesar Chavez Street along landscape areas to create a landscape parkway to separate pedestrian traffic from street and allow for shade from afternoon sun and reduce heat island effect. Alternatively, place tree grates in proposed sidewalk area consistent with Pueblo Viejo Design Guidelines (page 4-180) that reduce heat island effect and provide shade from afternoon sun.
12. Widen 6-foot sidewalk areas to 8 feet to enhance pedestrian access.

Landscaping

13. Final landscaping and irrigation plans shall be submitted to the Development Services Department for review and approval. Said plans shall conform to the landscaping plan

submitted as part of the subject Architectural Review, and as conditioned herein. Landscape lighting shall be incorporated. All landscape materials shall be identified on a legend and identified graphically on a landscape plan including planting counts, tree caliper, and planted tree heights.

14. Add trees and plants at the retention basin between fencing and curb.
15. Decomposed granite for landscape areas shall be a minimum of $\frac{3}{4}$ inch.
16. Landscaping and irrigation shall be provided in accordance with Section 17.54.010(J) of the Municipal Code and in accordance with the State Model Water Efficient Landscape Ordinance (AB 1881). Water budget calculations, including the Maximum Applied Water Allowance (MAWA) and Estimated Total Water Use (ETWU) shall be provided as part of the landscaping and irrigation plan.
17. Combination of date palms and shade trees shall be incorporated into the landscape design which shall include Hong Kong Orchid or Chinese Elm trees, which are eligible trees in the Pueblo Viejo design guidelines. Plants shall be substituted with the succulents, shrubs, and perennials recommended in the Pueblo Viejo design guidelines.
18. The applicant shall submit, and must obtain approval from the Development Services Director, a letter from a registered landscape architect confirming that landscaping and irrigation have been installed in accordance with the approved plans prior to issuance of a certificate of occupancy. Any damaged, dead or decayed landscaping landscape areas within the remainder of the commercial center shall be replaced per approved landscape plans upon landscape inspection by the Development Services Department and prior to issuance of a certificate of occupancy/project completion.