Page 2 Request for Comments AR 18-11 Pueblo Viejo Plaza

Comments from Environmental Compliance:

- 1. Submit water and sewer plans for approval from Utilities Manager -project required to connect to City's public water and sewer system
- 2. Submit detailed plumbing and mechanical plans
- 3. Grease Interceptor required for **each** proposed restaurant
- Facility will be required to submit a source control survey; https://coachella.seamlessdocs.com/f/WkkhIf
- 5. The project will require a Water Quality Management Plan (WQMP) as it is a Priority Project
- 6. Install Above Ground "Double Check Detector Assembly" DCDA for fire system to protect water supply from contamination or pollution; must install separate AMI 4-G metering system
- 7. Backflow devices; will require Reduced Pressure Principle Device(RP) within 12 inches of water service installed to protect water supply from contamination or pollution; must install separate AMI 4-G metering system
- 8. Install separate AMI 4-G metering system for each building;
- 9. Install separate AMI 4-G water service meter for irrigation system;
- 10. The project must implement the State's drought mandate which prohibits irrigation with potable water outside newly constructed homes and buildings that is not delivered by drip or microspray systems;

Comments made by: **Berlinda Blackburn** Date: **01/08/2019**

Printed Name & Title: Berlinda Blackburn/Environmental/Regulatory Programs Manager_

Agency: <u>City of Coachella</u> Telephone #: 760-501-8114

Please return your comments to:
CITY OF COACHELLA

Attn: Luis Lopez, Development Services Director
Development Services Department
1515 6th Street
Coachella, CA 92236
(760) 398-3102x118 (760) 398-5421 FAX