

Request for Comments  
CZ 20-08, & CUP 336  
Pueblo Cannabis Co.

**Environmental Compliance Comments:**

This facility will be required to submit:

1. Submit detailed plumbing plans
2. Verify required backflow device
3. Submit the sizing criteria for a grease interceptor: online application can be found here: <https://coachella.seamlessdocs.com/f/Fs9RjX>
4. Submit a wastewater survey for coffee shop/and or microbusiness if food service establishment is proposed.- <https://coachella.seamlessdocs.com/f/WkkhIf>
5. All floor drains must 3/8” have strainers to prevent debris from entering sewer

Comments made by: **Berlinda Blackburn**      Date: **01/25/2021**

Printed Name & Title: **Berlinda Blackburn//Environmental/Regulatory Program Manager**

Agency: **City of Coachella**

Telephone #: **760-501-8114**

<p>Please return your comments to: CITY OF COACHELLA Attn: Luis Lopez, Development Services Director Development Services Department 53-990 Enterprise Way Coachella, CA 92236 (760) 398-3102x118</p>
---