

COHOCTAH TOWNSHIP

RESOLUTION NO. 2024-03

**RESOLUTION TO ADOPT AN ORDINANCE TO AMEND THE ZONING
ORDINANCE TO REGULATE UTILITY-SCALE BATTERY ENERGY STORAGE
SYSTEMS**

At a special meeting of the Township Board for the Township of Cohoctah, Livingston County, Michigan, held on the 11th day of July, 2024, at 7:00 p.m.

PRESENT: _____

ABSENT: _____

The following preamble and resolution were offered by _____
and seconded by _____.

WHEREAS, the Michigan Zoning Enabling Act, Public Act 110 of 2006, MCL 125.3101 *et seq.*, as amended, authorizes townships to adopt and amend zoning ordinances to regulate the use of land and structures within their zoning jurisdictions; and

WHEREAS, the Cohoctah Township Board (“Township Board”) has adopted such a zoning ordinance (“Zoning Ordinance”); and

WHEREAS, the Township Board desires to amend the Zoning Ordinance to regulate utility-scale battery energy storage systems; and

WHEREAS, the Cohoctah Township Planning Commission (“Planning Commission”) held a duly noticed public hearing on June 27, 2024 to consider amendments to the Zoning Ordinance regarding utility-scale battery energy storage systems (“Proposed Amendments”); and

WHEREAS, the Planning Commission recommended adoption of the Proposed Amendments to the Township Board; and

WHEREAS, the Livingston County Planning Commission reviewed the Proposed

Amendments at a meeting on July 9, 2024, and provided comments to the Township Board;

WHEREAS, the Township Board finds the Proposed Amendments promote the public health, safety, and welfare.

NOW, THEREFORE, the Cohoctah Township Board resolves as follows:

1. Ordinance No. 2024-03, An Ordinance to Amend the Zoning Ordinance to Regulate Utility-Scale Battery Energy Storage Systems (“Ordinance”), attached as **Exhibit A**, is hereby adopted.
2. The Ordinance will be filed with the Township Clerk.
3. The Township Clerk is to publish notice of adoption of the Ordinance in a newspaper of general circulation in the Township.
4. Any resolutions that conflict with this Resolution are hereby repealed to the extent necessary to give this Resolution full force and effect.

A vote on the above Resolution was taken and was as follows:

ADOPTED:

YEAS: _____

NAYS: _____

STATE OF MICHIGAN)
) ss.
COUNTY OF LIVINGSTON)

I, the undersigned, the duly qualified and acting Clerk for Cohoctah Township, Livingston County, Michigan, CERTIFY that the foregoing is a true and complete copy of certain proceedings taken by the Township Board of said Township at a meeting held on the 11th day of July, 2024.

Barb Fear, Township Clerk

EXHIBIT A

COHOCTAH TOWNSHIP

ORDINANCE NO. 2024-03

**AN ORDINANCE TO AMEND THE ZONING ORDINANCE
TO REGULATE UTILITY-SCALE BATTERY ENERGY STORAGE SYSTEMS**

The Township of Cohoctah ordains:

Section 1. Add Definitions to Section 2.02

The following definitions are added to Section 2.02 of the Zoning Ordinance, and will be placed in the Zoning Ordinances so that all definitions are in alphabetical order:

- A. Battery management system: An electronic regulator that manages a Utility-Scale Battery Energy Storage System by monitoring individual battery module voltages and temperatures, container temperature and humidity, off-gassing of combustible gas, fire, ground fault and DC surge, and door access and capable of shutting down the system before operating outside safe parameters.
- B. Utility-scale battery energy storage facilities: One or more devices, assembled together, capable of storing energy in order to supply electrical energy, including battery cells used for absorbing, storing, and discharging electrical energy in a Utility-Scale Battery Energy Storage System ("BESS") with a battery management system ("BMS").
- C. Utility-Scale Battery Energy Storage System: A physical container providing secondary containment to battery cells that is equipped with cooling, ventilation, fire suppression, and a battery management system.

Section 2. Add New Section 13.28 entitled “Utility-Scale Battery Energy Storage Systems”

Section 13.28, entitled “Utility-Scale Battery Energy Storage Systems,” is added to Article XIII of the Township’s Zoning Ordinance. The section reads in its entirety as follows:

Section 13.28 Utility-Scale Battery Energy Storage Systems.

- A. General Provisions. All Utility-Scale Battery Energy Storage Systems are subject to the following requirements:
 - 1. All Utility-Scale Battery Energy Storage Systems must conform to the provisions of this Ordinance and all county, state, and federal regulations and safety requirements, including applicable building codes, applicable industry standards, and NFPA 855 “Standard for the Installation of Stationary Energy Storage Systems”

2. The Township Planning Commission may issue a “stop work” order or order to cease operations to any Utility-Scale Battery Energy Storage System that does not comply with this Ordinance.

3. Utility-Scale Battery Energy Storage Systems are permitted in the Township as a special use in the following zoning districts:

a. Light Industrial LI

B. Application Requirements. The applicant for a Utility-Scale Battery Energy Storage System must provide the Township with all of the following:

1. Application fee in an amount set by resolution of the Township Board.
2. A list of all parcel numbers that will be used by the Utility-Scale Battery Energy Storage System; documentation establishing ownership of each parcel; and any lease agreements, easements, or purchase agreements for the subject parcels.
3. An operations agreement setting forth the operations parameters, the name and contact information of the operator, the applicant’s inspection protocol, emergency procedures, and general safety documentation.
4. Current photographs of the subject property.
5. A site plan that includes all proposed structures and the location of all equipment, as well as all setbacks, the location of property lines, signage, fences, greenbelts and screening, drain tiles, easements, floodplains, bodies of water, proposed access routes, and road right of ways. The site plan must be drawn to scale and must indicate how the Utility-Scale Battery Energy Storage System will be connected to the power grid.
6. A copy of the applicant’s power purchase agreement or other written agreement with an electric utility showing approval of an interconnection with the proposed Utility-Scale Battery Energy Storage System.
7. A written plan for maintaining the subject property, including a plan for maintaining and inspecting drain tiles and addressing stormwater management, which is subject to the Township’s review and approval.
8. A decommissioning and land reclamation plan describing the actions to be taken following the abandonment or discontinuation of the Utility-Scale Battery Energy Storage System, including evidence of proposed commitments with property owners to ensure proper final reclamation, repairs to roads, and other steps necessary to fully remove the Utility-Scale Battery Energy Storage System and restore the subject parcels, which is subject to the Township’s review and approval.
9. Financial security that meets the requirements of this Section, which is subject to the Township’s review and approval.

10. A plan for resolving complaints from the public or other property owners concerning the construction and operation of the Utility-Scale Battery Energy Storage System, which is subject to the Township's review and approval.

11. A plan for managing any hazardous waste, which is subject to the Township's review and approval.

12. A fire protection plan, which identifies the fire risks associated with the Utility-Scale Battery Energy Storage System; describes the fire suppression system that will be implemented; describes what measures will be used to reduce the risk of fires re-igniting (i.e., implementing a "fire watch"); identifies the water sources that will be available for the local fire department to protect adjacent properties; identifies a system for continuous monitoring, early detection sensors, and appropriate venting; and explains all other measures that will be implemented to prevent, detect, control, and suppress fires and explosions.

13. A transportation plan for construction and operation phases, including any applicable agreements with the County Road Commission and Michigan Department of Transportation, which is subject to the Township's review and approval.

14. An attestation that the applicant will indemnify and hold the Township harmless from any costs or liability arising from the approval, installation, construction, maintenance, use, repair, or removal of the Utility-Scale Battery Energy Storage System, which is subject to the Township's review and approval.

15. Proof of environmental compliance, including compliance with Part 31, Water Resources Protection, of the Natural Resources and Environmental Protection Act; (MCL 324.3101 et. seq.; Part 91, Soil Erosion and Sedimentation Control (MCL 324.9101 et. seq.) and any corresponding County ordinances; Part 301, Inland Lakes and Streams, (MCL 324.30101 et. seq.); Part 303, Wetlands (MCL 324.30301 et. seq.); Part 365, Endangered Species Protection (MCL 324.36501 et. seq.); and any other applicable laws and rules in force at the time the application is considered by the Township

16. Any additional information or documentation requested by the Planning Commission, Township Board, or other Township representative.

C. System and Location Requirements.

1. *Minimum Acreage.* Utility-Scale Battery Energy Storage Systems must be located on parcels of land 40 acres in size or larger.

2. *Lot Area Coverage.* No more than 40% of the total lot area may be covered by a Utility-Scale Battery Energy Storage System.

3. *Setbacks.* Utility-Scale Battery Energy Storage Systems must be set back at least 500 feet from all lot lines and public road rights-of-way. If a single Utility-Scale Battery Energy Storage System is located on more than one lot, then the lot-line setbacks of this subsection do not apply to the lot lines shared by those lots.

4. *Screening.* Greenbelt screening is required around any Utility-Scale Battery Energy Storage System and around any equipment associated with the system to obscure, to the greatest extent possible, the Utility-Scale Battery Energy Storage System from any adjacent residences. The greenbelt must consist of shrubbery, trees, or other non-invasive plant species that provide a visual screen. In lieu of a planting greenbelt, a decorative fence that is at least 50% opaque and that meets the requirements of this Ordinance applicable to fences may be used if approved by the Planning Commission.

5. *Lighting.* Lighting of the Utility-Scale Battery Energy Storage System is limited to the minimum light necessary for safe operation. Illumination from any lighting must not extend beyond the perimeter of the lot(s) used for the Utility-Scale Battery Energy Storage System. The Utility-Scale Battery Energy Storage System must not produce any glare that is visible to neighboring lots or to persons traveling on public or private roads.

6. *Security Fencing.* Security fencing must be installed around all electrical equipment related to the Utility-Scale Battery Energy Storage System. Appropriate warning signs must be posted at safe intervals at the entrance and around the perimeter of the Utility-Scale Battery Energy Storage System.

7. *Noise.* The noise generated by a Commercial Utility-Scale Battery Energy Storage System must not exceed 40 dBA Lmax / A-weighted scale, as measured at the property line of any adjacent parcel / nearest outer wall of the nearest dwelling located on an adjacent nonparticipating property.

8. *Underground Transmission.* All power transmission or other lines, wires, or conduits from a Utility-Scale Battery Energy Storage System to any building or other structure must be located underground at a depth that complies with current National Electrical Code standards, except for power switchyards or the area within a substation.

9. *Drain Tile Inspections.* The Utility-Scale Battery Energy Storage System must be maintained in working condition at all times while in operation. The applicant or operator must inspect all drain tile at least once every three years by means of robotic camera, with the first inspection occurring before the Utility-Scale Battery Energy Storage System is in operation. The applicant or operator must submit proof of the inspection to the Township. The owner or operator must repair any damage or failure of the drain tile within sixty (60) days after discovery and submit proof of the repair to the Township. The Township is entitled, but not required, to have a representative present at each inspection or to conduct an independent inspection.

10. *Fire Protection.*

- a. Before any construction of the Utility-Scale Battery Energy Storage System begins, the Township's fire department (or fire department with which the Township contracts for fire service) will review the fire protection plan submitted with the application under Section (B)(12) above. The fire chief will determine whether the fire protection plan adequately protects the Township's residents and property and whether there is sufficient water supply to comply with the fire protection plan and to respond to fire or explosion incidents. If the fire chief determines that the plan is

adequate, then the fire chief will notify the Township Supervisor of that determination. If the fire chief determines that the plan is inadequate, then the fire chief may propose modifications to the plan, which the applicant or operator of the Utility-Scale Battery Energy Storage System must implement. The fire chief's decision may be appealed to the Township Board, and the Township Board will hear the appeal at an open meeting. The Township Board may affirm, reverse, or modify the fire chief's determination. The Township Board's decision is final, subject to any appellate rights available under applicable law.

- b. The applicant or operator may amend the fire protection plan from time-to-time in light of changing technology or other factors. Any proposed amendment must be submitted to the fire department for review and approval under subsection (a).
 - c. The Utility-Scale Battery Energy Storage System must comply with the fire protection plan as approved by the fire chief (or as approved by the Township Board in the event of an appeal).
11. *Insurance.* The applicant or operator will maintain property/casualty insurance and general commercial liability insurance in an amount of at least \$5 million per occurrence.
12. *Permits.* All required county, state, and federal permits must be obtained before the Utility-Scale Battery Energy Storage System begins operating.
13. *Decommissioning.* If a Utility-Scale Battery Energy Storage System is abandoned or otherwise nonoperational for a period of one year, the property owner or the operator must notify the Township and must remove the system within 90 days after the date of abandonment. Removal requires receipt of a demolition permit from the Building Official and full restoration of the site to the satisfaction of the Zoning Administrator. The site must be filled and covered with top soil and restored to a state compatible with the surrounding vegetation. The requirements of this subsection also apply to a Utility-Scale Battery Energy Storage System that is never fully completed or operational if construction has been halted for a period of 180 days.
14. *Financial Security.* To ensure proper decommissioning of a Commercial Utility-Scale Battery Energy Storage System upon abandonment, the applicant must post financial security in the form of a security bond, escrow payment, or irrevocable letter of credit in an amount equal to 125% of the total estimated cost of decommissioning, code enforcement, and reclamation, which cost estimate must be approved by the Township. The operator and the Township will review the amount of the financial security every two (2) years to ensure that the amount remains adequate. This financial security must be posted within fifteen (15) business days after approval of the special use application.
15. *Extraordinary Events.* If the Utility-Scale Battery Energy Storage System experiences a failure, fire, leakage of hazardous materials, personal injury, or other extraordinary or catastrophic event, the applicant or operator must notify the Township within 8 hours.
16. *Annual Report.* The applicant or operator must submit a report on or before November 1 of each year that includes all of the following:

- a. Current proof of insurance;
- b. Verification of financial security; and
- c. A summary of all complaints, complaint resolutions, and extraordinary events; and
- d. Written notice of any change or addition of equipment.

17. *Inspections.* The Township may inspect a Utility-Scale Battery Energy Storage System at any time by providing 24 hours advance notice to the applicant or operator.

18. *Transferability.* A special use permit for a Utility-Scale Battery Energy Storage System is transferable to a new owner. The new owner must register its name and business address with the Township and must comply with this Ordinance and all approvals and conditions issued by the Township.

19. *Remedies.* If an applicant or operator fails to comply with this Ordinance, the Township, in addition to any other remedy under this Ordinance, may revoke the special use permit and site plan approval after giving the applicant or operator notice and an opportunity to be heard. Additionally, the Township may pursue any legal or equitable action to abate a violation and recover any and all costs, including the Township's actual attorney fees and costs.

20. *Height Restriction.* Containers shall be stacked on top of each other. Container must be in a single layer only and limited to the average industry standard height for a storage container.

21. *Complaint resolution.* Utility-Scale Battery Energy Storage Systems shall provide a complaint resolution process, as described below:

- a. The site shall have signs posted with contact information to collect complaints related to the Utility-Scale Battery Energy Storage System.
- b. A log shall be kept by the owner/operator of all complaints received and shall be available to Township officials for review at the Township's request.
- c. The owner/operator shall respond to complainants within ten (10) business days and shall provide notification to the Zoning Administrator.
- d. Any resolution shall include lawful and reasonable solutions consistent with the Zoning Ordinance, which shall also be provided to the Zoning Administrator.
- e. The owner/operator or its assigns reserve the right to adjudicate any claims made against it, including residential claims, in a court of competent jurisdiction. An annual report shall be submitted to the Zoning Administrator and the Township Board that details all complaints received, the status of complaint resolution, and actions taken to mitigate complaints.

D. Utility-Scale Battery Energy Storage Systems under PA 233.

On or after November 29, 2024, once PA 233 of 2023 is in effect, then the following provisions apply to Utility-Scale Battery Energy Storage Systems with a nameplate capacity of 50 megawatts or more and an energy discharge capability of 200 megawatt hours or more. To the extent these provisions conflict with the provisions in Sections A through C above, these provisions control as to such Utility-Scale Battery Energy Storage Systems. This subsection does not apply if PA 233 is repealed, enjoined, or otherwise not in effect and does not apply to Utility-Scale Battery Energy Storage Systems with a nameplate capacity of less than 50 megawatts and an energy discharge capability of less than 200 megawatt hours. All provisions in subsections A-C above that do not conflict with this subsection remain in full force and effect.

1. *Setbacks.* Utility-Scale Battery Energy Storage Systems must comply with the following minimum setback requirements, with setback distances measured from the nearest edge of the perimeter fencing of the facility:

Setback Description	Setback Distance
Occupied community buildings and dwellings on nonparticipating properties	300 feet from the nearest point on the outer wall
Public road right-of-way	50 feet measured from the nearest edge of a public road right-of-way
Nonparticipating parties	50 feet measured from the nearest shared property line

2. *NFPA Standard.* Utility-Scale Battery Energy Storage Systems must comply with the version of NFPA 855 “Standard for the Installation of Stationary Energy Storage Systems” in effect on the effective date of the amendatory act that added this section or any applicable successor standard adopted by the commission as reasonable and consistent with the purposes of this subdivision.

3. *Noise.* The Utility-Scale Battery Energy Storage System must not generate a maximum sound in excess of 55 average hourly decibels as modeled at the nearest outer wall of the nearest dwelling located on an adjacent nonparticipating property. Decibel modeling shall use the A-weighted scale as designed by the American National Standards Institute.

4. *Lighting.* The Utility-Scale Battery Energy Storage System must implement dark sky-friendly lighting solutions.

5. *Environmental Regulations.* The Utility-Scale Battery Energy Storage System must comply with applicable state or federal environmental regulations.

6. *Host community agreement.* The applicant shall enter into a host community agreement with the Township. The host community agreement shall require that, upon

commencement of any operation, the Utility-Scale Battery Energy Storage System owner must pay the Township \$2,000.00 per megawatt of nameplate capacity. The payment shall be used as determined by the Township for police, fire, public safety, or other infrastructure, or for other projects as agreed to by the local unit and the applicant.

Section 3. Amend Section 11.03.

Section 11.03 of the Zoning Ordinance is amended to add the following use permitted by special use permit with conditions in the Light Industrial zoning district:

- Utility-Scale Battery Energy Storage System

Section 4. Validity and Severability.

If any portion of this Ordinance is found invalid for any reason, such holding will not affect the validity of the remaining portions of this Ordinance.

Section 5. Repealer.

All other ordinances inconsistent with the provisions of this Ordinance are hereby repealed to the extent necessary to give this Ordinance full force and effect.

Section 6. Effective Date.

This Ordinance takes effect seven (7) days after publication as provided by law.

88436:00001:200649478-1