



City of Columbia Heights | *Community Development*

590 40th Avenue NE, Columbia Heights, MN 55421 ▪ Ph: 763-706-3670 ▪ Fax: 763-706-3671 ▪ www.columbiaheightsmn.gov

10/23/2020

Re: 1329 41st Ave. NE,
Columbia Heights, MN 55421

Walls and projections less than 5ft from property lines shall be protected with a fire-resistance rating of 1 hour. The plans submitted shall show an assembly that has been tested in accordance with ASTM E119, UL263, or Section 703.3 of the International Building Code with exposure from both sides as required by MSRC Table R302.1(1).

If you have any questions please call (763)706-3677.

Sincerely,

Ryan Smith
Building Official