## **2024 AGENDA ITEM**

Utility Commission Meeting Date: 11/21/2024

ITEM: October 26, 2024 - Electrical Outage - 5F/42/39

## **DETAILED DESCRITPTION OF SUBJECT MATTER:**

On October 26<sup>th</sup>, 2024 at 9:28AM an animal came into contact with equipment. This caused a fuse to blow inside the transformer due to equipment overload. Power was restored at 9:55AM, 3 customers were affected.

## LIST ALL SUPPORTING DOCUMENTATION ATTACHED:

1. Utility Electrical Outage Report 10/26/2024

## **ACTION REQUESTED OF COMMISSION:**

1. Information Only