

353 W. School Street – current and proposed driveway

1. Driveway permit for new driveway not constructed to code and permit requirements



2. Apron flare on left missing (left arrow)
3. Utilities not moved
4. Curb cut and gutter not constructed (right arrow)

353 W. School St. (South Main St. side yard/proposed second driveway location)

