

950 Maple Avenue
PO Box 228
Columbus, WI 53925
Email: cwl@columbuswaterandlight.com

People You Know ... Service You Trust, Since 1896

Phone (920)623-5912

FAX (920) 623-5923

www.columbuswaterandlight.com

Plant #1 Softener Valve Replacement Project:

- Started on 4/7/25 with Stabb Construction removing all of the old softener valves and replacing them with the new and improved valves
- Ran into some hiccups removing some of the old larger valves
- Called in Russ with Water Tank and Coat to assist with bleaching the iron filter and draining the drinking water reservoir
 - o This is due to the water sitting stagnant in the iron filter and drinking water reservoir for 3 months
 - o Jake Tanner wanted to ensure the water was safe to drink for the customers of Columbus once the project is completed
- Bleached the iron filter on 4/10/25 with Russ and letting it sit with a 0.2 mg/L residual of chlorine in the iron filter over the weekend. On Monday 4/14/25 Jake and Craig will rinse the chlorine out of the iron filter
- Tuesday 4/11/25 Stabb, Doner valves, and Ruckert-mielke will be on site to start testing the new air system with the new valves on the softener system
- Thursday 4/17/25 Russ will be back to drain the reservoir and assist with taking bacteria samples to go back online

Please see the photos of the project so far.



old valves



New valves installed



New valve