

## **2024 AGENDA ITEM**

**Utility Commission Meeting Date: 10/17/2024**

**ITEM:** Replacement of Hydrant 118 Meister Drive – Dollar Tree

### **DETAILED DESCRIPTION OF SUBJECT MATTER:**

The construction of the Dollar Tree at 118 Meister Drive has been challenging in regards to the water service. The bacteriological testing initially failed and needed to be retested and then passed. The pressure testing of the line failed, and the contractor was ordered to make repairs to the hydrant that is onsite.

The contractor made the appropriate repairs of the hydrant and attempted the pressure test yet again. The pressure test once again failed. In conversation with the Project Manager at Ruekert & Mielke it was agreed by the contractor, Project Manager, and Utility Director that the Utility would authorize the installation of a new hydrant and would pay the contractor for the materials and service.

Upon completion the line will once again be pressure tested. If the pressure test fails, the contractor has agreed that the problem lies within the line that was constructed during the construction and will need to be excavated and repaired to meet the pressure requirements at NO CHARGE to the City or Utility.

The contractor performing the work CJ Kavon Company, LLC has provided the quote for the work and due to the fact they have performed all the work at the site it is highly recommended that they perform this task as well simply due to the liability factor that will be associated with the pending test results.

### **LIST ALL SUPPORTING DOCUMENTATION ATTACHED:**

1. Quote for Hydrant and Installation from CJ Kavon Company, LLC

### **ACTION REQUESTED OF COMMISSION:**

Review, discuss, and approve the replacement of the hydrant for the quoted amount of **\$12,265** from CJ Kavon Company, LLC.