## **2024 AGENDA ITEM**

**Utility Commission Meeting Date: 10/17/2024** 

ITEM: October 2, 2024 – Water Outage Church Street North including all of Meister Park Neighborhood

## **DETAILED DESCRIPPTION OF SUBJECT MATTER:**

On October 2<sup>nd</sup>, 2024 construction work at Meister Park for a new Sewage Lift Station prompted and emergency shutoff of all water service north of the Crawfish River. A mislocated water main was struck by the bucket of a large excavator causing a break in the water main. Isolation near the break failed and corrective actions were taken to remove water pressure from the surrounding area while the break could be evaluated and repaired. Water service to the area was disrupted for roughly 8 hours and the Utility lost roughly 80,000 gallons of water during the incident. Water was returned to customers by roughly 8:00PM that evening.

## LIST ALL SUPPORTING DOCUMENTATION ATTACHED:

1. None

## **ACTION REQUESTED OF COMMISSION:**

1. Information Only