

2024 AGENDA ITEM

Utility Commission Meeting Date: 9/19/2024

ITEM: August 29, 2024 Middleton & Dickason

DETAILED DESCRIPTION OF SUBJECT MATTER:

On August 29, 2024 at 7:41AM animal contact caused the fuse to blow at 3F/80/96 on Circuit #206 of Substation #2. 69 customers were without power for 39 minutes. Power was restored at 8:20AM.

LIST ALL SUPPORTING DOCUMENTATION ATTACHED:

1. See Attached Columbus Water & Light Customer Outage Report.

ACTION REQUESTED OF COMMISSION:

1. Review Outage Report.