

**COLUMBUS WATER & LIGHT CUSTOMER OUTAGE REPORT**

SUBSTATION Sub 4 CIRCUIT # 401 DATE 11/5/2026

LOCATION OF FUSE OR RECLOSER SF/56/07

CUSTOMER NAME OR LOCATION \_\_\_\_\_

REMARKS Old porcelain cutout broke from age and cracking

**PART THAT FAILED**

- 0 None
- 1 Numerous
- 2 Other-note in remarks
- 3 Transmission equipment
- 4 Substation equipment

**O.H. DISTRIBUTION**

- 10 Anchor or guy
- 11 Arrester
- 12 Conductor - Primary
- 13 " - Secondary
- 14 Connector
- 21 Insulator
- 24 Metering equipment
- 25 Pole
- 26 Recloser
- 27 Riser or Jumper
- 28 Splice
- 29 Switch - GOAB
- 30 " - Disc.
- 31 Cutout - Fused
- 32 Transformer - Line
- 33 Transformer - Potential

**U.G. DISTRIBUTION**

- 50 Arrester
- 51 Conductor - Primary
- 52 " - Secondary
- 53 Connector - Bolted
- 54 " - Comp.
- 55 " - Elbow
- 56 " - Splice
- 59 Terminator
- 60 Transformer - Pad Mount
- 61 Transformer - Bayonet Fuse
- 62 Metering Equipment

**WEATHER**

- 1 Normal
- 2 Wind
- 3 Thunderstorm
- 4 Rain
- 5 Rain and wind
- 6 Fog
- 7 Ice
- 8 Ice and wind
- 9 Snow
- 10 Extreme cold
- 11 Extreme heat
- 12 Extreme storm

**CAUSE**

- 0 Unknown
- 1 Loss of supply
- 2 Operating error
- 3 Circuit overload
- 4 Mis-coordination
- 5 Faulty installation
- 6 Lightning
- 7 Wind
- 8 Ice
- 9 Cold weather
- 10 Hot Weather
- 11 Moisture
- 12 Contamination
- 13 Fire
- 14 Extreme storm

**FOREIGN OBJECTS**

- 20 Vehicles
- 22 Trees - tore down
- 23 Trees - shorted
- 24 Animals
- 25 Birds
- 26 Underground dig in
- 27 Vandalism
- 28 Other

**EQUIPMENT**

- 30 Manufacturing defect
- 31 Equipment overload
- 32 Electrical failure
- 33 Worn out

(use 24 hour time)

TIME OFF 9:07am ON 9:51am

Number of Calls 1

Number of Customers	Minutes Duration
<u>6</u>	<u>44</u>

**TRANSFORMER FAILURE**

CWL# \_\_\_\_\_ KVA \_\_\_\_\_

MFG \_\_\_\_\_ AGE (est) \_\_\_\_\_

Serial # \_\_\_\_\_

Arrester ON / OFF Tank (circle one)

**ARRESTOR FAILURE**

MFR \_\_\_\_\_ Porc Polymer  
Riser Line Transformer  
(circle all that apply)

**DEVICE THAT OPENED**

Distribution  
Main Feeder

Breaker \_\_\_\_\_ Counter \_\_\_\_\_

Targets \_\_\_\_\_

**Branch Line**

O.C.R. \_\_\_\_\_ Size \_\_\_\_\_

Fuse \_\_\_\_\_ Size \_\_\_\_\_

Fuse 8a Transformer Transf. Size 375

**ROUTING (initial)**

Responded By JH

Line Assisted By MM

Assisted By DH

Manager JB

Outage File \_\_\_\_\_