

COLUMBUS WATER & LIGHT CUSTOMER OUTAGE REPORT

SUBSTATION 4CIRCUIT # 403DATE 11/13/2025

LOCATION OF FUSE OR RECLOSER

Sunset Circle 6DB918

CUSTOMER NAME OR LOCATION

Sunset CircleREMARKS SquirrelsPART THAT FAILED

0 None
 1 Numerous
 2 Other-note in remarks
 3 Transmission equipment
 4 Substation equipment
O.H. DISTRIBUTION
 10 Anchor or guy
 11 Arrester
 12 Conductor – Primary
 13 " – Secondary
 14 Connector
 21 Insulator
 24 Metering equipment
 25 Pole
 26 Recloser
 27 Riser or Jumper
 28 Splice
 29 Switch - GOAB
 30 " - Disc.
31 Cutout - Fused
 32 Transformer – Line
33 Transformer – Potential

U.G. DISTRIBUTION

50 Arrester
 51 Conductor – Primary
 52 " – Secondary
 53 Connector – Bolted
 54 " – Comp.
 55 " – Elbow
 56 " – Splice
 59 Terminator
 60 Transformer – Pad Mount
 61 Transformer – Bayonet Fuse
 62 Metering Equipment

WEATHER

1 Normal
 2 Wind
 3 Thunderstorm
 4 Rain
 5 Rain and wind
 6 Fog
 7 Ice
 8 Ice and wind
 9 Snow
10 Extreme cold
 11 Extreme heat
 12 Extreme storm

CAUSE

0 Unknown
 1 Loss of supply
 2 Operating error
 3 Circuit overload
 4 Mis-coordination
 5 Faulty installation
 6 Lightning
 7 Wind
 8 Ice
 9 Cold weather
 10 Hot Weather
 11 Moisture
 12 Contamination
 13 Fire
 14 Extreme storm

FOREIGN OBJECTS

20 Vehicles
 22 Trees – tore down
23 Trees – shorted
24 Animals
 25 Birds
 26 Underground dig in
 27 Vandalism
 28 Other

EQUIPMENT

30 Manufacturing defect
 31 Equipment overload
 32 Electrical failure
 33 Worn out

(use 24 hour time)

TIME OFF _____ ON _____

Number of Calls 1Number of Customers 4 Minutes Duration 30 minTRANSFORMER FAILURE

CWL# _____ KVA _____

MFG _____ AGE (est) _____

Serial # _____

Arrester ON / OFF Tank (circle one)

ARRESTOR FAILUREMFR _____ Porc Polymer
Riser Line Transformer
(circle all that apply)DEVICE THAT OPENEDDistribution
Main Feeder

Breaker _____ Counter _____

Targets _____

Branch LineO.C.R. _____ Size _____
Fuse 60/59/88 Size 10Amp

Fuse _____ Transf. Size _____

ROUTING (initial)Responded By Jeff RechtLine Assisted By Tony BonessDalton Hiley
Mason Masher

Assisted By _____

Manager _____

Outage File _____