

Public Works Department Monthly Report October 2023

Listed below is a summary of the activities of the Public Works Department for October

STREETS, PROPERTIES, AND STORM SEWER

- Patched potholes as needed.
- Mowed Town property
- Swept the streets on the parade route.
- Distributed/collected barricades for the parade.
- Installed the "temporary No Parking" signs for the parade.
- Completed residential limb/stick chipping.
- Started leaf pick up.
- Replaced over 100ft of broken sidewalk at various locations.
- Continued the ped path north and extended the culvert on Klein Avenue
- Poured concrete and installed bike racks.
- Installed 3 new garbage cans. Two along the path and one at the splash pad.
- Repaired two LED drivers in streetlights.





EQUIPMENT/VEHICLE MAINTENANCE AND REPAIRS

- Squad 21 Oil Change and fill tires with air.
- Squad 20 Oil Change
- Squad 19 Oil Change
- Squad 17 Oil Change
- Truck 01 Oil Change
- Truck 06 Oil Change
- Truck 10 Oil Change
- Truck 12 Oil Change
- Truck 17 Oil Change
- Replaced Tires on the Leaf Vac
- Leaf Vac Oil Change
- All Trucks and Trailers went to the safety lane.
- Truck 01 had a new rear tire installed because of a puncture.

TRAINING

Jeff Lemke has obtained his Class A CDL

WATER AND WASTEWATER

GENERAL


• Completed work orders for:

| Shut-Off Service: | 0 |
|---|--------|
| Turn On Service: | 0 |
| Final Read: | 15 |
| Courtesy Read: | 0 |
| Julie Locate Requests: | 87 |
| New Meters Installed: | |
| Existing Meters Replaced with New Meter | ers: 2 |
| Other: | |
| Final Inspections: | 0 |
| Total Work Orders: | 7 |


WASTEWATER

- Approx. 9,896,000 gallons flowed into the treatment plant.
- Approx. 0 gallons were discharged.
- The Discharge Monitoring Report (DMR) was completed and filed with the IEPA.
- Completed monthly wastewater sampling.
- Completed normal sewer main jetting.
- Continued with maintenance overhaul of all the process equipment at STP and disc filters.
- Replaced all discs in the disc filter units.

INFLUENT




EFFLUENT



WATER

- Completed daily lab samples related to water quality. (pH, Fluoride, Chlorine, Hardness)
- Monthly chemical injection reports were completed and mailed to the IEPA.
- Completed monthly sampling.
- Completed meter reading for utility billing.
- Completed re-reads.
- Rebuilt the Well 2 CL2 pump.
- Completed scheduled Radium sampling.



| Well 1 | 94,400 |
|--------|-----------|
| Well 2 | 52,300 |
| Well 3 | 1,363,000 |
| Well 4 | 6,406,200 |

Total pumpage of treated water from wells for October 2023: 7,915,900