



CITY COUNCIL ITEM SUMMARY

MEETING DATE:	April 20, 2023
SUBCATEGORY:	Bid Award/Purchases
DEPARTMENT NAME:	Water
AGENDA ITEM TITLE:	Lift Station Pump Repair
DEPARTMENT SUMMARY RECOMMENDATION:	<p>One of two sewer lift station submersible pumps serving the area east of I-75 on Main Street has failed and needs major repair or replacement. The Water Department received quotes for repair and replacement of the pump from the sole source service/manufacturer, Xylem Water Solutions USA, Inc. The repair cost is \$46,882.92 and the replacement cost is \$70,418.60.</p> <p>It is the Water Department's intention to replace this entire lift station within the next fiscal year, as it was not designed for the demand of development in this area and the current pumps would be inadequate for the new lift station. For this reason, I recommend repair of the pump for a cost of \$46,882.92.</p> <p>This is a budgeted maintenance expense to be paid from account 505.3330.52.2361.</p>
LEGAL:	N/A