



CITY COUNCIL ITEM SUMMARY

MEETING DATE:	May 18, 2023
SUBCATEGORY:	Engineering Services
DEPARTMENT NAME:	Water Department
AGENDA ITEM TITLE:	Overlook Gravity Sewer Engineering
DEPARTMENT SUMMARY RECOMMENDATION:	<p>The current sewer lift station at Overlook Parkway is not adequately located nor does it have sufficient capacity to serve the current and proposed residential development in that area. The City has identified a location for a replacement lift station to properly serve the developable property in this basin. This will require laying approximately 2,100 feet of 12-inch gravity sewer from the current lift station to the proposed new lift station.</p> <p>In accordance with the Engineering Services agreement dated August 18, 2022, Sweitzer Engineering has submitted Task Order #3 for a not-to-exceed price of \$80,000, which includes the design through the bid phase of the project.</p> <p>I recommend approval of this task order. This is not a currently budgeted expense, but it is included in the FY23_24 budget. Funds are available and will be paid by sewer capacity fee revenue.</p>
LEGAL:	N/A