



## CITY COUNCIL ITEM SUMMARY

<b>MEETING DATE:</b>	February 20, 2025
<b>SUBCATEGORY:</b>	Bid Award/Purchases
<b>DEPARTMENT NAME:</b>	Water
<b>AGENDA ITEM TITLE:</b>	Alum Pump Replacement
<b>DEPARTMENT SUMMARY RECOMMENDATION:</b>	<p>The #1 aluminum sulfate (alum) pump at the WPCP needs rebuilding or replacement. To rebuild the existing pump would cost \$7,919.00, but to replace it with a newer model with a replaceable head costs \$8,638.00. The replaceable head would eliminate the need for rebuilds in the future.</p> <p>I recommend the purchase of a new Watson-Marlow QDOS pump and head from Eco-Tech for \$8,638.00. This is a budgeted maintenance expense.</p>
<b>LEGAL:</b>	N/A