



## CITY COUNCIL ITEM SUMMARY

**MEETING DATE:**

April 18, 2024

**SUBCATEGORY:**

Bid Award/Purchases

**DEPARTMENT NAME:**

Water Department

**AGENDA ITEM TITLE:**

Flow Meter Console Replacement

**DEPARTMENT SUMMARY  
RECOMMENDATION:**

The Water Treatment Plant uses acoustic transit time flow meters to accurately measure flow pumped into the City's water distribution system by the high service pumps. The original Accusonic console for high service pump station #2, installed in 2007 has failed and needs replacement.

The sole source provider of this equipment, Accusonic has provided a quote for a new, updated replacement console at a cost of \$42,478.00. This cost includes material, installation, commissioning, and one-year parts and labor warranty.

This is a budgeted maintenance item and is recommended for your approval.

**LEGAL:**

N/A