



CITY COUNCIL ITEM SUMMARY

MEETING DATE:	March 18, 2021
SUBCATEGORY:	Bid Award/Purchase
DEPARTMENT NAME:	Water Department
AGENDA ITEM TITLE:	Main Street Lift Station Pump Replacement
DEPARTMENT SUMMARY RECOMMENDATION:	<p>One submersible, Flygt pump in the Main Street sewer lift station has failed. This pump has been rebuilt several times since it's initial installation in 1998.</p> <p>We've requested both a rebuild and replacement quote from the manufacturer. Repair cost is \$13,513.42, and replacement cost is \$17,564.70.</p> <p>Your approval is recommended for a new replacement pump for \$17,564.70. This will be paid from account 505-3330-52-2361, and is a budgeted item.</p>
LEGAL:	N/A