



CITY COUNCIL ITEM SUMMARY

MEETING DATE:	January 22, 2026
SUBCATEGORY:	Bid Award/Purchases
DEPARTMENT NAME:	Water
AGENDA ITEM TITLE:	Valve Actuator Replacement
DEPARTMENT SUMMARY RECOMMENDATION:	The operator gearbox on the 48” filter bypass plug valve at the WPCP has failed and needs replacement. The Water Department received quotes for replacement and for the addition of an electric actuator for this valve. Chalmers & Kubeck South (C&K) submitted the best bid of \$60,065.00. The recommendation of award to the best bid is due to C&K being a certified Pratt Valve repair shop and having approximately 20-week shorter lead time for material than other bidders. I recommend awarding this work to Chalmers and Kubeck South for \$60,065.00. This is a budgeted maintenance item.
LEGAL:	N/A