



CITY COUNCIL ITEM SUMMARY

MEETING DATE:	May 20, 2021
SUBCATEGORY:	Bid Award/Purchases
DEPARTMENT NAME:	Water Department
AGENDA ITEM TITLE:	Fairview Tank Exterior Painting
DEPARTMENT SUMMARY RECOMMENDATION:	<p>The water storage tank on Fairview Street is a 5 million-gallon, steel tank built in 1969. The existing surface paint was applied in 2000 over the top of the older base coat. The coating is beginning to delaminate near the bottom of the tank and is corroded through over much of the tank surface.</p> <p>Due to the presence of lead in the older base coatings, bids were solicited from companies with experience removing and disposing of lead-based paint, in addition to applying a new AWWA approved coating system. Bids received were as follows:</p> <p>Utility Service Co., Inc. - \$546,200.00 Classic Protective Coatings - \$724,950.00 Southern Road & Bridge - \$934,000.00 E&D Contracting Services, Inc. - \$2,783,810.00</p> <p>The low bid of \$546,200.00 by Utility Service Co., Inc. is recommended for your approval.</p> <p>This is a budgeted, bond funded project to be paid from account 505-3320-54-3401.</p>
LEGAL:	N/A