



## CITY COUNCIL ITEM SUMMARY

|   |  |
|---|--|
| <b>MEETING DATE:</b>                      | November 17, 2022  |
| <b>SUBCATEGORY:</b>                       | Bid Award/Purchases  |
| <b>DEPARTMENT NAME:</b>                   | Water  |
| <b>AGENDA ITEM TITLE:</b>                 | Slide Gate Installation  |
| <b>DEPARTMENT SUMMARY RECOMMENDATION:</b> | <p>The influent gates for the secondary lift station in the Water Pollution Control Plant were installed in 1990. Though well maintained, they have deteriorated to the point that they will not seal sufficiently to allow for maintenance on the secondary lift station screw pumps. The replacement gates were purchased last year and are on site. The size of the gates coupled with the speed with which they must be replaced necessitates hiring a contractor for the work.</p> <p>We requested and received three quotes for the work from contractors we have used previously. I recommend awarding the job to the low bidder, Southern Machine &amp; Fabrication for \$17,000.00.</p> <p>This is a budgeted maintenance expense to be paid from account 505.3330.52.2361.</p> |
| <b>LEGAL:</b>                             | N/A  |