



CITY COUNCIL ITEM SUMMARY

MEETING DATE:	May 6, 2021
SUBCATEGORY:	Bid Award/Purchases
DEPARTMENT NAME:	Water Department
AGENDA ITEM TITLE:	Press Building AC Replacement
DEPARTMENT SUMMARY RECOMMENDATION:	<p>The air conditioning unit for the press building at the WPCP has a ruptured evaporator coil and needs replacing. This unit is 8 years old and not under warranty.</p> <p>Quotes were solicited from local vendors with the lowest bid being from Weaver Heating and Air Inc. for \$9,618.00.</p> <p>This recommended purchase is a budgeted expense to be paid from the "Maintenance – Heating & A/C" line item, 505-3330-52-2350.</p>
LEGAL:	N/A