



CITY COUNCIL ITEM SUMMARY

MEETING DATE:	May 6, 2021
SUBCATEGORY:	Bid Award/Purchases
DEPARTMENT NAME:	Water Department
AGENDA ITEM TITLE:	WPCP Limatorque Slide Gate Actuator
DEPARTMENT SUMMARY RECOMMENDATION:	<p>The discharge gate for a primary screw lift pump must be operated from completely open to completely closed every time a pump is started or stopped. When cycled by hand, this operation takes either two people, or a large “cheater” bar to accomplish, in addition to a significant amount of time. In 2015, we installed electric actuators for the 3 most used pumps. The plant upgrade installed a new pump in the fourth location, which now needs an electric actuator. The Limatorque actuator would complete and standardize the actuators for this pump station.</p> <p>This is a sole source item to ensure standardization of parts and repairs for all actuators. The attached quote from Chalmers and Kubeck South for \$10,550.00 is recommended for your approval.</p> <p>This purchase is a budgeted expense to be paid from the “Maintenance to WPC Plant” line item, 505-3330-52-2361.</p>
LEGAL:	N/A