



## CITY COUNCIL ITEM SUMMARY

<b>MEETING DATE:</b>	November 16, 2023
<b>SUBCATEGORY:</b>	Bid Award/Purchases
<b>DEPARTMENT NAME:</b>	Water Department
<b>AGENDA ITEM TITLE:</b>	Valve Manhole Installation
<b>DEPARTMENT SUMMARY RECOMMENDATION:</b>	<p>During the AMI meter changeout at the Anheuser Busch plant, one of the City valves in the vault broke. The leakage is relatively minor but does need to be addressed. As this repair will require the brewery to be completely shut down, including fire service lines, we have scheduled the repair for the Friday after Thanksgiving Day, during the scheduled plant shutdown.</p> <p>To accomplish this work, we will need the buried 24-inch valve supplying the brewery to be accessible. For this purpose, a quote from C.H. Kirkpatrick and Sons was requested for the work, and a price of \$13,500.00 was received. I recommend awarding this work to the bidder. This is budgeted maintenance to be paid from acct #505.3320.52.2380.</p>
<b>LEGAL:</b>	N/A