

Transformer Quote Evaluation

(Harmony Walk Townhomes - Mimosa)

12470Y/7200 or DV

(7x) 50kVA 120/240

Jan. 2025

	VENDOR	BRAND	LEAD TIME IN WEEKS	UNIT PRICE (per unit)	QTY	QUOTE TOTAL	COND./NOTES
1	Gresco	Ermco	1-2	\$ 3,425.00	7	\$ 23,975.00	New DV
2	Irby	GE-Prolec	1	\$ 2,471.00	7	\$ 17,297.00	New 7.2kV
3	Irby	GE-Prolec	12-16+	\$ 2,902.00	7	\$ 20,314.00	New DV
4	Cape	VaOpto	10-16	\$ 11,935.48	7	\$ 83,548.39	New 7.2kV
5	Cape	VaOpto	10-16	\$ 20,645.00	7	\$ 144,515.00	New DV
6	Wesco/Anixter			\$ -		\$ -	*
7				\$ -		\$ -	
8				\$ -		\$ -	
9				\$ -		\$ -	
10				\$ -		\$ -	

* RFQ sent, quote not yet received or No Response

Recommendation:

I recommend the 12470Y/7200 GE Prolec transformers from Irby due to lead time and lowest unit cost for services that will be fed by 12470Y/7200 primary, eliminating the need for dual voltage units for the Harmony Walk Townhomes project .