



## CITY COUNCIL ITEM SUMMARY

<b>MEETING DATE:</b>	January 20, 2022
<b>SUBCATEGORY:</b>	Bid Award/Purchases
<b>DEPARTMENT NAME:</b>	Water
<b>AGENDA ITEM TITLE:</b>	WTP Heat Pump Replacement
<b>DEPARTMENT SUMMARY RECOMMENDATION:</b>	<p>The 7.5-ton heat pump at the Water Treatment Plant has quit working completely after several minor repairs this year. The repair quote is now \$2,700 with no guarantee this will fix the problem. This is a 12-year old unit, conditioning a 24 hour/day occupied space.</p> <p>We solicited and received three quotes for a replacement unit.</p> <p>I recommend purchase from the low bidder, T&amp;T Commercial Services, LLC for \$13,600.00.</p> <p>This is a budgeted maintenance expense and will be paid from account #505-3310-52-2350.</p>
<b>LEGAL:</b>	N/A