



CITY COUNCIL ITEM SUMMARY

MEETING DATE:	January 20, 2022
SUBCATEGORY:	Bid Award/Purchases
DEPARTMENT NAME:	Water
AGENDA ITEM TITLE:	RAS Check Valve Repair
DEPARTMENT SUMMARY RECOMMENDATION:	<p>On August 5, 2021 Council approved the repair of two – 30-inch check valves on the return activated sludge pumps at the Water Pollution Control Plant. This approval was for a not-to-exceed cost of \$25,000 for Goforth Williamson, Inc.</p> <p>Upon issuance of the notice to proceed, the contractor significantly increased their price for the work due to material and labor price increases and other uncertainties.</p> <p>The Water Department rebid the project and had only one responsive bidder with an updated proposal, Goforth Williamson, Inc. The revised price includes \$58,500.00 for valve repair labor and parts and \$2,975.00 for a blind flange to close the open-ended pipe while the valve is removed.</p> <p>I recommend rescinding the original approval of the not-to-exceed price of \$25,000, and the approval of the Goforth Williamson, Inc. updated bid of \$61,475.00.</p> <p>This is a budgeted maintenance item to be paid from account #505-3330-52-2361.</p>
LEGAL:	N/A