



## CITY COUNCIL ITEM SUMMARY

<b>MEETING DATE:</b>	June 5, 2025
<b>SUBCATEGORY:</b>	Bid Award/Purchase
<b>DEPARTMENT NAME:</b>	Water
<b>AGENDA ITEM TITLE:</b>	Center Road Tank Mixer Replacement
<b>DEPARTMENT SUMMARY RECOMMENDATION:</b>	<p>The 3-million-gallon water storage tank on Center Road utilizes a submerged mixer to prevent stratification and ensure consistent water quality. The sealed 120-volt motor on the existing mixer has failed. We received a quote of \$9,292.00 for a replacement Gridbee GS-9 mixer from the sole-source vendor, IXOM Watercare.</p> <p>This is a budgeted maintenance expense and is recommended for your approval.</p>
<b>LEGAL:</b>	N/A