



## CITY COUNCIL ITEM SUMMARY

<b>MEETING DATE:</b>	March 7, 2024
<b>SUBCATEGORY:</b>	Bid Award/Purchase
<b>DEPARTMENT NAME:</b>	Water
<b>AGENDA ITEM TITLE:</b>	Lift Station Pump Replacement
<b>DEPARTMENT SUMMARY RECOMMENDATION:</b>	<p>The #1 pump at the Main Street sewer lift station has failed and needs to be rebuilt or replaced. We received quotes for both rebuild and replacement from the pump station manufacturer.</p> <p>The estimate for a complete rebuild of the pump is \$16,910.56 and includes a 90-day parts and labor warranty. A new replacement pump costs \$22,888.00 and includes a one-year warranty.</p> <p>I recommend approval to purchase a new replacement pump from Xylem Water Solutions USA, Inc. This is a budgeted maintenance expense to be paid from account #505.3330.52.2361.</p>
<b>LEGAL:</b>	N/A