



CITY COUNCIL ITEM SUMMARY

MEETING DATE:	June 20, 2024
SUBCATEGORY:	Bid Award/Purchases
DEPARTMENT NAME:	Water
AGENDA ITEM TITLE:	Flow Meter Console Replacement
DEPARTMENT SUMMARY RECOMMENDATION:	<p>The Water Treatment Plant uses acoustic transit time flow meters to accurately measure flow pumped into the City's water distribution system by the high service pumps. The original Accusonic console for high service pump station #1, installed in 2007 has failed and needs replacement. The sole source provider of this equipment, Accusonic has provided a quote for a new, updated replacement console at a cost of \$42,178.00. This cost includes material, installation, commissioning, and one-year parts and labor warranty.</p> <p>This is the same type of unit as that on #2 pump station, which was replaced in April 2024. This is a budgeted maintenance item and is recommended for your approval.</p>
LEGAL:	N/A