

TO: Mayor and City Council of the City of Dacula
FROM: Brittni Nix, City Administrator
DATE: October 24, 2023
SUBJECT: Design proposal for Whisper Way storm drainage replacement

Concerns about the stability of a stormwater ditch near Whisper Way were reported by a city resident. Upon inspection, it was discovered there was a storm system failure. The corrugated metal pipe (CMP) along the Whisper Way cul-de-sac has deteriorated and has a rusted-out bottom. Erosion and stormwater have undermined the area around the rusted pipe which can create a safety hazard for residents.

The City of Dacula staff requested a proposal from Bowman Consulting Group Ltd. to design and bid a storm drainage replacement project for the subject CMP in the Whisper Woods subdivision. The provided proposal includes surveying, creating construction documents, bid management, and construction administration for \$39,700. The City anticipates utilizing American Rescue Plan Act (ARPA) funding for this project.

Staff requests approving Bowman's proposal in the amount of \$39,700 for the stated services as provided.