

JARRELL PLUMBING, INC.
51 Township Drive
Hiram GA 30141

Office: 770-222-0255
Cell Phone: 404-274-7912

Invoice

DATE	INVOICE #
9/14/2022	1998702

BILL TO

Right Path Tax & Accounting
321 Merchants Dr
Dallas, GA 30132

P.O. NO.

TERMS

Due on receipt

DESCRIPTION	AMOUNT
LABOR AND JOB MATERIALS	650.00
LITTLE TO NO WATER PRESSURE IN THE BUILDING SINCE THE COUNTY MADE A REPAIR TO A WATER LINE AT THE STREET. REMOVED THE PRV TO THE BUILDING AND FOUND SOME DEBRIS IN THE SCREEN. INSTALLED A NEW 3/4" PRV AND RESTORED WATER TO THE BUILDING AT THE SERVICE VALVE. STILL HAD VERY LITTLE FLOW THROUGH THE SYSTEM. INSPECTED THE CHECKED VALVE AT THE WATER METER AND FOUND IT TO BE NOT IN WORKING CONDITION. DALLAS WATER WAS CONTACTED AND INFORMED OF THE ISSUE. DALLAS WATER PROCEEDED TO REPLACED THE WATER METER RISER WITH A NEW CHECK VALVE. AFTER THIS WAS COMPLETED THERE WAS NO LONGER ANY WATER GETTING TO THE BUILDING. THE WATER LINE ON THE EXTERIOR OF THE BUILDING AND AT THE METER WERE DUG UP AND INSPECTED. FOUND NO ISSUE WITH THE WATER LINE FROM THE METER TO THE BUILDING. WITH THE LINE REMOVED FROM THE METER WE RESTORED WATER TO THE METER AND FOUND THAT THERE WAS NOT ENOUGH PRESSURE TO SUPPLY WATER UP TO THE BUILDING DUE TO A WATER LEAK ON THE DALLAS SIDE OF THE WATER METER.	
THANK YOU FOR YOUR BUSINESS	Total \$650.00