

DALTON FIRE DEPARTMENT

Standard Operating Procedure

Fire Chief Signature

DATE

S.O.P.: SCBA-04
Effective: 2/26/2019
Revised:
Reviewed: 2/23/2021

Title: Daily PPE Inspection

Reference: NFPA 1852: Standard on Selection, Care, and Maintenance of Open-Circuit Self-Contained Breathing Apparatus (SCBA), 2019 Edition

Scope: Suppression Division

Procedure:

- A. All personnel assigned a riding position with an SCBA shall perform a daily inspection in accordance with NFPA 1852.
 1. This applies to seats without a dedicated SCBA. An SCBA from a compartment shall be inspected for immediate use.
- B. All personnel shall ready assigned Personal Protective Equipment for immediate use.
 1. PPE shall be arranged so it can be donned immediately upon receiving a call.
 2. Individual emergency escape system and other personal tools shall be inspected for operation.
- C. All personnel shall inspect for location and readiness of any tools that would be required immediately for his/her riding assignment.
- D. These inspections shall be done immediately after clocking in for duty. Pass-ons and other business should be done after these inspections and readiness to respond have been completed.