DALTON FIRE DEPARTMENT

TODD PANGLE

Fire Chief Telephone 706-278-7363 Fax 706-272-7107 tpangle@cityofdalton-ga.gov 404 School Street Dalton, GA 30720



PUBLIC SAFETY COMMISSION

Bill Weaver Keith Whitworth Terry Mathis Kenneth E. Willis Anthony Walker

Monthly Synopsis March 2019

Incident Response

Category	Responses	<u>Percentage</u>
Fire	17	2.25%
Overpressure Rupture, Overhea	at 1	0.28%
Rescue/Medical	234	66.28%
Hazardous Condition	11	3.11%
Service Call	7	1.98%
Good Intent	50	14.16%
False Alarm	33	9.34%

Total Responses 353

Average Response Time 3:18

Estimated Loss \$137,005

Incident Type Report (Monthly Summary)

Alarm Date Between {03/01/2019} And {03/31/2019}

		Pct of	Total	Pct of
Incident Type	Count	Incidents	Est Loss	Losses
1 Fire				
111 Building fire	5	1.41%	\$121,500	88.68%
113 Cooking fire, confined to container	2	0.56%	\$0	0.00%
118 Trash or rubbish fire, contained	1	0.28%	\$5	0.00%
131 Passenger vehicle fire	1	0.28%	\$12,000	8.75%
138 Off-road vehicle or heavy equipment fire	1	0.28%	\$3,500	2.55%
142 Brush or brush-and-grass mixture fire	2	0.56%	\$0	0.00%
143 Grass fire	2	0.56%	\$0	0.00%
151 Outside rubbish, trash or waste fire	3	0.84%	\$0 	0.00%
	17	4.81%	\$137,005	100.00%
2 Overpressure Rupture, Explosion, Overheat(no i	Eire)			
251 Excessive heat, scorch burns with no	1	0.28%	\$0	0.00%
	1	0.28%	\$0	0.00%
2 December C. Empreson and Modical Country Traditions				
3 Rescue & Emergency Medical Service Incident 311 Medical assist, assist EMS crew	203	57.50%	\$0	0.00%
322 Motor vehicle accident with injuries	16	4.53%	\$0 \$0	0.00%
323 Motor vehicle/pedestrian accident (MV Ped)	3	0.84%	\$0	0.00%
324 Motor Vehicle Accident with no injuries	11	3.11%	\$0	0.00%
350 Extrication, rescue, Other	1	0.28%	\$0	0.00%
	234	66.28%	\$0	0.00%
4 Hazardous Condition (No Fire)	2	0 568	40	0 00%
411 Gasoline or other flammable liquid spill 412 Gas leak (natural gas or LPG)	2	0.56% 0.28%	\$0 \$0	0.00% 0.00%
424 Carbon monoxide incident	1	0.28%	\$0 \$0	0.00%
442 Overheated motor	3	0.84%	\$0	0.00%
444 Power line down	1	0.28%	\$0	0.00%
445 Arcing, shorted electrical equipment	2	0.56%	\$0	0.00%
461 Building or structure weakened or collapsed	1	0.28%	\$0	0.00%
	11	3.11%	\$0	0.00%
5 Service Call				
531 Smoke or odor removal	1	0.28%	\$0	0.00%
553 Public service	4	1.13%	\$0	0.00%
555 Defective elevator, no occupants	1	0.28%	\$0	0.00%
561 Unauthorized burning	1	0.28%	\$0	0.00%

Incident Type Report (Monthly Summary)

Alarm Date Between {03/01/2019} And {03/31/2019}

		Pct of	Total	Pct of
Incident Type	Count	Incidents	Est Loss	Losses
5 Service Call				
	7	1.98%	\$0	0.00%
6 Good Intent Call				
611 Dispatched & cancelled en route	39	11.04%	\$0	0.00%
622 No Incident found on arrival at dispatch	7	1.98%	\$0	0.00%
631 Authorized controlled burning	2	0.56%	\$0	0.00%
651 Smoke scare, odor of smoke	2	0.56%	\$0	0.00%
	50	14.16%	\$0	0.00%
7 False Alarm & False Call				
714 Central station, malicious false alarm	1	0.28%	\$0	0.00%
715 Local alarm system, malicious false alarm	3	0.84%	\$0	0.00%
733 Smoke detector activation due to	1	0.28%	\$0	0.00%
735 Alarm system sounded due to malfunction	4	1.13%	\$0	0.00%
743 Smoke detector activation, no fire -	15	4.24%	\$0	0.00%
744 Detector activation, no fire -	2	0.56%	\$0	0.00%
745 Alarm system activation, no fire -	7	1.98%	\$0	0.00%
	33	9.34%	\$0	0.00%

Total Incident Count: 353 Total Est Loss: \$137,005

DALTON

Dollar Value Saved & Loss Analysis (Monthly)

Alarm Date Between {03/01/2019} And {03/31/2019}

		Total	Total	Total F	ercent	Percent
Incident Type	Count	Values	Losses	Saved	Lost	Saved
111 Building fire	5	\$1,615,000	\$121,500	\$1,493,500	7.52%	92.48%
113 Cooking fire, confined	1	\$250,000	\$0	\$250,000	0.00%	100.00%
118 Trash or rubbish fire,	1	\$90,000	\$5	\$89,995	0.01%	99.99%
131 Passenger vehicle fire	1	\$25,500	\$12,000	\$13,500	47.06%	52.94%
138 Off-road vehicle or	1	\$5,000	\$3,500	\$1,500	70.00%	30.00%
Grand Totals	9	\$1,985,500	\$137,005	\$1,848,495		

Total Percent Lost: 6.90 % Total Percent Saved: 93.10 %

04/16/2019 14:10 Page 1

DALTON

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000584	0	03/01/2019	04:27:25	805	Professional	311 Medical assist, assist EMS crew	
19-0000585	0	03/01/2019	06:16:42		I-75 S. Bound	324 Motor Vehicle Accident with no	
19-0000586	0	03/01/2019	08:35:23	804	Kenner	311 Medical assist, assist EMS crew	
19-0000587	0	03/01/2019	08:37:25	810	Red Clay	311 Medical assist, assist EMS crew	
19-0000588	0	03/01/2019	14:21:59	1300	Waugh (West)	311 Medical assist, assist EMS crew	
19-0000589	0	03/01/2019	15:02:29	1304	Winton	311 Medical assist, assist EMS crew	
19-0000590	0	03/01/2019	15:38:00	1116	Willowdale	311 Medical assist, assist EMS crew	
19-0000591	0	03/01/2019	16:42:01	1212	Broadrick	311 Medical assist, assist EMS crew	
19-0000592	0	03/01/2019	18:21:05	606	Clark	311 Medical assist, assist EMS crew	
19-0000593	0	03/01/2019	19:26:43	1310	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000594	0	03/01/2019	21:07:52	1614	Waring	311 Medical assist, assist EMS crew	
19-0000595	0	03/01/2019	22:27:54	1218	Broadrick	611 Dispatched & cancelled en route	
19-0000596	0	03/01/2019	23:46:53	907	Vernon	311 Medical assist, assist EMS crew	
19-0000597	0	03/02/2019	01:23:07		Thornton (South)	311 Medical assist, assist EMS crew	
19-0000598	0	03/02/2019	08:43:26	1212	Broadrick	611 Dispatched & cancelled en route	
19-0000599	0	03/02/2019	11:41:57	515	Parkside	311 Medical assist, assist EMS crew	
19-0000600	0	03/02/2019	12:23:07	1104	Walston	311 Medical assist, assist EMS crew	
19-0000601	0	03/02/2019	18:18:51	159	Haigmill Lake	622 No Incident found on arrival at	
19-0000602	0	03/02/2019	19:38:45		Walnut (East)	322 Motor vehicle accident with	
19-0000603	0	03/02/2019	20:26:46	442	Hamilton (North)	743 Smoke detector activation, no fire	
19-0000604	0	03/02/2019	21:46:47		Cherokee	311 Medical assist, assist EMS crew	
19-0000605	0	03/03/2019	01:03:39	402	Hawthorne (East)	311 Medical assist, assist EMS crew	
19-0000606	0	03/03/2019	05:23:49	2106	Chattanooga	311 Medical assist, assist EMS crew	
19-0000607	0	03/03/2019	09:32:33	532	Underwood	311 Medical assist, assist EMS crew	
19-0000608	0	03/03/2019	10:08:16		Underwood	322 Motor vehicle accident with	
19-0000609	0	03/03/2019	11:25:36	136	Nickie	745 Alarm system activation, no fire -	
19-0000610	0	03/03/2019	16:47:47	104	Grade (South)	143 Grass fire	
19-0000611	0	03/03/2019	17:35:57	1104	Walston	311 Medical assist, assist EMS crew	
19-0000612	0	03/03/2019	19:48:28	302	Red Cross	311 Medical assist, assist EMS crew	
19-0000613	0	03/03/2019	20:49:19	1907	Chattanooga	411 Gasoline or other flammable liquid	

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000614	0	03/03/2019	20:58:44	1902	Summit View	311 Medical assist, assist EMS crew	
19-0000615	0	03/03/2019	22:12:38	1607	Beechland	311 Medical assist, assist EMS crew	
19-0000616	0	03/04/2019	01:36:25	404	Lesley	611 Dispatched & cancelled en route	
19-0000617	0	03/04/2019	07:43:57	1511	Abutment	323 Motor vehicle/pedestrian accident	
19-0000618	0	03/04/2019	08:15:46	1808	Dug Gap	611 Dispatched & cancelled en route	
19-0000619	0	03/04/2019	12:10:53	1644	Old Haig Mill	311 Medical assist, assist EMS crew	
19-0000620	0	03/04/2019	16:31:10	1213	Applewood	311 Medical assist, assist EMS crew	
19-0000621	0	03/04/2019	17:12:43	815	Shugart	311 Medical assist, assist EMS crew	
19-0000622	0	03/04/2019	18:24:43	520	Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000623	0	03/04/2019	19:34:27	820	Shugart	445 Arcing, shorted electrical	
19-0000624	0	03/04/2019	20:44:23	900	Shugart	311 Medical assist, assist EMS crew	
19-0000625	0	03/04/2019	21:49:46	450	Conway	311 Medical assist, assist EMS crew	
19-0000626	0	03/05/2019	02:33:42	1708	Westchester	311 Medical assist, assist EMS crew	
19-0000627	0	03/05/2019	03:48:57	1320	Winton	311 Medical assist, assist EMS crew	
19-0000628	0	03/05/2019	07:58:57	1009	Professional	611 Dispatched & cancelled en route	
19-0000629	0	03/05/2019	08:10:41	1409	Coronet	311 Medical assist, assist EMS crew	
19-0000630	0	03/05/2019	11:00:08	1407	Vann	311 Medical assist, assist EMS crew	
19-0000631	0	03/05/2019	12:32:40	205	Selvidge St. (North)	311 Medical assist, assist EMS crew	
19-0000632	0	03/05/2019	13:51:52	1529	Walnut (West)	611 Dispatched & cancelled en route	
19-0000633	0	03/05/2019	16:46:50	2659	Abutment	311 Medical assist, assist EMS crew	
19-0000634	0	03/05/2019	17:58:31	407	Vann	311 Medical assist, assist EMS crew	
19-0000635	0	03/05/2019	18:23:10	505	Lesley	311 Medical assist, assist EMS crew	
19-0000636	0	03/05/2019	18:48:34		Glenwood (South)	322 Motor vehicle accident with	
19-0000637	0	03/05/2019	22:42:13	601	School	311 Medical assist, assist EMS crew	
19-0000638	0	03/05/2019	23:01:28	1321	Winton	311 Medical assist, assist EMS crew	
19-0000639	0	03/06/2019	00:45:10	801	Red Clay	311 Medical assist, assist EMS crew	
19-0000640	0	03/06/2019	01:20:00	1116	Willowdale	311 Medical assist, assist EMS crew	
19-0000641	0	03/06/2019	05:37:11	609	Thornton (South)	311 Medical assist, assist EMS crew	
19-0000642	0	03/06/2019	09:16:53	1407	Vann	311 Medical assist, assist EMS crew	
19-0000643	0	03/06/2019	12:38:44	713	Stillwood	311 Medical assist, assist EMS crew	

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Exp Alm Date	Time		Location	Incident Type	Est Loss
19-0000644	0 03/06/2019	13:56:42	1414	Dug Gap	311 Medical assist, assist EMS crew	
19-0000645	0 03/06/2019	15:58:37	815	Walnut (East)	131 Passenger vehicle fire	\$12,000
19-0000646	0 03/06/2019	16:33:13	1909	Walnut (East)	311 Medical assist, assist EMS crew	
19-0000647	0 03/06/2019	18:37:21		MLK Jr.	322 Motor vehicle accident with	
19-0000648	0 03/06/2019	18:47:52	905	Roan	118 Trash or rubbish fire, contained	\$5
19-0000649	0 03/06/2019	18:49:17	1499	Westover	311 Medical assist, assist EMS crew	
19-0000650	0 03/06/2019	18:50:01	114	Massengill	611 Dispatched & cancelled en route	
19-0000651	0 03/06/2019	18:53:38	114	Massengill	151 Outside rubbish, trash or waste	
19-0000652	0 03/06/2019	19:50:23	1507	Habersham	311 Medical assist, assist EMS crew	
19-0000653	0 03/06/2019	20:56:48	905	Roan	553 Public service	
19-0000654	0 03/06/2019	21:11:20	617	Virginia	311 Medical assist, assist EMS crew	
19-0000655	0 03/06/2019	21:50:19		Morningside	324 Motor Vehicle Accident with no	
19-0000656	0 03/06/2019	22:54:26	1912	Chattanooga	311 Medical assist, assist EMS crew	
19-0000657	0 03/07/2019	05:41:09	1120	Riverbend	311 Medical assist, assist EMS crew	
19-0000658	0 03/07/2019	07:02:56	865	Holiday Inn	311 Medical assist, assist EMS crew	
19-0000659	0 03/07/2019	09:57:05	636	Spring	622 No Incident found on arrival at	
19-0000660	0 03/07/2019	11:18:19		Royal	745 Alarm system activation, no fire -	
19-0000661	0 03/07/2019	12:26:17	1320	Winton	743 Smoke detector activation, no fire	
19-0000662	0 03/07/2019	14:37:04	806	Harris	745 Alarm system activation, no fire -	
19-0000663	0 03/07/2019	14:41:38		Trammell	322 Motor vehicle accident with	
19-0000664	0 03/07/2019	14:45:22	1900	Morris (East)	631 Authorized controlled burning	
19-0000665	0 03/07/2019	16:58:58		Chattanooga	311 Medical assist, assist EMS crew	
19-0000666	0 03/07/2019	17:29:07	1824	Brady	311 Medical assist, assist EMS crew	
19-0000667	0 03/07/2019	17:35:19	707	Gist	311 Medical assist, assist EMS crew	
19-0000668	0 03/07/2019	19:04:18	2106	Chattanooga	311 Medical assist, assist EMS crew	
19-0000669	0 03/07/2019	19:47:39	404	School	311 Medical assist, assist EMS crew	
19-0000670	0 03/07/2019	23:36:19	1150	Ridgeleigh	311 Medical assist, assist EMS crew	
19-0000671	0 03/08/2019	00:43:17	232	Grimes (South)	611 Dispatched & cancelled en route	
19-0000672	0 03/08/2019	01:11:35	906	Sierra	611 Dispatched & cancelled en route	
19-0000673	0 03/08/2019	07:08:53	1116	Willowdale	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000674	0	03/08/2019	08:28:30	438	Underwood	311 Medical assist, assist EMS crew	
19-0000675	0	03/08/2019	09:46:08	609	Cockburn	311 Medical assist, assist EMS crew	
19-0000676	0	03/08/2019	09:54:39	816	Walnut Square	743 Smoke detector activation, no fire	
19-0000677	0	03/08/2019	11:48:55	1225	Broadrick	611 Dispatched & cancelled en route	
19-0000678	0	03/08/2019	14:13:00	1308	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000679	0	03/08/2019	14:22:02	114	Cuyler (west)	733 Smoke detector activation due to	
19-0000680	0	03/08/2019	14:24:07	503	Learning	311 Medical assist, assist EMS crew	
19-0000681	0	03/08/2019	14:32:19	1315	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000682	0	03/08/2019	15:27:16	1030	Willowdale	311 Medical assist, assist EMS crew	
19-0000683	0	03/08/2019	17:40:15	900	Shugart	715 Local alarm system, malicious	
19-0000684	0	03/08/2019	18:26:29	405	Moore	311 Medical assist, assist EMS crew	
19-0000685	0	03/08/2019	18:38:59		Roberts	322 Motor vehicle accident with	
19-0000686	0	03/08/2019	18:55:02	2106	Chattanooga	311 Medical assist, assist EMS crew	
19-0000687	0	03/08/2019	19:24:53	1575	Chattanooga	611 Dispatched & cancelled en route	
19-0000688	0	03/08/2019	20:04:45	818	J & J	311 Medical assist, assist EMS crew	
19-0000689	0	03/08/2019	20:22:34	816	Walnut Square	735 Alarm system sounded due to	
19-0000690	0	03/08/2019	22:26:48	300	Grimes (South)	311 Medical assist, assist EMS crew	
19-0000691	0	03/09/2019	01:01:52		I-75 S. Bound	611 Dispatched & cancelled en route	
19-0000692	0	03/09/2019	02:12:18	1000	Brown	311 Medical assist, assist EMS crew	
19-0000693	0	03/09/2019	03:20:22	M/M	I-75 S. Bound	611 Dispatched & cancelled en route	
19-0000694	0	03/09/2019	06:02:11	1000	Brown	311 Medical assist, assist EMS crew	
19-0000695	0	03/09/2019	09:24:54		Walnut (East)	324 Motor Vehicle Accident with no	
19-0000696	0	03/09/2019	10:11:35	1008	Arizona	311 Medical assist, assist EMS crew	
19-0000697	0	03/09/2019	12:45:38	700	Strain	324 Motor Vehicle Accident with no	
19-0000698	0	03/09/2019	12:55:08		Walnut (East)	324 Motor Vehicle Accident with no	
19-0000699	0	03/09/2019	18:22:42	1706	Southmont	311 Medical assist, assist EMS crew	
19-0000700	0	03/09/2019	19:15:15	1206	Georgian	311 Medical assist, assist EMS crew	
19-0000701	0	03/09/2019	21:21:35	1300	Waugh (West)	311 Medical assist, assist EMS crew	
19-0000702	0	03/09/2019	21:50:03	1306	Georgian	311 Medical assist, assist EMS crew	
19-0000703	0	03/09/2019	23:30:56	216	Keith	611 Dispatched & cancelled en route	

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000704	0	03/10/2019	06:55:37	1218	Broadrick	311 Medical assist, assist EMS crew	
19-0000705	0	03/10/2019	09:20:34	1110	Burleyson	311 Medical assist, assist EMS crew	
19-0000706	0	03/10/2019	18:49:21	210	Robinwood	311 Medical assist, assist EMS crew	
19-0000707	0	03/10/2019	20:13:20	501	Lester	311 Medical assist, assist EMS crew	
19-0000708	0	03/10/2019	21:54:05		I-75 S. Bound	622 No Incident found on arrival at	
19-0000709	0	03/10/2019	22:02:49	106	Kinnier	111 Building fire	\$500
19-0000710	0	03/11/2019	00:21:22	1115	Professional	611 Dispatched & cancelled en route	
19-0000711	0	03/11/2019	05:53:48	1110	Burleyson	311 Medical assist, assist EMS crew	
19-0000712	0	03/11/2019	08:01:19	1365	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000713	0	03/11/2019	12:31:40	900	Shugart	311 Medical assist, assist EMS crew	
19-0000714	0	03/11/2019	13:32:26	1236	Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000715	0	03/11/2019	14:00:49	1807	Beechland	311 Medical assist, assist EMS crew	
19-0000716	0	03/11/2019	14:49:25	118	Lisa	113 Cooking fire, confined to	
19-0000717	0	03/11/2019	16:31:22	1808	Ridgefield	311 Medical assist, assist EMS crew	
19-0000718	0	03/11/2019	17:43:16	622	Fifth	311 Medical assist, assist EMS crew	
19-0000719	0	03/11/2019	19:55:16	1306	Georgian	113 Cooking fire, confined to	
19-0000720	0	03/12/2019	01:40:08	421	Claude	311 Medical assist, assist EMS crew	
19-0000721	0	03/12/2019	06:09:39	1142	Thornton (North)	651 Smoke scare, odor of smoke	
19-0000722	0	03/12/2019	06:19:17		I-75 S. Bound	322 Motor vehicle accident with	
19-0000723	0	03/12/2019	07:27:22	117	Green (South)	323 Motor vehicle/pedestrian accident	
19-0000724	0	03/12/2019	07:28:35	922	Avenue F	311 Medical assist, assist EMS crew	
19-0000725	0	03/12/2019	09:22:02		I-75 S. Bound	611 Dispatched & cancelled en route	
19-0000726	0	03/12/2019	09:28:03	218	Spencer (North)	311 Medical assist, assist EMS crew	
19-0000727	0	03/12/2019	10:10:27		I-75 N. Bound	324 Motor Vehicle Accident with no	
19-0000728	0	03/12/2019	10:43:28	205	Selvidge St. (North)	311 Medical assist, assist EMS crew	
19-0000729	0	03/12/2019	13:25:45	717	Morningside	311 Medical assist, assist EMS crew	
19-0000730	0	03/12/2019	15:32:29	900	Shugart	311 Medical assist, assist EMS crew	
19-0000731	0	03/12/2019	16:07:38	915	Selvidge St. (North)	311 Medical assist, assist EMS crew	
19-0000732	0	03/12/2019	19:12:44		Grace	311 Medical assist, assist EMS crew	
19-0000733	0	03/12/2019	21:06:12		MLK Jr.	324 Motor Vehicle Accident with no	

DALTON

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000734	0	03/13/2019	08:15:56	1200	Memorial	611 Dispatched & cancelled en route	
19-0000735	0	03/13/2019	13:41:16	204	Industrial (West)	735 Alarm system sounded due to	
19-0000736	0	03/13/2019	14:06:10		Hamilton (South)	611 Dispatched & cancelled en route	
19-0000737	0	03/13/2019	17:18:04	816	Walnut Square	735 Alarm system sounded due to	
19-0000738	0	03/13/2019	18:46:31	1817	Dug Gap	143 Grass fire	
19-0000739	0	03/13/2019	19:29:30	1306	Underwood	311 Medical assist, assist EMS crew	
19-0000740	0	03/13/2019	20:26:22	1013	Lakeshore (East)	311 Medical assist, assist EMS crew	
19-0000741	0	03/14/2019	07:37:22	204	Industrial (West)	735 Alarm system sounded due to	
19-0000742	0	03/14/2019	10:04:35	519	Hawthorne (West)	743 Smoke detector activation, no fire	
19-0000743	0	03/14/2019	12:45:12	1101	Hamilton (North)	311 Medical assist, assist EMS crew	
19-0000744	0	03/14/2019	15:31:39	1225	Broadrick	311 Medical assist, assist EMS crew	
19-0000745	0	03/14/2019	15:46:58	918	Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000746	0	03/14/2019	17:36:40	601	Cockburn	311 Medical assist, assist EMS crew	
19-0000747	0	03/14/2019	17:51:08	815	Shugart	311 Medical assist, assist EMS crew	
19-0000748	0	03/14/2019	17:55:43	816	Shugart	311 Medical assist, assist EMS crew	
19-0000749	0	03/14/2019	18:50:28	1102	Burleyson	744 Detector activation, no fire -	
19-0000750	0	03/14/2019	21:07:34	1300	Waugh (West)	251 Excessive heat, scorch burns with	
19-0000751	0	03/15/2019	00:19:23	1250	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000752	0	03/15/2019	01:08:12	1600	MLK Jr.	611 Dispatched & cancelled en route	
19-0000753	0	03/15/2019	01:25:44	1120	Riverbend	311 Medical assist, assist EMS crew	
19-0000754	0	03/15/2019	07:06:15		Abutment	322 Motor vehicle accident with	
19-0000755	0	03/15/2019	07:26:15		Sir Lancelot	324 Motor Vehicle Accident with no	
19-0000756	0	03/15/2019	08:03:44		Abutment	611 Dispatched & cancelled en route	
19-0000758	0	03/15/2019	10:26:02		Plesant Grove	311 Medical assist, assist EMS crew	
19-0000759	0	03/15/2019	11:05:37	615	Thornton (South)	311 Medical assist, assist EMS crew	
19-0000760	0	03/15/2019	14:35:08	414	Benton	111 Building fire	\$25,000
19-0000761	0	03/15/2019	15:21:02	705	Emmons	743 Smoke detector activation, no fire	
19-0000762	0	03/15/2019	19:33:19	1308	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000763	0	03/15/2019	20:28:22		MLK Jr.	323 Motor vehicle/pedestrian accident	
19-0000764	0	03/15/2019	20:35:26	2518	Walnut (East)	311 Medical assist, assist EMS crew	

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Ехр	Alm Date	Time		Location	Incident Type	Est Loss
19-0000765	0	03/15/2019	22:18:47	415	Country Club	311 Medical assist, assist EMS crew	
19-0000766	0	03/15/2019	23:23:17	609	Thornton (South)	311 Medical assist, assist EMS crew	
19-0000767	0	03/16/2019	00:47:21	404	Lesley	311 Medical assist, assist EMS crew	
19-0000768	0	03/16/2019	01:46:52	801	Selvidge St. (North)	311 Medical assist, assist EMS crew	
19-0000769	0	03/16/2019	08:24:56	1253	Glenwood (North)	611 Dispatched & cancelled en route	
19-0000770	0	03/16/2019	09:43:45	219	Fredrick (North)	311 Medical assist, assist EMS crew	
19-0000771	0	03/16/2019	10:45:20	629	Fifth	311 Medical assist, assist EMS crew	
19-0000772	0	03/16/2019	14:08:39	310	Chestnut	311 Medical assist, assist EMS crew	
19-0000773	0	03/16/2019	15:28:56	107	Davidson	745 Alarm system activation, no fire -	
19-0000774	0	03/16/2019	15:34:42	1116	Willowdale	311 Medical assist, assist EMS crew	
19-0000775	0	03/16/2019	15:42:41	107	Davidson	745 Alarm system activation, no fire -	
19-0000776	0	03/16/2019	16:52:00	609	Thornton (South)	311 Medical assist, assist EMS crew	
19-0000777	0	03/16/2019	17:08:46	1016	Bonanza	311 Medical assist, assist EMS crew	
19-0000778	0	03/16/2019	17:42:01	2209	Seminole	311 Medical assist, assist EMS crew	
19-0000779	0	03/16/2019	17:58:41	1218	Broadrick	311 Medical assist, assist EMS crew	
19-0000780	0	03/17/2019	03:34:49	1208	Applewood	311 Medical assist, assist EMS crew	
19-0000781	0	03/17/2019	06:43:24		Morris (East)	622 No Incident found on arrival at	
19-0000782	0	03/17/2019	10:46:53	1102	Burleyson	743 Smoke detector activation, no fire	
19-0000783	0	03/17/2019	14:21:51	145	Raisin Way	311 Medical assist, assist EMS crew	
19-0000784	0	03/17/2019	16:41:39	1104	Walston	311 Medical assist, assist EMS crew	
19-0000785	0	03/17/2019	16:51:40	1102	Cargal	311 Medical assist, assist EMS crew	
19-0000786	0	03/17/2019	17:05:06	1107	Memorial	442 Overheated motor	
19-0000787	0	03/17/2019	18:52:29	1107	Memorial	442 Overheated motor	
19-0000788	0	03/17/2019	19:08:20	1529	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000789	0	03/17/2019	20:05:30	1116	Willowdale	531 Smoke or odor removal	
19-0000790	0	03/17/2019	22:48:37	815	Shugart	622 No Incident found on arrival at	
19-0000791	0	03/17/2019	23:31:32	1108	Walston	311 Medical assist, assist EMS crew	
19-0000792	0	03/18/2019	06:37:36	1111	Foster	311 Medical assist, assist EMS crew	
19-0000793	0	03/18/2019	13:47:28	1129	Thornton (South)	611 Dispatched & cancelled en route	
19-0000794	0	03/18/2019	13:52:51	208	Walnut (East)	322 Motor vehicle accident with	

DALTON

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000795	0	03/18/2019	15:12:27	219	Fredrick (North)	311 Medical assist, assist EMS crew	
19-0000796	0	03/18/2019	15:34:56		Thornton (North)	324 Motor Vehicle Accident with no	
19-0000797	0	03/18/2019	17:37:22		School	611 Dispatched & cancelled en route	
19-0000798	0	03/18/2019	18:03:14	211	Kenemer	311 Medical assist, assist EMS crew	
19-0000799	0	03/18/2019	18:42:31	1130	Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000800	0	03/18/2019	18:57:39	1225	Broadrick	311 Medical assist, assist EMS crew	
19-0000801	0	03/18/2019	20:00:34	1904	Deer Run	424 Carbon monoxide incident	
19-0000802	0	03/18/2019	21:51:43		Walnut (East)	411 Gasoline or other flammable liquid	
19-0000803	0	03/19/2019	13:51:20	1129	Thornton (South)	311 Medical assist, assist EMS crew	
19-0000804	0	03/19/2019	14:03:02		Thornton (North)	311 Medical assist, assist EMS crew	
19-0000805	0	03/19/2019	14:51:10		Thornton (South)	311 Medical assist, assist EMS crew	
19-0000806	0	03/19/2019	19:15:41		Walnut (West)	622 No Incident found on arrival at	
19-0000807	0	03/19/2019	22:20:48	2101	Club	311 Medical assist, assist EMS crew	
19-0000808	0	03/20/2019	08:07:29	907	Liddell	611 Dispatched & cancelled en route	
19-0000809	0	03/20/2019	08:15:39	2214	Mount Haven	553 Public service	
19-0000810	0	03/20/2019	11:02:24	103	Ogburn	311 Medical assist, assist EMS crew	
19-0000811	0	03/20/2019	12:50:05	1803	St Ives	311 Medical assist, assist EMS crew	
19-0000812	0	03/20/2019	15:11:20	602	Main	311 Medical assist, assist EMS crew	
19-0000813	0	03/20/2019	15:54:28	1212	Maple	311 Medical assist, assist EMS crew	
19-0000814	0	03/20/2019	16:00:11	1200	James	311 Medical assist, assist EMS crew	
19-0000815	0	03/20/2019	16:13:32	1300	Waugh (West)	311 Medical assist, assist EMS crew	
19-0000816	0	03/20/2019	17:57:23	1500	Manly	311 Medical assist, assist EMS crew	
19-0000817	0	03/20/2019	19:41:00	1212	Maple	311 Medical assist, assist EMS crew	
19-0000818	0	03/20/2019	19:48:35	802	Dewitt	311 Medical assist, assist EMS crew	
19-0000819	0	03/20/2019	21:02:39	1205	Royal	715 Local alarm system, malicious	
19-0000820	0	03/21/2019	09:21:26		I-75 N. Bound	611 Dispatched & cancelled en route	
19-0000821	0	03/21/2019	09:33:10	220	Westerly	611 Dispatched & cancelled en route	
19-0000822	0	03/21/2019	09:45:43	1711	Chattanooga	611 Dispatched & cancelled en route	
19-0000823	0	03/21/2019	10:18:25	1104	Penrose	311 Medical assist, assist EMS crew	
19-0000824	0	03/21/2019	10:31:23	2312	Chattanooga	311 Medical assist, assist EMS crew	

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Ехр	Alm Date	Time		Location	Incident Type	Est Loss
19-0000825	0	03/21/2019	11:54:49	310	Chestnut	311 Medical assist, assist EMS crew	
19-0000826	0	03/21/2019	12:24:40	1320	Winton	611 Dispatched & cancelled en route	
19-0000827	0	03/21/2019	12:55:45		Fields	611 Dispatched & cancelled en route	
19-0000828	0	03/21/2019	13:22:29		Riverbend	611 Dispatched & cancelled en route	
19-0000829	0	03/21/2019	13:36:43	1804	Martha's Bridge	743 Smoke detector activation, no fire	
19-0000830	0	03/21/2019	14:51:24	606	Silver	611 Dispatched & cancelled en route	
19-0000831	0	03/21/2019	17:08:10	1717	Cleveland	311 Medical assist, assist EMS crew	
19-0000832	0	03/21/2019	19:00:18		Tibbs (South)	611 Dispatched & cancelled en route	
19-0000833	0	03/21/2019	19:02:30	1802	Underwood	151 Outside rubbish, trash or waste	
19-0000834	0	03/21/2019	20:31:17	1800	Underwood	311 Medical assist, assist EMS crew	
19-0000835	0	03/21/2019	20:36:02	1102	Cargal	311 Medical assist, assist EMS crew	
19-0000836	0	03/22/2019	07:42:44		I-75 S. Bound	311 Medical assist, assist EMS crew	
19-0000837	0	03/22/2019	09:37:32	100	Thornton (South)	311 Medical assist, assist EMS crew	
19-0000838	0	03/22/2019	11:38:58	1212	Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000839	0	03/22/2019	13:33:24	803	Lumpkin	553 Public service	
19-0000840	0	03/22/2019	15:38:27	1305	Valencia	311 Medical assist, assist EMS crew	
19-0000841	0	03/22/2019	17:46:53	209	Lynn	311 Medical assist, assist EMS crew	
19-0000842	0	03/22/2019	20:24:47	812	Thornton	445 Arcing, shorted electrical	
19-0000843	0	03/22/2019	20:41:35	460	American	151 Outside rubbish, trash or waste	
19-0000844	0	03/22/2019	20:43:46	814	Underwood	350 Extrication, rescue, Other	
19-0000845	0	03/22/2019	23:20:34		Broadrick	311 Medical assist, assist EMS crew	
19-0000846	0	03/23/2019	05:31:14	1320	Winton	311 Medical assist, assist EMS crew	
19-0000847	0	03/23/2019	08:48:30	1502	Coronet	745 Alarm system activation, no fire -	
19-0000848	0	03/23/2019	10:16:47	1246	Thornton (North)	311 Medical assist, assist EMS crew	
19-0000849	0	03/23/2019	12:55:41	712	Cotton	461 Building or structure weakened or	
19-0000850	1	03/23/2019	13:57:49	1320	MLK Jr.	111 Building fire	\$5,000
19-0000850	0	03/23/2019	13:57:49	1322	MLK Jr.	111 Building fire	\$90,000
19-0000851	0	03/23/2019	15:15:29		North Bypass	322 Motor vehicle accident with	
19-0000852	0	03/23/2019	20:51:38	611	Sheridan	311 Medical assist, assist EMS crew	
19-0000853	0	03/23/2019	21:07:19		Hawthorne (East)	324 Motor Vehicle Accident with no	

DALTON

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Ехр	Alm Date	Time		Location	Incident Type	Est Loss
19-0000854	0	03/23/2019	21:32:07	1118	Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000855	0	03/23/2019	22:34:36	1804	Shadow	611 Dispatched & cancelled en route	
19-0000856	0	03/23/2019	23:03:46	1200	James	311 Medical assist, assist EMS crew	
19-0000857	0	03/24/2019	10:08:16	304	Robinwood	611 Dispatched & cancelled en route	
19-0000858	0	03/24/2019	14:01:26	202	Bogle (North)	311 Medical assist, assist EMS crew	
19-0000859	0	03/24/2019	16:05:23	1300	Waugh (West)	311 Medical assist, assist EMS crew	
19-0000860	0	03/24/2019	16:35:58	1365	Walnut (West)	322 Motor vehicle accident with	
19-0000861	0	03/24/2019	19:14:54	454	American	412 Gas leak (natural gas or LPG)	
19-0000862	0	03/24/2019	19:37:23	1320	Winton	743 Smoke detector activation, no fire	
19-0000863	0	03/24/2019	20:07:48	807	Croy	311 Medical assist, assist EMS crew	
19-0000864	0	03/24/2019	20:20:53	881	College	311 Medical assist, assist EMS crew	
19-0000865	0	03/25/2019	08:34:27	1601	Mockingbird Hill	311 Medical assist, assist EMS crew	
19-0000866	0	03/25/2019	10:12:08	100	Crawford (West)	311 Medical assist, assist EMS crew	
19-0000867	0	03/25/2019	13:06:26		Riverbend	611 Dispatched & cancelled en route	
19-0000868	0	03/25/2019	13:52:22	1007	Underwood	745 Alarm system activation, no fire -	
19-0000869	0	03/25/2019	15:12:35	404	School	611 Dispatched & cancelled en route	
19-0000870	0	03/26/2019	00:51:15	1527	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000871	0	03/26/2019	03:26:34	1966	Meadowbrook	311 Medical assist, assist EMS crew	
19-0000872	0	03/26/2019	03:51:19	502	Brittney	311 Medical assist, assist EMS crew	
19-0000873	0	03/26/2019	09:29:56	505	Underwood	311 Medical assist, assist EMS crew	
19-0000874	0	03/26/2019	10:52:03	405	School	743 Smoke detector activation, no fire	
19-0000875	0	03/26/2019	13:34:36	938	Market	311 Medical assist, assist EMS crew	
19-0000876	0	03/26/2019	14:09:08	1300	Waugh (West)	311 Medical assist, assist EMS crew	
19-0000877	0	03/26/2019	17:07:23	609	Thornton (South)	311 Medical assist, assist EMS crew	
19-0000878	0	03/26/2019	19:37:50	1502	Anthony	311 Medical assist, assist EMS crew	
19-0000879	0	03/27/2019	07:03:26	100	North Oaks	311 Medical assist, assist EMS crew	
19-0000880	0	03/27/2019	08:59:30	900	Shugart	714 Central station, malicious false	
19-0000881	0	03/27/2019	10:09:20	1920	Brady	311 Medical assist, assist EMS crew	
19-0000882	0	03/27/2019	10:56:29	101	Long (East)	444 Power line down	
19-0000883	0	03/27/2019	16:47:31	903	Oneonta	138 Off-road vehicle or heavy	\$3,500

04/16/2019 14:11 Page 10

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000884	0	03/27/2019	16:56:05	98	Walnut (West)	322 Motor vehicle accident with	
19-0000885	0	03/27/2019	17:09:04	1205	Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000886	0	03/27/2019	19:13:17	1525	Morris (East)	442 Overheated motor	
19-0000887	0	03/27/2019	20:37:54	304	Robinwood	311 Medical assist, assist EMS crew	
19-0000888	0	03/27/2019	21:14:39	622	Fifth	311 Medical assist, assist EMS crew	
19-0000889	0	03/28/2019	04:23:06	701	Red Clay	311 Medical assist, assist EMS crew	
19-0000890	0	03/28/2019	06:57:38	1320	Winton	611 Dispatched & cancelled en route	
19-0000891	0	03/28/2019	08:31:06		North Bypass	322 Motor vehicle accident with	
19-0000892	0	03/28/2019	15:05:36	785	College	744 Detector activation, no fire -	
19-0000893	0	03/28/2019	15:29:56	1013	Bonanza	311 Medical assist, assist EMS crew	
19-0000894	0	03/28/2019	15:34:03	1009	Ponderosa	111 Building fire	\$1,000
19-0000895	0	03/28/2019	16:36:45	1116	Willowdale	311 Medical assist, assist EMS crew	
19-0000896	0	03/28/2019	17:10:42	227	Grace	311 Medical assist, assist EMS crew	
19-0000897	0	03/28/2019	18:12:19	205	Selvidge St. (North)	743 Smoke detector activation, no fire	
19-0000898	0	03/28/2019	19:44:12	704	Moonraker	311 Medical assist, assist EMS crew	
19-0000899	0	03/28/2019	20:24:39	205	Selvidge St. (North)	555 Defective elevator, no occupants	
19-0000900	0	03/28/2019	20:53:19	806	Red Clay	311 Medical assist, assist EMS crew	
19-0000901	0	03/28/2019	21:37:20	623	Campus	311 Medical assist, assist EMS crew	
19-0000902	0	03/28/2019	22:34:06		MLK Jr.	322 Motor vehicle accident with	
19-0000903	0	03/28/2019	22:38:13	610	Strain	311 Medical assist, assist EMS crew	
19-0000904	0	03/29/2019	00:29:31	136	Nickie	311 Medical assist, assist EMS crew	
19-0000905	0	03/29/2019	01:38:00	1116	Willowdale	311 Medical assist, assist EMS crew	
19-0000906	0	03/29/2019	07:33:49	309	Keith	311 Medical assist, assist EMS crew	
19-0000907	0	03/29/2019	09:27:17	1701	West Oak	553 Public service	
19-0000908	0	03/29/2019	10:51:38	505	Underwood	715 Local alarm system, malicious	
19-0000909	0	03/29/2019	11:12:08	204	Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000910	0	03/29/2019	11:20:50		Glenwood (North)	324 Motor Vehicle Accident with no	
19-0000911	0	03/29/2019	11:32:49	1320	Winton	743 Smoke detector activation, no fire	
19-0000912	0	03/29/2019	12:48:14	905	Hamilton (South)	311 Medical assist, assist EMS crew	
19-0000913	0	03/29/2019	16:35:24	1549	Shady	311 Medical assist, assist EMS crew	

04/16/2019 14:11 Page 11

Incident List by Incident Number w/Est Loss(Month)

Alarm Date Between {03/01/2019} And {03/31/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000914	0	03/29/2019	20:38:30 13	06	Underwood	311 Medical assist, assist EMS crew	
19-0000915	0	03/29/2019	21:24:03 90	15	West Bridge	743 Smoke detector activation, no fire	
19-0000916	0	03/30/2019	00:19:50 88	1	College	743 Smoke detector activation, no fire	
19-0000917	0	03/30/2019	00:37:52 14	20	Mineral Springs	311 Medical assist, assist EMS crew	
19-0000918	0	03/30/2019	02:11:42 19	38	Springchase	651 Smoke scare, odor of smoke	
19-0000919	0	03/30/2019	12:07:27 13	00	Morton (East)	631 Authorized controlled burning	
19-0000920	0	03/30/2019	12:18:31		Walnut (East)	322 Motor vehicle accident with	
19-0000921	0	03/30/2019	12:58:19 10	31	Hamilton (South)	142 Brush or brush-and-grass mixture	
19-0000922	0	03/30/2019	13:25:22 10	16	Bonanza	311 Medical assist, assist EMS crew	
19-0000923	0	03/30/2019	15:00:28 13	808	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000924	0	03/30/2019	18:06:16 12	01	Burleyson	142 Brush or brush-and-grass mixture	
19-0000925	0	03/30/2019	19:29:34 19	21	Sourwood	311 Medical assist, assist EMS crew	
19-0000926	0	03/30/2019	19:58:09 13	00	Waugh (West)	311 Medical assist, assist EMS crew	
19-0000927	0	03/30/2019	20:03:06 15	19	Byron	311 Medical assist, assist EMS crew	
19-0000928	0	03/30/2019	21:21:39 13	00	Waugh (West)	611 Dispatched & cancelled en route	
19-0000929	0	03/31/2019	00:51:40 19	15	Crow Valley	561 Unauthorized burning	
19-0000930	0	03/31/2019	10:39:00 23	05	Ravine	311 Medical assist, assist EMS crew	
19-0000931	0	03/31/2019	10:58:34 40	19	Fredrick (North)	311 Medical assist, assist EMS crew	
19-0000932	0	03/31/2019	12:03:50 14	07	Thornton (North)	743 Smoke detector activation, no fire	
19-0000933	0	03/31/2019	12:08:44		I-75 N. Bound	622 No Incident found on arrival at	
19-0000934	0	03/31/2019	12:48:45		Underwood	322 Motor vehicle accident with	
19-0000935	0	03/31/2019	16:54:39 51	.9	Hawthorne (West)	743 Smoke detector activation, no fire	
19-0000936	0	03/31/2019	20:31:22 11	.02	Burleyson	611 Dispatched & cancelled en route	
Total Incid	lent	Count 353				Total Est Loss	\$137,005

04/16/2019 14:11 Page 12

DALTON

Incident Type Period Comparisons

Alarm Date Between {03/01/2019} and {03/31/2019}

Incident Type	03/01/2019	03/01/2018	03/01/2017	03/01/2016
	to	to	to	to
	03/31/2019	03/31/2018	03/31/2017	03/31/2016
111 Building fire	5	0	2	1
113 Cooking fire, confined to container	2	0	4	5
116 Fuel burner/boiler malfunction, fire confined	0	1	0	0
118 Trash or rubbish fire, contained	1	0	1	0
120 Fire in mobile prop used as a fixed struc, Oth	ner 0	1	0	0
131 Passenger vehicle fire	1	1	4	1
132 Road freight or transport vehicle fire	0	0	2	0
138 Off-road vehicle or heavy equipment fire	1	0	0	0
141 Forest, woods or wildland fire	0	2	2	2
142 Brush or brush-and-grass mixture fire	2	2	0	2
143 Grass fire	2	1	0	1
151 Outside rubbish, trash or waste fire	3	2	1	1
154 Dumpster or other outside trash receptacle fir	re 0	1	0	0
251 Excessive heat, scorch burns with no ignition	1	1	1	1
311 Medical assist, assist EMS crew	203	200	193	167
322 Motor vehicle accident with injuries	16	1	3	21
323 Motor vehicle/pedestrian accident (MV Ped)	3	1	0	1
324 Motor Vehicle Accident with no injuries	11	1	1	6
331 Lock-in (if lock out , use 511)	0	0	0	1
350 Extrication, rescue, Other	1	0	0	0
351 Extrication of victim(s) from building/structu	ure 0	0	1	0
352 Extrication of victim(s) from vehicle	0	0	2	1
353 Removal of victim(s) from stalled elevator	0	0	2	0
411 Gasoline or other flammable liquid spill	2	1	0	0
412 Gas leak (natural gas or LPG)	1	1	1	2
413 Oil or other combustible liquid spill	0	0	2	0
422 Chemical spill or leak	0	0	0	1

04/16/2019 14:13 Page 1

DALTON

Incident Type Period Comparisons

Alarm Date Between {03/01/2019} and {03/31/2019}

Incident Type	03/01/2019	03/01/2018	03/01/2017	03/01/2016
	to	to	to	to
	03/31/2019	03/31/2018	03/31/2017	03/31/2016
424 Carbon monoxide incident	1	0	1	0
441 Heat from short circuit (wiring), defective/wo	orn 0	0	1	0
442 Overheated motor	3	0	0	2
443 Breakdown of light ballast	0	1	0	0
444 Power line down	1	0	2	0
445 Arcing, shorted electrical equipment	2	1	0	1
461 Building or structure weakened or collapsed	1	0	4	0
463 Vehicle accident, general cleanup	0	0	1	2
500 Service Call, other	0	0	1	0
522 Water or steam leak	0	0	1	1
531 Smoke or odor removal	1	1	0	0
551 Assist police or other governmental agency	0	0	4	0
553 Public service	4	2	1	2
554 Assist invalid	0	0	0	1
555 Defective elevator, no occupants	1	0	0	0
561 Unauthorized burning	1	2	3	3
600 Good intent call, Other	0	0	0	1
611 Dispatched & cancelled en route	39	34	12	13
622 No Incident found on arrival at dispatch addre	ess 7	3	4	10
631 Authorized controlled burning	2	1	1	0
651 Smoke scare, odor of smoke	2	4	5	6
671 HazMat release investigation w/no HazMat	0	1	1	0
711 Municipal alarm system, malicious false alarm	0	0	1	0
714 Central station, malicious false alarm	1	0	1	0
715 Local alarm system, malicious false alarm	3	1	1	1
730 System malfunction, Other	0	1	0	1
731 Sprinkler activation due to malfunction	0	0	1	1

04/16/2019 14:13 Page 2

Incident Type Period Comparisons

Alarm Date Between {03/01/2019} and {03/31/2019}

Incident Type	03/01/2019	03/01/2018	03/01/2017	03/01/2016
	to	to	to	to
	03/31/2019	03/31/2018	03/31/2017	03/31/2016
733 Smoke detector activation due to malfunction	1	1	7	7
735 Alarm system sounded due to malfunction	4	5	8	3
736 CO detector activation due to malfunction	0	0	1	3
740 Unintentional transmission of alarm, Other	0	1	0	0
741 Sprinkler activation, no fire - unintentional	0	1	1	2
743 Smoke detector activation, no fire -	15	8	6	11
744 Detector activation, no fire - unintentional	2	1	2	2
745 Alarm system activation, no fire - unintention	al 7	8	3	6
746 Carbon monoxide detector activation, no CO	0	0	2	0
813 Wind storm, tornado/hurricane assessment	0	0	5	0
Totals	353	294	303	293

04/16/2019 14:13 Page 3

DALTON

Monthly Unit Response Time Analysis

Alarm Date Between {03/01/2019} And {03/31/2019} and Response Code = "1 " (Emergency)

Resp	Response		
Hrs	Mins	Count	Percentage
	< 01	22	5.2%
	01	66	15.6%
	02	107	25.3%
	03	102	24.1%
	04	71	16.8%
	05	31	7.3%
	06	9	2.1%
	07	5	1.1%
	08	7	1.6%
	09	1	0.2%
	10	1	0.2%

Overall Average Response Time: 00:03:18

Monthly Unit Response Time Analysis

Alarm Date Between {03/01/2019} And {03/31/2019} and Response Code = "2 " (Non-Emergency)

espo	onse		
irs	Mins	Count	Percentage
	< 01	8	15.3%
	01	4	7.6%
	02	4	7.6%
	03	10	19.2%
	04	6	11.5%
	05	9	17.3%
	06	4	7.6%
	08	4	7.6%
	11	1	1.9%
	12	1	1.9%
	20	1	1.9%

Overall Average Response Time: 00:04:29

04/16/2019 14:15 Page 1

Dalton Fire Department Medical Incident Study EMS On scene/Not on scene Prior to DFD Comparison 3/1/19 –3/31/19

Total incidents in time period – 242

EMS on-scene prior to DFD - 59

EMS not on-scene prior – 183

During the month of March, Dalton Fire Department arrived on-scene prior to Hamilton EMS on 75% of medical responses.

Training Division Monthly Report March 2019

Overview

Instructors from The Nozzle Forward delivered a 24-hour course focused on loading, deployment, and stretching of the initial attack hand line to 26 DFD personnel. The Training Division delivered a ground ladder refresher and scenario-based VEIS evolution with live fire to all suppression personnel. The department hosted and enrolled 68 personnel in the 8-hour technician level unit of Modular Emergency Response Radiological Transport Training (MERRTT) delivered by GEMA and the U.S. Department of Energy. This course was followed by a 3-day tabletop and full-scale exercise coordinated by GEMA and the U.S. Department of Energy's WIPP/TREX division. 42 DFD personnel attended these exercises. Monthly training included territory familiarization, pre-fire training, core competency check-offs, special operations training, and company level drills chosen by company officers. Training hours during the month of March totaled 3,828.

Outside Schools

Dalton Fire delivered an 80-hour Hazardous Materials Technician course in concert with Gordon County and Calhoun Fire Departments. This curriculum also included a 24-hour Hazardous Materials Incident Management component for command and general staff officers.

Additional off-campus training included:

Fire Department Supervision	GPSTC	2
FLAMES	Chatsworth FD	1
Incident Response to Terrorist Bombings	GPSTC	1
Prevention and Response to Suicide Bombings	GPSTC	1

Support Functions

- 93 hours were spent completing apparatus checks and equipment replenishment
- Cleaning and maintenance activities accounted for 716 hours in March
- 8 hours were dedicated to fire investigation and related activities

Prevention Division Monthly Report March 2019

Inspections

Annual Inspections	Total:	57
Apartment Inspections	Total:	5
Site Inspections	Total:	43
Fire Alarm Inspection	Total:	1
Sprinkler System Inspection	Total:	
New Kitchen Hood Inspections	Total:	
Knox Box Installation	Total:	1
Occupational Tax Certificate Inspections	Total:	13
Alcohol Inspections	Total:	1
50 Percent Inspections	Total:	
80 Percent Inspections	Total:	1
100 Percent Inspections	Total:	1
Pre-Incident Surveys	Total:	95
Plan Reviews	Total:	3
Addressing	Total:	3
Total Inspections		224
Publi	c Relations	
Fire Saf	Fety Education	
Events	Total:	10
Staff Members Participated	Total:	31
Staff Hours	Total:	44
Number of Adults Reached	Total:	24
Number of Children Reached	Total:	203
Total Residents Reached		227
Smoke Det	tector Installation	
Events	Total:	1
Staff Members Participated	Total:	4
Staff Hours	Total:	1
Total Smoke Detectors Installed	Total:	3
Total Number of Adults Reached	Total:	3
Total Number of Children Reached	Total:	2
Total Residents Reached		5

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs	Fee
200 INSPEC	TION -	Annual		
03/11/2019	08:43	10754 Dalton Fire Department Station 1 404 School ST	0.03	
03/18/2019	15:55	10789 Ross Woods Adult Day Services 1402 Walston AVE	0.23	
03/25/2019	13:41	10790 Centerstone 206 Hawthorne (West) ST	1.06	
03/07/2019	09:25	20101 Servicios Latinos 908 Elk ST	0.48	
03/08/2019	13:21	30033 Guest Inn 2220 Chattanooga RD	0.00	
03/12/2019	10:00	30207 Vacant 785 Shugart RD /Suite 1,2	0.00	
03/12/2019	10:00	30208 Vacant 785 Shugart RD /Suite 4	0.00	
03/12/2019	14:11	30209 Great Clips 785 Shugart RD /3	0.10	
03/14/2019	09:38	30210 First Bank of Dalton 785 Shugart RD /11	0.23	
03/12/2019	14:46	30211 Blood Assurance 785 Shugart RD /5	0.26	
03/14/2019	14:29	30212 PS Nails 785 Shugart RD /6	0.01	
03/14/2019	10:26	30213 Game Stop 785 Shugart RD /7	0.14	
03/14/2019	10:03	30214 Marco Pizza 785 Shugart RD /8	0.05	
03/14/2019	11:04	30215 Seasons Hibachi & Sushi 785 Shugart RD /9	0.21	
03/19/2019	13:51	30205 Wal-Mart 815 Shugart RD	0.94	
03/12/2019	09:58	30216 vacant 785 Shugart RD /10	0.00	
03/25/2019	11:15	30252 Waffle House 1912 Chattanooga RD	0.05	
03/18/2019	10:34	30254 Kohl's 835 Shugart RD	0.42	
03/18/2019	14:03	30260 Academy Sports & Outdoors 865 Shugart RD	0.50	

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs	Fee
200 INSPEC	TION -	Annual		
03/20/2019	10:09	30260 Academy Sports & Outdoors 865 Shugart RD	0.08	
03/14/2019	09:33	30283 Rainbow Frozen Yogurt 785 Shugart RD /9B	0.00	
03/15/2019	10:05	30293 Petco 841 Shugart RD	0.53	
03/15/2019	10:57	30294 Mattress Firm 845 Shugart RD	0.04	
03/15/2019	11:28	30295 Aspen Dental 849 Shugart RD	0.18	
03/15/2019	11:39	30296 I Luv Nails 851 Shugart RD	0.09	
03/15/2019	11:53	30297 Verizon 853 Shugart RD	0.13	
03/29/2019	13:46	40009 La Quinta Inn & Suites 715 College DR	0.05	
03/12/2019	13:29	40012 Holiday Inn Express 865 Holiday Inn DR	0.03	
03/28/2019	12:28	40041 CHRIST CHURCH PRESBYTERIAN CHURCH 510 Tibbs (South) RD	0.19	
03/18/2019	12:54	40043 Las Palmas 1331 Walnut (West) AVE	0.17	
03/18/2019	13:43	40044 SPRINT PCS 1333 Walnut (West) AVE	0.05	
03/18/2019	13:41	40045 BIG LOTS 1335 Walnut (West) AVE	0.09	
03/18/2019	14:01	40046 DALTON NAILS 1337 Walnut (West) AVE	0.04	
03/18/2019	14:06	40047 Tobacco Outlet 1339 Walnut (West) AVE	0.06	
03/18/2019	14:17	40049 Liberty Tax 1345 Walnut (West) AVE	0.02	
03/18/2019	14:12	40051 Atlas Physical 1343 Walnut (West) AVE	0.01	
03/22/2019	08:49	40062 Shoney's 1302 Walnut (West) AVE	0.08	
03/22/2019	09:26	40064 Applebee's 1322 Walnut (West) AVE	0.13	

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs	Fee
200 INSPEC	TION -	Annual		
03/18/2019	13:28	40065 Reflexology 1323 Walnut (West) AVE /Suite 1	0.04	
03/08/2019	10:22	40079 O'Charley's 1520 Walnut (West) AVE	0.01	
03/08/2019	10:41	40082 Red Lobster 901 West Bridge RD	0.01	
03/12/2019	10:04	40083 Country Inn and Suites 903 West Bridge RD	0.08	
03/12/2019	09:53	40084 Thompson Energy 745 College DR /A	0.07	
03/12/2019	09:35	40090 Courtyard by Marriott 785 College DR	0.05	
03/05/2019	13:49	40112 Timothy Q. Rushing, D.M.D. 1400 Dug Gap RD	0.07	
03/08/2019	13:17	40114 Pine Needle Gift Shoppe 1319 Dug Gap RD	0.06	
03/12/2019	13:49	40115 Simply Delightful Consignment 1407 Dug Gap RD	0.06	
03/12/2019	13:55	40118 Pulmanary & Sleep Medicine 1420 Mineral Springs RD	0.09	
03/18/2019	14:21	40059 KROGER 1365 Walnut (West) AVE	0.23	
03/08/2019	14:05	40150 Hilton Garden Inn 879 Holiday Inn DR	0.02	
03/05/2019	10:45	40161 Georgia Hope Family & Childrens 1414 Dug Gap RD	0.03	
03/21/2019	14:47	40163 Verizon Wireless 1516 Walnut (West) AVE	0.05	
03/18/2019	13:16	40167 TJ Maxx 1327 Walnut (West) AVE	0.05	
03/18/2019	13:23	40168 Sport Clips 1323 Walnut (West) AVE /Suite 4	0.07	
03/18/2019	13:31	40156 Fuji Japanese Steakhouse 1321 Walnut (West) AVE /Suite 1	0.13	
03/28/2019	12:56	50034 All Seasons Self Storage 1060 Vista DR	0.02	
03/25/2019	10:25	40186 Schlotzsky's 1325 Walnut (West) AVE	0.03	

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

	CTION -		
		for Type: 57	7.85
205 INSPE	CTION -	Annual Apartment	
03/19/2019	9 09:54	30269 Park Canyon Apartment Homes 284 Park Canyon DR	1.77
03/06/2019	9 09:56	30272 Arbordale Apartments 2140 Arbordale PL	0.91
03/26/2019	9 09:19	30263 Dalton Village Apartments 1809 Shadow LANE	1.03
03/21/2019	9 10:33	30265 Legacy of Dalton 2111 Club DR	0.02
03/07/2019	9 10:28	30265 Legacy of Dalton 2111 Club DR	0.78
Total Act:	ivities	for Type: 5	4.51
210 INSPEC		Site 30265 Legacy of Dalton	0.00
		2111 Club DR	
03/18/2019	9	30207 Vacant 785 Shugart RD /Suite 1,2	0.00
03/25/2019	9	30207 Vacant 785 Shugart RD /Suite 1,2	0.00
03/15/2019	9	30011 JBrennon Construction Inc. 1419 Chattanooga AVE /Suite 1	0.00
03/13/2019	€	30215 Seasons Hibachi & Sushi 785 Shugart RD /9	0.00
03/05/2019	9 10:00	30033 Guest Inn 2220 Chattanooga RD	1.00
03/05/2019	9 15:00	30033 Guest Inn 2220 Chattanooga RD	1.00
03/12/2019	9	30033 Guest Inn 2220 Chattanooga RD	0.00
03/26/2019	e	30089 Advanced Color Technologies 1727 Kimberly Park DR	0.00

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs	Fee
210 INSPEC	TION -	Site		
03/01/2019		30272 Arbordale Apartments 2140 Arbordale PL	0.00	
03/01/2019	09:00	30287 Anna Shaw's Children Institute 1201 Burleyson RD	2.50	
03/15/2019		3P002 Shoppes on Shugart 785 Shugart RD	0.00	
03/14/2019		3P002 Shoppes on Shugart 785 Shugart RD	0.00	
03/15/2019		3P003 Shugart Center 841 Shugart RD	0.00	
03/04/2019		40036 Stadium BBQ Pool 1001 Market ST /Suite 13	0.00	
03/04/2019	13:00	40038 Stadium BBQ 1001 Market ST /Suite 14	1.50	
03/18/2019	15:19	40038 Stadium BBQ 1001 Market ST /Suite 14	0.04	
03/20/2019	11:40	40038 Stadium BBQ 1001 Market ST /Suite 14	0.03	
03/05/2019	16:00	10783 Peeple's Cancer Center 1215 Memorial DR	0.50	
03/26/2019		10576 Trevitt Hall 111 Hamilton (North) ST	0.00	
03/27/2019		10720 Cockburn St. Apartments 600 Cockburn ST	1.00	
03/27/2019		10721 Cockburn St. Apartments 601 Cockburn ST	1.00	
03/27/2019		10722 Cockburn St. Apartments 602 Cockburn ST	1.00	
03/20/2019		10007 Las Chikas Bar 600 MLK Jr. BLVD /A	1.00	
03/25/2019		10007 Las Chikas Bar 600 MLK Jr. BLVD /A	1.00	
03/26/2019		10070 City Park School 405 School ST	0.00	
03/08/2019		10070 City Park School 405 School ST	0.00	
03/13/2019		10359 HAMILTON MEDICAL CENTER 1200 Memorial DR	0.00	

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs Fee
210 INSPECT	rion -	Site	
03/01/2019	10:00	10359 HAMILTON MEDICAL CENTER	1.50
		1200 Memorial DR	
03/04/2019	09:00	20326 SHAW IND. PLANT #52	0.50
		1100 Riverbend RD	
03/14/2019		20233 UNIVERSAL TEXTILE TECHNOLOGIST	0.00
		204 Industrial (West) BLVD	
03/07/2019		20278 City of Refuge	0.00
		120 Morris (East) ST	
03/06/2019		20317 C & H Services	0.00
		820 Riverbend DR	
03/15/2019		20420 Sharon Langford Realty, LLC	0.00
02/10/2010		720 Glenwood (South) AVE /206	0.00
03/19/2019		20504 Dalton Mall 816 Walnut Square BLVD	0.00
03/06/2019		20775 Transformers Transmission	0.00
03/00/2019		815 Walnut (East) AVE	0.00
03/19/2019		40189 KFC	0.00
00, 10, 1010		1519 Walnut (West) AVE	
03/06/2019		50053 Kroger	0.00
		1205 Glenwood (North) AVE	
03/27/2019		50135 Underwood Lodge	1.00
		1306 Underwood ST	
03/01/2019		40171 Ross	0.00
		1310 Walnut (West) AVE /Suite 2	
03/11/2019		40171 Ross	0.00
		1310 Walnut (West) AVE /Suite 2	
03/12/2019		40178 Kay Jewelers	0.00
		1314 Walnut (West) AVE /Suite 1	
03/08/2019		40108 Christ Reformed Baptist Church	0.00
		1378 Dug Gap RD	
Total Activ	vities	for Type: 43	14.57

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date Time	Occupancy	Hrs Fee
211 INSPECTION -		
03/13/2019	40192 Ryman Farm 1915 Ryman's Ridge RD	3.00
03/14/2019	10359 HAMILTON MEDICAL CENTER 1200 Memorial DR	1.00
	10506 Dalton Storage 426 Thornton (North) AVE	2.00
Total Activities	for Type: 3	6.00
221 INSPECTION -	Fire Alarm	
	10506 Dalton Storage 426 Thornton (North) AVE	1.37
Total Activities	for Type: 1	1.37
251 INSPECTION -	Knox Box Installation	
	30138 Alliant Health Plans 1503 Tibbs (North) RD	0.00
Total Activities		0.00
261 INSPECTION -	OTC	
03/22/2019 08:43	30222 Village Podiatry 1505 Professional CT	0.01
03/21/2019 13:58	30287 Anna Shaw's Children Institute 1201 Burleyson RD	0.02
03/11/2019 09:51	30287 Anna Shaw's Children Institute 1201 Burleyson RD	2.09
03/13/2019	10201 The Paper Princess 238 Hamilton (North) ST /Suite 2	0.00
03/13/2019	20776 Garcia Son's Tires and More 1104 Thornton (South) AVE	0.00
03/06/2019	10788 Carlson & Carlson 311 Hamilton (North) ST	0.00
03/13/2019	20015 PSG Functional Materials 2200 Abutment RD	0.00

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs Fee
261 INSPEC	TION -	OTC	
03/08/2019	16:00	20771 Salon Garibaldi 1309 Morris (East) ST	0.00
03/12/2019	12:52	30011 JBrennon Construction Inc. 1419 Chattanooga AVE /Suite 1	0.08
03/06/2019	09:33	20318 One Source Sample LLC. 950 Riverbend DR	0.15
03/22/2019	09:44	40178 Kay Jewelers 1314 Walnut (West) AVE /Suite 1	0.24
03/12/2019	13:18	30016 Preferred Cherokee Dalton 1506 Thornton (North) AVE /A	0.05
		40171 Ross 1310 Walnut (West) AVE /Suite 2	0.03
		for Type: 13	2.67
03/25/2019		10007 Las Chikas Bar 600 MLK Jr. BLVD /A	1.00
	. – – – – -		
264 INSPEC			
03/15/2019		30196 St. Joseph's Catholic Church 1775 Haigmill Lake RD	0.00
Total Activ	vities	for Type: 1	0.00
280 INSPEC	TION -	80	
03/19/2019		20436 SHAW INDUSTRIES 616 Walnut (East) AVE	0.00
Total Activ	vities	for Type: 1	0.00

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs	Fee
290 INSPEC	TION -	100		
03/26/2019		40189 KFC 1519 Walnut (West) AVE	0.00	
Total Acti	vities	for Type: 1	0.00	
501 PRE-IN	CIDENT			
03/18/2019	10:00	50035 Jack's 1202 Glenwood (North) AVE	0.00	
03/18/2019	10:45	50038 McDonalds 1210 Glenwood (North) AVE	0.00	
03/18/2019	10:30	50039 GooGoo Express Wash 1234 Glenwood (North) AVE	0.00	
03/18/2019	10:15	50040 CAPTAIN D's SEAFOOD 1236 Glenwood (North) AVE	0.00	
03/25/2019	13:00	50031 CVG/FinishTEK 1030 Vista DR	0.00	
03/25/2019	10:00	50033 C. V. G / Warehouse 1050 Vista DR	0.00	
03/25/2019	11:00	50034 All Seasons Self Storage 1060 Vista DR	0.00	
03/18/2019	09:10	40156 Fuji Japanese Steakhouse 1321 Walnut (West) AVE /Suite 1	0.00	
03/18/2019	10:05	40168 Sport Clips 1323 Walnut (West) AVE /Suite 4	0.00	
03/18/2019	10:10	40169 UPS Store 1323 Walnut (West) AVE /Suite 2	0.00	
03/18/2019	09:55	40165 Sun Tan City 1329 Walnut (West) AVE /Suites 3 & 4	0.00	
03/18/2019	10:00	40167 TJ Maxx 1327 Walnut (West) AVE	0.00	
03/18/2019	10:25	40151 Delta Spa Nails 1321 Walnut (West) AVE /Suite 4	0.00	
03/18/2019	09:15	40059 KROGER 1365 Walnut (West) AVE	0.00	
03/18/2019	09:20	40060 Jersey Mike's Subs 1367 Walnut (West) AVE	0.00	
03/25/2019	10:00		0.00	

04/09/2019 06:55 Page

2104 Fiber Park DR /A

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs F
501 PRE-IN	CIDENT		
03/18/2019	10:20	40065 Reflexology	0.00
		1323 Walnut (West) AVE /Suite 1	
03/04/2019	09:15	40071 Total Health Chiropractic	0.00
		1513 Walnut (West) AVE /Suite 3	
03/04/2019	10:00	40073 Planet Fitness	0.00
		1515 Walnut (West) AVE	
03/18/2019	09:30	40051 Atlas Physical	0.00
		1343 Walnut (West) AVE	
03/18/2019	09:20	40052 Petland	0.00
02/10/0010	10.15	1343 Walnut (West) AVE	0.00
03/18/2019	10:15	40057 Massage 1321 Walnut (West) AVE /# 5	0.00
03/18/2019		40058 H&R BLOCK	0.00
03/16/2019		1323 Walnut (West) AVE	0.00
03/04/2019	00.30	20480 SHERWIN WILLIAMS	0.00
03/01/2019	0,70	1904 Walnut (East) AVE	0.00
03/04/2019	09:30	20484 Shaw's Furniture Place	0.00
		2132 Walnut (East) AVE	
03/11/2019	10:00	20366 Windstream	1.00
		615 Thornton (South) AVE	
03/11/2019	09:30	20376 VACANT	0.00
		919 Thornton (South) AVE	
03/11/2019	10:00	20378 Junk mans son	0.00
		1000 Thornton (South) AVE	
03/11/2019		20379 Samano Janitorial	0.50
		1008 Thornton (South) AVE	
03/11/2019	14:00	20380 Greater Works of Dalton	0.00
		1001 Thornton (South) AVE	
03/11/2019	14:30	20381 Dalton Drag Strip	0.00
00/11/0010	14.20	1002 Thornton (South) AVE	0.00
03/11/2019	14:30	20383 Courtemanche LLC 1004 Thornton (South) AVE	0.00
02/11/2010	15.00	20384 Carstar Auto Repair	0.00
03/11/2019	13.00	1018 Thornton (South) AVE	0.00
03/18/2019		20777 East Cost Marketing	1.00
55, 10, 2017		802 John ST	1.00
03/18/2019		20778 Export Trade Service	1.00
		804 John ST	

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs Fee
501 PRE-IN	CIDENT		
03/11/2019	14:30	30010 Brooks & Collins Agency 1419 Chattanooga AVE /Suite 2	0.50
03/11/2019	14:00	30011 JBrennon Construction Inc. 1419 Chattanooga AVE /Suite 1	0.50
03/11/2019		20600 Fortune Cookie 801 Walnut (East) AVE /Suite J	0.00
03/25/2019	13:00	20635 Vacant 1027 Hamilton (South) ST	0.00
03/04/2019	09:30	20640 Jokers Audio 2132 Walnut (East) AVE /Suite-1	0.00
03/11/2019		20692 Carneceria Loa #3 801 Walnut (East) AVE /Suite G	0.00
03/11/2019		20693 Dalton RV 801 Walnut (East) AVE /Suite A	0.00
03/11/2019		20695 Vallarta 801 Walnut (East) AVE /Suite C	0.00
03/11/2019		20697 Cosmo Prof 801 Walnut (East) AVE /Suite F	0.00
03/11/2019		20699 Natural World 801 Walnut (East) AVE /Suite K	0.00
03/11/2019		20701 Groomingtails 801 Walnut (East) AVE /Suite H	0.00
03/11/2019		20702 Vacant 801 Walnut (East) AVE /Suite I	0.00
03/11/2019	09:30	20754 Barrett Marketplace 801 Walnut (East) AVE	0.00
03/11/2019		20756 Veritas 801 Walnut (East) AVE /Suite L	0.00
03/11/2019		20757 Select Staffing 801 Walnut (East) AVE /Suite N	0.00
03/11/2019		20758 Executive Management 801 Walnut (East) AVE /Suite O	0.00
03/25/2019		10026 Inventure IT 105 Depot ST	0.50
03/25/2019		10028 Cross Ins. Co 101 Crawford (East) ST /suite 102	0.25
03/25/2019		10029 Wells Fargo Advisors 101 Crawford (East) ST /Suite 101	0.25

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs	Fee
501 PRE-I	NCIDENT	SURVEY		
03/25/201	9	10032 Greenhouse Child Advocacy Center	0.50	
		101 Crawford (East) ST /Suite 201		
03/25/201	9	10039 Morris and Dean Trial Lawyers	0.25	
		101 Crawford (East) ST /Suite 300		
03/25/201	9	10042 Big Rig Lending	0.50	
		101 Crawford (East) ST /Suite 400		
03/25/201	9	10045 Little, Bates, Kelchear, PC	0.50	
		101 Crawford (East) ST /500		
03/25/201	9	10046 Wells Fargo	0.00	
		100 Hamilton (North) ST		
03/25/201	9 14:00	10190 World Finance Inc	0.25	
		110 Hamilton (North) ST		
03/04/201	9 10:00	10502 The Haymes Group Accounting/Tax Service	0.00	
		407 Thornton (North) AVE /Suite 2		
03/04/201	9 10:15	10503 CRIDERS INTERIORS	0.00	
		407 Thornton (North) AVE /Suite 4/5		
03/04/201	9 10:30	10506 Dalton Storage	0.00	
		426 Thornton (North) AVE		
03/18/201	9 13:30	10506 Dalton Storage	2.50	
		426 Thornton (North) AVE		
03/18/201	9 09:00	20001 Shaw Company Store	0.00	
		800 Abutment RD		
03/18/201	9 09:30	20155 BCS International	0.00	
		806 John ST		
03/18/201	9 10:00	20156 ZRC Plastics, Inc	0.00	
		910 John ST		
03/04/201	9 09:30	20171 SUPER BODY FITNESS CENTER	0.00	
		701 Hamilton (South) ST		
03/25/201	9 13:00	20187 Vacant	0.00	
		1021 Hamilton (South) ST		
03/25/201	9 13:00	20195 Vacant	0.00	
		1031B Hamilton (South) ST		
03/04/201	9 10:40	10786 Ruth and Doyles Warehouse	0.00	
		407 Thornton (North) AVE /Suite 1		
03/04/201	9 10:45	10787 Ruth and Doyles Florist	0.00	
		407 Thornton (North) AVE /Suite 3		
03/18/201	9 10:00	30200 Flexstar Packageing Inc.	2.00	
		1902 Kimberly Park DR		

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs	Fee
501 PRE-IN	CIDENT			
03/11/2019	15:00	30012 ALFA Insurance 1419 Chattanooga AVE /Suite 3	0.25	
03/25/2019	10:30	30266 The Valley Biscayne PL	0.50	
03/25/2019	09:30	30268 Huntington Place Apartments. 100 Brothers LN	0.50	
03/25/2019	10:00	30264 Dalton Beach Club 1898 Brady DR	0.50	
03/25/2019	14:00	30163 Whitfield Place Apartments 1320 Winton DR	1.00	
03/11/2019	10:00	30192 Dalton Ear, Nose, and Throat 1436 Chattanooga AVE	1.00	
03/29/2019	11:30	30287 Anna Shaw's Children Institute 1201 Burleyson RD	1.00	
03/25/2019	13:30	30273 The Cliffs Apartments 818 Shugart RD	0.50	
03/25/2019	09:00	30274 S & B Apartments 1030 Willowdale RD	0.50	
03/25/2019	09:00	40003 Vertex Investment Partners 2201 Executive Park DR	0.00	
03/25/2019	11:00	40005 SBG Holdings 2100 Fiber Park DR	0.00	
03/25/2019	10:30	40006 Belhaven University 2103 Fiber Park DR	0.00	
03/25/2019	10:15	40007 Invista 2104 Fiber Park DR /B	0.00	
03/25/2019	09:30	40008 FBI Dalton Resident Agency 705 College DR	0.00	
03/18/2019	09:50	40044 SPRINT PCS 1333 Walnut (West) AVE	0.00	
03/18/2019	09:50	40045 BIG LOTS 1335 Walnut (West) AVE	0.00	
03/18/2019	09:05	40043 Las Palmas 1331 Walnut (West) AVE	0.00	
03/18/2019	09:00	40050 CI CI'S PIZZA 1345 Walnut (West) AVE /Suite 2	0.00	
03/18/2019	09:35	40048 AMERICA'S BEST CONTACT & EYEGLASSES 1341 Walnut (West) AVE	0.00	

Monthly Prevention Inspections by Type

Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Date	Time	Occupancy	Hrs	Fee
501 PRE-INC	CIDENT	SURVEY		
03/18/2019	09:25	40049 Liberty Tax 1345 Walnut (West) AVE	0.00	
03/18/2019	09:45	40046 DALTON NAILS 1337 Walnut (West) AVE	0.00	
03/18/2019	09:40	40047 Tobacco Outlet 1339 Walnut (West) AVE	0.00	
Total Activ	rities	for Type: 95	17.75	

Grand Total Activities: 222 Grand Totals: 55.72 0.00

04/09/2019 06:55 Page

1

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30260 Academy Sports & Outdoors

865 Shugart RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/18/2019	*2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1		0
Notes: No	t on file.			
03/18/2019	*2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1		0
Notes: Re	check violation record automatically created from	a recheck reques	t.	
Or	iginal Violation Remarks: Not on file.			
Total Indiv	idual Violation Codes for Occupancy: 2			

50034 All Seasons Self Storage 1060 Vista DR

Dalton, GA 30720

Count Article	Division	Page
1		0
anageMyInspections.com	recheck	
1 anageMyInspections.com ge for riser room.	recheck	0
1 nnageMyInspections.com	recheck	0
	recheck	0
a a	1 anageMyInspections.com building. Order at Should be installed r Make sure to put the 1 anageMyInspections.com ge for riser room. 1 anageMyInspections.com	1 anageMyInspections.com recheck a building. Order at Should be installed near front Make sure to put the sticker on 1 anageMyInspections.com recheck ge for riser room. 1 anageMyInspections.com recheck 1 anageMyInspections.com recheck

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

50034 All Seasons Self Storage

1060 Vista DR Dalton, GA 30720

Reported Code/Description	Count Article Division Page
09/28/2018 * 2012 NFPA101 7.10.5.1 Exit sign, non function	onal 1 0
Notes: Recheck violation record auto-generated from M request.	anageMyInspections.com recheck
Original Violation Remarks: Multiple exit sign	s need repair.
09/28/2018 * 2013 NFPA 13 6.2.9.6 Sprinkler system, no h	ead 1 0
Notes: Recheck violation record auto-generated from M request.	anageMyInspections.com recheck
Original Violation Remarks: Add wrench to box.	

Total Individual Violation Codes for Occupancy: 6

30287 Anna Shaw's Children Institute

1201 Burleyson RD Dalton, GA 30720

Reported	Code/Description	Count Article Div	rision Page
03/11/2019	*2012 IFC 509.1 Riser room not marked	1	0
	echeck violation record automatically created fr riginal Violation Remarks: Add signage.	om a recheck request.	
	*2012 IFC 509.1 Riser room not marked dd signage.	1	0
	*2012 IFC 605.6 Electrical panel, cover not cover in electrical room.	1	0
Notes: R	*2012 IFC 605.6 Electrical panel, cover not echeck violation record automatically created fr riginal Violation Remarks: Cover in electrical r		0
Notes: R	*2012 IFC 912.2.1 FDC, location not signed echeck violation record automatically created fr riginal Violation Remarks: Add FDC sign.	1 om a recheck request.	0
	*2012 IFC 912.2.1 FDC, location not signed dd FDC sign.	1	0

^{*} Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30287 Anna Shaw's Children Institute

1201 Burleyson RD Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
03/11/2019	*2012 NFPA 101 9.6.1.1 Fire alarm , not installed	1			0
Ri	eed visuals in m# 2-110, 2-120, 2-121- 2-124 bike storage 2-169 2-3	159			
	moke detectors in 2nd 3rd floor IT rooms rd floor storage needs viual				
Notes: Ro O: Ro Si	*2012 NFPA 101 9.6.1.1 Fire alarm , not installed echeck violation record automatically created from a riginal Violation Remarks: Need visuals in m# 2-110, 2-120, 2-121- 2-124 bike storage 2-169 2-1 moke detectors in 2nd 3rd floor IT rooms rd floor storage needs viual			t.	0
Notes: R	*2013 NFPA 13 8.17.1.1 Sprinkler system, exterior echeck violation record automatically created from a riginal Violation Remarks: Add bell	1 a reche		t.	0
03/11/2019 Notes: Ad	*2013 NFPA 13 8.17.1.1 Sprinkler system, exterior dd bell	1			0
Notes: W	*DFDFMO AHJ, Requirement rong operating nut. dd FACP to electrical room door.	1			0
03/11/2019	* DFDFMO AHJ, Requirement	1			0
0:	echeck violation record automatically created from a riginal Violation Remarks: Wrong operating nut. dd FACP to electrical room door.	a reche	ck reques	t.	

40064 Applebee's

1322 Walnut (West) AVE

Dalton, GA 30720

Reported Code/Description Count Article Division Page

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

40064 Applebee's

1322 Walnut (West) AVE Dalton, GA 30720

Count Article Reported Code/Description Division Page 01/15/2019 * 2011 NFPA 25 4.3.6.1 Sprinkler system, Annual 0 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Have sprinkler system inspected. 01/15/2019 2012 IFC 509.1 Riser room not marked 0 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Mark riser room. 01/15/2019 *2012 IFC 912.2.1 FDC, location not signed Λ Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install FDC signage. 01/15/2019 * 2012 IMC 507.12 Cooking equipment, Proper Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Cooking equipment should be at least 6 inches inside hood. 01/15/2019 2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire 0 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Email a copy of the current inspection report. 01/15/2019 * DFDFMO AHJ, Requirement Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Secure all compressed gas cylinders.

Total Individual Violation Codes for Occupancy: 6

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

30295

Aspen Dental 849 Shugart RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/15/2019	2012 NFPA 101 7.9.3.1.1 Emergency light,	1		0
Notes: Re	pair or replace emergency lighting.			
	2012 NFPA101 7.10.5.1 Exit sign, non functional pair or replace exit signs.	1		0
03/15/2019 Notes: Un	DFDFMO AHJ, Requirement known status on sprinkler system.	1		0

Total Individual Violation Codes for Occupancy: 3

40051 Atlas Physical

1343 Walnut (West) AVE

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/16/2019	*2012 IFC 506.1 Knox Box, requirements	1		0

Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request.

Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.Install Knox Box.

Total Individual Violation Codes for Occupancy: 1

40045 BIG LOTS

1335 Walnut (West) AVE

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/08/2019	2012 IFC 506.1 Knox Box, requirements	1		0

 $\begin{tabular}{ll} \textbf{Notes:} Recheck \ violation \ record \ auto-generated \ from \ ManageMyInspections.com \ recheck \ request. \end{tabular}$

Original Violation Remarks: Install Knox Box on building. Order at

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40045 BIG LOTS
1335 Walnut (West) AVE

Dalton, GA 30720

Reported	Code/Description Count Art	icle	Division	Page
	www.knoxbox.com select Dalton Fire Department. Should be install door at a maximum height of 6 feet from ground. Make sure to pu	ut the	e sticker on	
	the door. Ensure proper key is in place to access building.Add H	Knox E	Box.	
01/08/20	19 *2012 IFC 605.3 Electrical panel, obstructed 1			0
Notes	: Recheck violation record auto-generated from ${\tt ManageMyInspections}$ request.	s.com	recheck	
	Original Violation Remarks: Remove combustibles around electrica	al par	nel.	
01/08/20	19 * 2012 IFC 605.5 Extension cord, Improper use 1			0
Notes	: Recheck violation record auto-generated from ManageMyInspections request.	s.com	recheck	
	Original Violation Remarks: Remove drop cord.			
01/08/20	19 * 2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire 1			0
Notes	: Recheck violation record auto-generated from ${\tt ManageMyInspections}$ request.	s.com	recheck	
	Original Violation Remarks: Email a copy of the current inspect:	ion re	eport.	
01/08/20	19 * 2012 NFPA 101 9.7.1.1 Sprinkler system, no 1			0
Notes	: Recheck violation record auto-generated from $ManageMyInspections$ request.	s.com	recheck	
	Original Violation Remarks: Install sprinkler head under rack.			
01/08/20	19 2012 NFPA101 7.10.5.1 Exit sign, non functional 1			0
Notes	: Recheck violation record auto-generated from ManageMyInspections request.	s.com	recheck	
	Original Violation Remarks: Check exit signage monthly.			
01/08/20	19 2013 NFPA 72 10.4.4 Smoke detector at fire alarm 1			0
Notes	:Recheck violation record auto-generated from ManageMyInspections request.	s.com	recheck	
	Original Violation Remarks: Install smoke detector above fire a	larm p	oanel.	
01/08/20	19 2013 NFPA 72 17.14.8.2 Fire alarm, pull station 1			0
Notes	:Recheck violation record auto-generated from ManageMyInspections request.	s.com	recheck	
	Original Violation Remarks: Remove items blocking the pull stat:	ion.		

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40045 BIG LOTS

1335 Walnut (West) AVE Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
01/08/2019	*2013 NFPA 8.6.5.3.1 Storage with 18" of sprinkler	1			0
re Or	echeck violation record auto-generated from ManageMy equest. riginal Violation Remarks: Keep storage at least 18 eads.	_			

Total Individual Violation Codes for Occupancy: 9

30211 Blood Assurance 785 Shugart RD

5

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/12/2019	2011 NFPA 25 13.7.1 FDC, caps missing	1		0
Notes: Ad	d caps.			
03/12/2019	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1		0
Notes: Ha	ve inspection completed.			
03/12/2019	2012 IFC 506.1 Knox Box, requirements	1		0
Notes: In	stall Knox Box on building. Order at			
ht	tps://www.knoxbox.com/store/selectProduct.cfm?fdI	D=7992. It shou	ld be	
in	stalled near front door at a maximum height of 6	feet from ground	. Make sure	
to	put the sticker on the door. Ensure proper key i	s in place to acc	cess	
	ilding.Add Knox Box to building.			
03/12/2019	2012 IFC 509.1 Riser room not marked	1		0
Notes: Ma	rk riser room.			
03/12/2019	2012 IFC 509.2 Sprinkler system, Riser/Valves	1		0
Notes: Ne	ed key for riser room.			
03/12/2019	2012 IFC 906.2 Fire extinguisher, Properly	1		0
Notes: Ha	ve extinguishers inspected by a licensed contract	or.		

^{*} Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30211 Blood Assurance 785 Shugart RD

5

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/12/2019	2012 IFC 912.2.1 FDC, location not signed	1		0
Notes: Ad	d signage.			
	2013 NFPA 72 8.16.1.1.2.1 Sprinkler system,	1		0
Notes: Un.	known, two pits.			

Total Individual Violation Codes for Occupancy: 8

10788 Carlson & Carlson

311 Hamilton (North) ST

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/06/2019	2012 IFC 505.1 Address, no suite	1		0
sh	dress numbers should be a minimum of 4 inches tal would be visible from road fronting the property, ackground.	•		
Notes: In De fr	2012 IFC 506.1 Knox Box, requirements astall Knox Box on building. Order at www.knoxbox apartment. Should be installed near front door at com ground. Make sure to put the sticker on the cace to access building.	a maximum height	of 6 feet	0
	2012 IFC 605.1 Electrical panel, abatement of sposed wiring should be in conduit.	1		0
	2012 IFC 605.6 Electrical panel, cover not stall fans as discussed or cap junction boxes.	1		0
Notes: Co	2012 IFC 906.2 Fire extinguisher, Properly ontact a GA licensed fire extinguisher contractor stinguishers.	1 to install approp	riate	0

^{*} Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

10788 Carlson & Carlson

311 Hamilton (North) ST

Dalton, GA 30720

Reported Code/Description Count Article Division Page

Total Individual Violation Codes for Occupancy: 5

40041 CHRIST CHURCH PRESBYTERIAN CHURCH

510 Tibbs (South) RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
	*2012 IFC 506.1 Knox Box, requirements echeck violation record automatically created fr	1	+	(
C W C	original Violation Remarks: Install Knox Box on byww.knoxbox.com select Dalton Fire Department. Soloor at a maximum height of 6 feet from ground. The door. Ensure proper key is in place to access the building.	ouilding. Order at Should be installed : Make sure to put th	near front e sticker on	
Notes: F	*2012 IFC 509.1 Riser room not marked Recheck violation record automatically created froriginal Violation Remarks: Mark sprinkler room w	-		C
Notes: F	*2012 IFC 605.3 Electrical panel, obstructed echeck violation record automatically created from the priginal Violation Remarks: Remove combustibles in			(
Notes: F	*2012 IFC 605.5 Extension cord, Improper use echeck violation record automatically created from the cord of the cords of t	-		C
Notes: F	*2012 NFPA 101 7.1.10.1 MOE, unimpeded exit accepted the violation record automatically created from the violation Remarks: Remove storage in states the egress path clear.	om a recheck reques	t.	C
Notes: F	*2012 NFPA 101 8.3.5.1 Firewall, penatrations Recheck violation record automatically created fr Original Violation Remarks: Seal firewall penetra		t.	C

^{*} Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40041 CHRIST CHURCH PRESBYTERIAN CHURCH 510 Tibbs (South) RD Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
01/31/2019	*2012 NFPA101 7.10.5.1 Exit sign, non functional	1			0
Notes: Re	check violation record automatically created from a	reched	ck reques	t.	
Or	iginal Violation Remarks: Do not cover exit signage	•			
01/31/2019	*2013 NFPA 8.6.5.3.1 Storage with 18" of sprinkler	1			0
Notes: Re	check violation record automatically created from a	reched	ck reques	t.	
Or	iginal Violation Remarks: Keep storage at least 18	inches	below sp	rinkler	
hea	ads.				
01/31/2019	*DFDFMO AHJ, Requirement	1			0
Notes: Re	check violation record automatically created from a	reched	ck reques	t.	
	iginal Violation Remarks: Storage platform should h	ave spi	rinkler p	rotection	
Ke	ep stairwell doors closed.				
Ke	ep riser room accessible.				

Total Individual Violation Codes for Occupancy: 9

40083 Country Inn and Suites 903 West Bridge RD Dalton, GA 30720

01/23/2019 * 2012 IFC 315.3.3 Storage, equipment rooms Notes: Recheck violation record automatically created from a	1 a recheck req		0
-	a recheck req		
		uest.	
Original Violation Remarks: Remove combustibles in r	iser room.		
01/23/2019 * 2012 IFC 509.1 Riser room not marked	1		0
Notes: Recheck violation record automatically created from	a recheck req	uest.	
Original Violation Remarks: Mark riser room.			
01/23/2019 * 2013 NFPA 13 8.17.1.1 Sprinkler system, exterior	1		0
Notes: Recheck violation record automatically created from	a recheck req	uest.	
Original Violation Remarks: Bell not operational per	inspection r	eport.	
01/23/2019 * DFDFMO AHJ, Requirement	1		0
Notes: Recheck violation record automatically created from	a recheck req	uest.	
Original Violation Remarks: Have sprinkler system ca	lc plate perm	anently marked	

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

40083 Country Inn and Suites

903 West Bridge RD Dalton, GA 30720

Reported Code/Description Count Article Division Page

by engraving or stamping.

Total Individual Violation Codes for Occupancy: 4

40090 Courtyard by Marriott

785 College DR Dalton, GA 30720

Reported Code/Description Count Article Division Page

01/29/2019 * 2011 NFPA 96 8.1.1.1 Kitchen hood, Exhaust fan

_

0

Notes: Recheck violation record automatically created from a recheck request.

Original Violation Remarks: Have exhaust fan hinged.

Total Individual Violation Codes for Occupancy: 1

10754 Dalton Fire Department Station 1

404 School ST Dalton, GA 30720

Reported Code/Description Count Article Division Page

03/11/2019 2012 IFC 506.1 Knox Box, requirements

Notes: Install Knox Box on building. Order at https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992. It should be

installed near front door at a maximum height of 6 feet from ground. Make sure

to put the sticker on the door. Ensure proper key is in place to access

building.Test

Total Individual Violation Codes for Occupancy: 1

40046 DALTON NAILS

1337 Walnut (West) AVE

Dalton, GA 30720

Reported Code/Description Count Article Division Page

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

01/17/2019 2012 IFC 506.1 Knox Box, requirements 1	0
Notes: Recheck violation record automatically created from a recheck request.	
Original Violation Remarks: Install Knox Box on building. Order at	
www.knoxbox.com select Dalton Fire Department. Should be installed near front	
door at a maximum height of 6 feet from ground. Make sure to put the sticker on	
the door. Ensure proper key is in place to access building.Install Knox Box on building.	
01/17/2019 * 2012 IFC 605.5 Extension cord, Improper use 1	0
Notes: Recheck violation record automatically created from a recheck request.	
Original Violation Remarks: Extension cords should only be used for temporary power.	
01/17/2019 * 2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access 1	0
Notes: Recheck violation record automatically created from a recheck request.	
Original Violation Remarks: Remove items blocking the door.	
01/17/2019 * 2012 NFPA101 7.10.5.1 Exit sign, non functional 1	0
Notes: Recheck violation record automatically created from a recheck request.	
Original Violation Remarks: Repair or replace exit signage.	
Original Violation Remarks: Repair or replace exit signage. Total Individual Violation Codes for Occupancy: 4	

-

30210 First Bank of Dalton 785 Shugart RD 11 Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/14/2019	2011 NFPA 25 13.7.1 FDC, caps missing	1		0
Notes: Ad	d caps to FDC.			
	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1		0
Notes: Ha	ve system inspected.			
03/14/2019	2012 IFC 506.1 Knox Box, requirements	1		0
Notes: In	stall Knox Box on building. Order at			
ht	tps://www.knoxbox.com/store/selectProduct.cfm?fdl	ID=7992. It shoul	d be	
in	stalled near front door at a maximum height of 6	feet from ground.	Make sure	
to	put the sticker on the door. Ensure proper key	is in place to acc	ess	
bu	ilding.Add Knox Box to building.			

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30210 First Bank of Dalton

785 Shugart RD

11

Dalton, GA 30720

Reported	Code/Description	Count Article	e Division	Page
03/14/2019	2012 IFC 509.1 Riser room not marked	1		0
Notes: Ma	rk riser room,			
03/14/2019	2012 IFC 912.2.1 FDC, location not signed	1		0
Notes: Ad	d signage to FDC.			
03/14/2019	2012 IFC 912.2.1 / ORD 7L FDC, blocked/obstructed	1		0
Notes: Ha	ve FDC raised to proper height.			
03/14/2019	2013 NFPA 72 8.16.1.1.2.1 Sprinkler system,	1		0
Notes: Un	known, appears to be locked, currently underwater a	nd not marked		

Total Individual Violation Codes for Occupancy: 7

40156 Fuji Japanese Steakhouse

1321 Walnut (West) AVE

Suite 1

Dalton, GA 30720

Reported Code/Description	Count Article	Division	Page
01/17/2019 *2011 NFPA 96 10.1.1 Kitchen hood suppression	n 1		0
Notes: Recheck violation record automatically created	from a recheck request		
Original Violation Remarks: Ensure suppression	system heads are in co	rrect place	
to cover cooking equipment.			
01/17/2019 * 2011 NFPA 96 11.4 Kitchen hood,	1		0
Notes: Recheck violation record automatically created	from a recheck request		
Original Violation Remarks: Hood inspection was inspected.	s due in December, have	e hoods	
01/17/2019 * 2011 NFPA 96 11.7.2 Cooking equipment,	1		0
Notes: Recheck violation record automatically created	from a recheck request		
Original Violation Remarks: Clean cooking equipequipequipequipequipequipequipequip	oment and areas around	cooking	

^{*} Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40156 Fuji Japanese Steakhouse 1321 Walnut (West) AVE Suite 1

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/17/2019	9 *2012 IFC 605.3 Electrical panel, obstructed	1		(
Notes:	Recheck violation record automatically created fr	om a recheck reques	st.	
(Original Violation Remarks: Remove combustibles n	ear electrical pane	el.	
01/17/2019	9 *2012 IFC 605.5 Extension cord, Improper use	1		(
Notes:	Recheck violation record automatically created fr	om a recheck reques	st.	
(Original Violation Remarks: Extension cords should	d only be used for	temporary	
1	power.			
01/17/2019	9 *2012 IFC 906.2 Fire extinguisher, Properly	1		(
Notes:	Recheck violation record automatically created fr	om a recheck reques	st.	
(Original Violation Remarks: Fire extinguisher nee	ds inspection, and	recharged.	
01/17/2019	9 * 2012 NFPA 101 7.1.10.1 MOE, unimpeded exit acc	ess 1		(
Notes:	Recheck violation record automatically created fr	om a recheck reques	st.	
(Original Violation Remarks: Remove items blocking	rear exit.		
01/17/2019	9 *2012 NFPA 101 7.9.3.1.1 Emergency light,	1		(
Notes:	Recheck violation record automatically created fr	om a recheck reques	st.	
(Original Violation Remarks: Repair or replace eme	rgency lights.		
01/17/2019	9 *2013 NFPA 10 6.1.3.8.1 Fire extinguisher,	1		(
Notes:	Recheck violation record automatically created fr	om a recheck reques	st.	
(Original Violation Remarks: Hang fire extinguishe	r.		
01/17/2019	9 * 2013 NFPA 10 7.3.2.1 Extinguisher damaged/6yr	1		(
Notes:	Recheck violation record automatically created fr	om a recheck reques	st.	
(Original Violation Remarks: Fire extinguisher sho	wing damage should	be replaced,	,
	and moved away from mop sink.			

30213 Game Stop 785 Shugart RD 7 Dalton, GA 30720

Reported Code/Description Count Article Division Page

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

03/14/2019 2011 NFPA 25 13.7.1 FDC, caps missing	1	0
Notes: Add caps.	1	U
Notes: Add Caps.		
03/14/2019 2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1	0
Notes: Have inspection performed.		
03/14/2019 2012 IFC 506.1 Knox Box, requirements	1	0
Notes: Install Knox Box on building. Order at		
https://www.knoxbox.com/store/selectProduct.cfm?fdID=7	992. It should be	
installed near front door at a maximum height of 6 fee	t from ground. Make sure	
to put the sticker on the door. Ensure proper key is i	n place to access	
building.Add Knox Box to building.		
03/14/2019 2012 IFC 509.1 Riser room not marked	1	0
Notes: Mark riser room.		
03/14/2019 2012 IFC 912.2.1 FDC, location not signed	1	0
Notes: Add FDC signage.		
03/14/2019 2012 IFC 912.2.1 / ORD 7L FDC, blocked/obstructed	1	0
Notes: Raise FDC to appropriate height.		
03/14/2019 2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access	1	0
Notes: Exit door must remain unblocked.		
03/14/2019 2013 NFPA 72 8.16.1.1.2.1 Sprinkler system,	1	0
Notes: Unknown, valves are underwater and not marked.		
03/14/2019 DFDFMO AHJ, Requirement	1	0
Notes: No combustibles or storage within 36 inches of electri		

20776 Garcia Son's Tires and More 1104 Thornton (South) AVE Dalton, GA 30720

Reported	Code/Description	Count Artic	le Division	Page
03/13/2019	2012 IFC 506.1 Knox Box, requirements	1		0
Notes: I	nstall Knox Box on building. Order at			
h	ttps://www.knoxbox.com/store/selectProduct.cf	m?fdID=7992. It sho	ould be	

installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

20776 Garcia Son's Tires and More 1104 Thornton (South) AVE Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
bu	ilding.			
	2012 IFC 605.1 Electrical panel, abatement of stall blanks in electrical panel.	1		0
	2012 IFC 605.1 Electrical panel, abatement of posed wiring should be in conduit.	1		0
	2012 IFC 605.3 Electrical panel, obstructed ep combustibles atleast 3 feet away from electrica	1 l panels.		0
	2012 IFC 605.5 Extension cord, Improper use tension cords should only be used for temporary po	1 wer.		0
Notes: In	2012 IFC 906.2 Fire extinguisher, Properly stall appropriate fire extinguishers, and have the re extinguisher contractor.	1 m serviced by a (GA licensed	0
	2012 NFPA 101 7.9.2.1 Emergency light, none stall emergency lighting so occupants can get out	1 in case of a powe	er failure.	0
	idual Violation Codes for Occupancy: 7			

40161 Georgia Hope Family & Childrens 1414 Dug Gap RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/25/2019	*2012 IFC 906.2 Fire extinguisher, Properly	1		0
	echeck violation record automatically created from riginal Violation Remarks: Update extinguishers.	a recheck reques	t.	
01/25/2019	* DFDFMO AHJ, Requirement	1		0
Notes: Re	echeck violation record automatically created from	a recheck reques	t.	
0:	riginal Violation Remarks: Add smoke alarms.			

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40161 Georgia Hope Family & Childrens

1414 Dug Gap RD Dalton, GA 30720

Reported Code/Description Count Article Division Page

Total Individual Violation Codes for Occupancy: 2

30209 Great Clips

785 Shugart RD

3

Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
03/12/2019	2011 NFPA 25 13.7.1 FDC, caps missing	1			0
Notes: Ha	ave caps put on.				
03/12/2019	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1			0
Notes: Ne	eeds inspection.				
03/12/2019	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: In	nstall Knox Box on building. Order at				
ht	tps://www.knoxbox.com/store/selectProduct.cfm?fdI	D=7992.	It should	d be	
ir	nstalled near front door at a maximum height of 6	feet fro	m ground.	Make sure	
	put the sticker on the door. Ensure proper key i		2		
	ailding.Add Knox Box to building.	.b in pia	ce to acc.		
D C	ariang. Add know box to buriang.				
03/12/2019	2012 IFC 509.1 Riser room not marked	1			0
Notes: Ma	ark riser room.				
03/12/2019	2012 IFC 509.2 Sprinkler system, Riser/Valves	1			0
Notes: Ne	eed key.				
03/12/2019	2012 IFC 912.2.1 FDC, location not signed	1			0
Notes: Ad	dd signage.				
03/12/2019	2013 NFPA 72 8.16.1.1.2.1 Sprinkler system,	1			0
Notes: Ur	nknown, two pits.				

Total Individual Violation Codes for Occupancy: 7

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30033 Guest Inn 2220 Chattanooga RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
02/14/2019	2012 IFC 605.1 Electrical panel, abatement of	1		0
	echeck violation record automatically created from a	a recheck reques	t.	
Oı	riginal Violation Remarks: Must be in conduit.			
02/14/2019	2012 IFC 605.1 Electrical panel, abatement of	1		0
Notes: Re	echeck violation record automatically created from a	a recheck reques	t.	
Oı	riginal Violation Remarks: Must repair.			
02/14/2019	2012 IFC 605.5 Extension cord, Improper use	1		0
	echeck violation record automatically created from a	a recheck reques	t.	
	riginal Violation Remarks: See nots.			
02/14/2019	2012 IFC 605.5.3 Extension cord, Maintenance	1		0
Notes: Re	echeck violation record automatically created from a	a recheck reques	t.	
O	riginal Violation Remarks: Cannot use co dis for per	rmanent wiring.		
02/14/2019	2012 IFC 605.6 Electrical panel, cover not	1		0
Notes: Re	echeck violation record automatically created from a	a recheck reques	t.	
Oı	riginal Violation Remarks: Replace cover.			
02/14/2019	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access	1		0
Notes: Re	echeck violation record automatically created from a		t.	
Oı	riginal Violation Remarks: Cannot block.			
02/14/2019	2012 NFPA 101 7.2.2.2.1 MOE, stairs (existing)	1		0
	echeck violation record automatically created from a	a recheck reques	t.	
Oı	riginal Violation Remarks: Correct issues with stair	îs.		
02/14/2019	2012 NFPA 101 7.2.2.4.5.2 MOE, guardrails	1		0
	echeck violation record automatically created from a	a recheck reques	t.	
	riginal Violation Remarks: Must be brought up to cod			
02/14/2019	2012 NFPA 101 7.9.3.1.1 Emergency light,	1		0
	echeck violation record automatically created from a	a recheck reques	t.	
	riginal Violation Remarks: See note on cit sign.	-		
02/14/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional	1		0
	echeck violation record automatically created from a	-	t.	Ü
	riginal Violation Remarks: Repair or replace exit si			
re	emoved and hard wired.			

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30033 Guest Inn

2220 Chattanooga RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
02/14/2019	DFDFMO AHJ, Requirement	1		0
Notes: Red	check violation record automatically created from a	recheck reques	t.	
Or	iginal Violation Remarks: Smoke alarm out in rm 105			
Rm	107 no smoke alarm.			
Rm	111 not working.			
Rm	115 not working.			
Rm	211 has extension cord to another room.			
Rm	209 no alarm.			
No	emergency lights on exterior are working.			
Rm	203 no smoke alarm.			
Ado	d m 207 no smoke alarm. (Bed Bug) issues.			
Blo	dg. 2			
Rm	125 No smoke alarm			
Rm	129			
Rm	132 needs battery			
Rm	130 not working			
Rm	126 not working			
Rm	124 not working			
Rm	120 not working			
Blo	dg. 3			
Rm	135 not working			
Rm	137 not working			
Rm	139 not working			
Rm	145 no alarm			
Rm	246 no alarm			
Rm	242 not working			
Rm	233 not working			

Total Individual Violation Codes for Occupancy: 11

40150 Hilton Garden Inn

879 Holiday Inn DR Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page

* Denotes Violations Corrected or Variance Issued

04/09/2019 06:56 Page

1

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40150 Hilton Garden Inn 879 Holiday Inn DR Dalton, GA 30720

Reported	Code/Description	Count Artic	le Division	Page
02/04/2019	*2012 NFPA 101 7.9.3.1.1 Emergency light,	1		0
	check violation record automatically created from a riginal Violation Remarks: Repair or replace emergen		uest.	
Notes: Re	*2013 NFPA 13 6.2.7.2 Sprinkler system, eschusion check violation record automatically created from a siginal Violation Remarks: Replace rings.	1 a recheck req	uest.	0

Total Individual Violation Codes for Occupancy: 2

40012 Holiday Inn Express 865 Holiday Inn DR Dalton, GA 30720

Reported Cod	de/Description	Count	Article	Division	Page
01/02/2019 * 201	.2 NFPA 101 7.2.1.8.2.1 Firedoor, no auto	1			0
Notes: Recheci	k violation record auto-generated from ManageMy	Inspect	tions.com	recheck	
reques	t.				
Origin	al Violation Remarks: Broken closer on door on	second	floor.		
01/02/2019 * 201	2 NFPA101 7.10.5.1 Exit sign, non functional	1			0
Notes: Rechect	k violation record auto-generated from ManageMy	Inspect	tions.com	recheck	
reques	t.				
Origin	al Violation Remarks: Repair or replace exit si	gn near	r pool and	d front	
entran	ce.				

Total Individual Violation Codes for Occupancy: 2

30296 I Luv Nails

851 Shugart RD Dalton, GA 30720

Reported Code/Description Count Article Division Page

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

30296 I Luv Nails

851 Shugart RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/15/2019	DFDFMO AHJ, Requirement	1		0

Notes: Unknown status of sprinkler system.

Total Individual Violation Codes for Occupancy: 1

30011 JBrennon Construction Inc.

1419 Chattanooga AVE

Suite 1

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/07/2019	*2012 IFC 605.3 Electrical panel, obstructed	1		0
	Recheck violation record auto-generated from inspectemove combustibles near electrical panel.	tion on 01/07/201	9.	
01/07/2019	*2013 NFPA 10 6.1.3.8.1 Fire extinguisher,	1		0
Notes: R	echeck violation record auto-generated from inspec	tion on 01/07/201	9.	
F	ire Extinguisher needs to be hung.			
03/12/2019	2012 IFC 506.1 Knox Box, requirements	1		0
Notes: I	nstall Knox Box on building. Order at			
h	https://www.knoxbox.com/store/selectProduct.cfm?fdI	D=7992. It shoul	d be	
i	nstalled near front door at a maximum height of 6	feet from ground.	Make sure	
t	to put the sticker on the door. Ensure proper key i	s in place to acc	ess	
b	ouilding.Install Knox Box on the building.			

Total Individual Violation Codes for Occupancy: 3

40189 KFC

1519 Walnut (West) AVE

Dalton, GA 30720

Reported Code/Description Count Article Division Page

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40189 KFC

1519 Walnut (West) AVE Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
03/19/2019	*DFDFMO AHJ, Requirement	1			0
Notes: Th	ne following items need to be addressed:				
1.	. Hinge kit installed on exhaust fans				
2	. Grease containment device installed at exhaust far	ı			
3 .	. Class K placard needed				
4 .	. Install exit signage as discussed				
5 .	. Install Knox Box				
6	Install new wiring on exhaust fans.				
03/19/2019	*DFDFMO AHJ, Requirement	1			0
Notes: V	tolation carried over from inspection on 03/19/2019				
Tł	ne following items need to be addressed:				
1.	. Hinge kit installed on exhaust fans				
2 .	. Grease containment device installed at exhaust far	ı			
3 .	. Class K placard needed				
4 .	Install exit signage as discussed				
5 .	Install Knox Box				
6.	Install new wiring on exhaust fans.				
Al	ll items have been corrected with the exception of t	he gre	ase conta	inment	

device for the exhaust fan which has been added.

Total Individual Violation Codes for Occupancy: 2

30254 Kohl's

835 Shugart RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/18/2019	2012 NFPA 101 7.9.3.1.1 Emergency light,	1		0
Notes: Se	veral emergency lights out in storage area.			
03/18/2019	2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1		0
Notes: No	copy on file.			

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

30254 Kohl's

835 Shugart RD Dalton, GA 30720

Reported Code/Description Count Article Division Page

Total Individual Violation Codes for Occupancy: 2

40059 KROGER

1365 Walnut (West) AVE Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
01/08/2019	*2011 NFPA 96 11.7.2 Cooking equipment,	1			0
Notes: R	echeck violation record auto-generated from ManageMy	Inspec	tions.com	recheck	
r	equest.				
C	riginal Violation Remarks: Clean filters on a regula	ar basi	s.		
01/08/2019	*2012 IFC 605.3 Electrical panel, obstructed	1			0
	echeck violation record auto-generated from ManageMy equest.	/Inspec	tions.com	recheck	
C	riginal Violation Remarks: Remove combustibles arour	nd elec	trical pa	nel.	
01/08/2019	*2012 IFC 906.3 Fire extinguisher, incorrect	1			0
	echeck violation record auto-generated from ManageMy equest.	Inspec	tions.com	recheck	
C	riginal Violation Remarks: Fire extinguisher missing	ð.			
01/08/2019	*2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1			0
	echeck violation record auto-generated from ManageMy equest.	Inspec	tions.com	recheck	
C	riginal Violation Remarks: Email a copy of the curre	ent ins	pection r	eport.	
01/08/2019	*2013 NFPA 10 6.1.3.8.1 Fire extinguisher,	1			0
	echeck violation record auto-generated from ManageMy equest.	/Inspec	tions.com	recheck	
C	riginal Violation Remarks: Hang class k extinguisher	f.			
01/08/2019	*2013 NFPA 8.6.5.3.1 Storage with 18" of sprinkler	1			0
	echeck violation record auto-generated from ManageMy equest.	/Inspec	tions.com	recheck	
	riginal Violation Remarks: Keep storage at least 18 eads.	inches	below sp	rinkler	

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40059 KROGER

1365 Walnut (West) AVE Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/08/20	19 * 2013 NFPA 96 10.2.2 Class K placard required	1		0
Notes	:Recheck violation record auto-generated from ManageM request.	MyInspections.co	m recheck	
	Original Violation Remarks: See Annex A NFPA 10Instaclass k extinguisher.	all class k plac	ard above	
01/08/20	19 *DFDFMO AHJ, Requirement	1		0
Notes	:Recheck violation record auto-generated from ManageM request.		m recheck	
	Original Violation Remarks: Secure compressed gas cy Replace hydraulic calc plates with metal engraved or			

Total Individual Violation Codes for Occupancy: 8

40009 La Quinta Inn & Suites

715 College DR Dalton, GA 30720

Reported	Code/Description	Count Artic	le Division	Page
12/13/2018	2012 IFC 509.1 Riser room not marked	1		0
re	check violation record auto-generated from ManageM quest. iginal Violation Remarks: Mark riser room.	MyInspections.	com recheck	
Notes: Re	*2012 NFPA101 7.10.5.1 Exit sign, non functional check violation record auto-generated from ManageMquest.	1 MyInspections.	com recheck	0
Or	iginal Violation Remarks: Repair or replace exit s	signs.		
12/13/2018	*2013 NFPA 13 6.2.9.6 Sprinkler system, no head	1		0
	check violation record auto-generated from $ManageM$ quest.	MyInspections.	com recheck	
Or	iginal Violation Remarks: Riser room in conference	e area has no	wrench.	

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40043 Las Palmas 1331 Walnut (West) AVE

Dalton, GA 30720

Reported	Code/Description Com	unt Article	Division	Page
01/25/2019	2012 IFC 506.1 Knox Box, requirements	1		0
Or wv	echeck violation record automatically created from a re- riginal Violation Remarks: Install Knox Box on building ww.knoxbox.com select Dalton Fire Department. Should be	. Order at e installed	near front	
th	oor at a maximum height of 6 feet from ground. Make su he door. Ensure proper key is in place to access building.	_		
01/25/2019	*2012 IFC 605.3 Electrical panel, obstructed	1		0
	echeck violation record automatically created from a recriginal Violation Remarks: Remove combustibles near elec	_		
01/25/2019	*2012 IMC 507.12 Cooking equipment, Proper	1		0
Or	echeck violation record automatically created from a re- riginal Violation Remarks: All cooking equipment should nside hood.	_		
01/25/2019	2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1		0
Notes: Re	echeck violation record automatically created from a re-	check reques	st.	
Or	riginal Violation Remarks: Email a copy of the current	inspection r	report.	
01/25/2019	*2013 NFPA 10 6.1.3.8.1 Fire extinguisher,	1		0
	echeck violation record automatically created from a recriginal Violation Remarks: Hang fire extinguisher.	check reques	st.	
01/25/2019	*2013 NFPA 10 6.6.1 Class K fire extinguisher	1		0
Notes: Re	echeck violation record automatically created from a re-	check reques	st.	
Or	riginal Violation Remarks: Class K fire extinguisher is	missing.		
01/25/2019	2013 NFPA 72 10.21 Fire alarm impaired, silenced,	1		0
	echeck violation record automatically created from a re-	check reques	st.	
Or	riginal Violation Remarks: Have fire alarm repaired.			
01/25/2019	*2013 NFPA 96 10.2.2 Class K placard required	1		0
	echeck violation record automatically created from a re-	_		
Or	riginal Violation Remarks: See Annex A NFPA 10Replace c	lass k placa	ırd.	

Total Individual Violation Codes for Occupancy: 8

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

30265 Legacy of Dalton

> 2111 Club DR Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/07/2019	DFDFMO AHJ, Requirement	1		0
Notes: 21	.20, 2122,, 2123, 2124, 2125, 2126, 2127 need ex	xtinguishers on lower	floors.	
03/07/2019	DFDFMO AHJ, Requirement	1		0
Notes: Re	echeck violation record automatically created fr	rom a recheck request		
Or	riginal Violation Remarks: 2120, 2122,, 2123, 21	124, 2125, 2126, 2127	need	
ех	tinguishers on lower floors.			

Total Individual Violation Codes for Occupancy: 2

40049 Liberty Tax

1345 Walnut (West) AVE

Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
01/11/2019	2012 IFC 505.1 Address, no suite	1			0
Notes: Re	echeck violation record auto-generated from Manag	eMyInspec	tions.com	recheck	
re	equest.				
Or	riginal Violation Remarks: Address numbers should	be a min	imum of 4	inches tall	
an	nd 1/2 inch wide. Numbers should be visible from	road from	nting the	property,	
an	nd be contrasting to the background.Install addre	ss number	s on build	ding minimum	
4	inches tall and 1/2 inch wide.				

Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck

request. Original Violation Remarks: Install Knox Box on building. Order at

www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box on building.

Total Individual Violation Codes for Occupancy: 2

01/11/2019 2012 IFC 506.1 Knox Box, requirements

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30214 Marco Pizza 785 Shugart RD 8

Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
	2011 NFPA 25 13.7.1 FDC, caps missing place caps.	1			0
03/14/2019 Notes: Ha	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual ve inspection completed.	1			0
03/14/2019 Notes: Ho	2011 NFPA 96 11.4 Kitchen hood, od must be inspected.	1			0
	2011 NFPA 96 6.2.3.3 Kitchen hood, grease lters not cleaned.	1			0
ht in to	2012 IFC 506.1 Knox Box, requirements stall Knox Box on building. Order at tps://www.knoxbox.com/store/selectProduct.cfm?fdIstalled near front door at a maximum height of 6 put the sticker on the door. Ensure proper key is ilding.Add Knox Box to building.	feet fro	It should	Make sure	0
	2012 IFC 509.1 Riser room not marked rk riser room.	1			0
	2012 IFC 912.2.1 FDC, location not signed d FDC signage.	1			0
	2012 IFC 912.2.1 / ORD 7L FDC, blocked/obstructe ise FDC to appropriate height.	ed 1			0
03/14/2019 Notes: Em	2012 NFPA 101 7.9.3.1.1 Emergency light, ergency light needs replaced.	1			0
03/14/2019 Notes: Ad	2013 NFPA 10 6.6.1 Class K fire extinguisher d Class K extinguisher in kitchen.	1			0
03/14/2019 Notes: Un	2013 NFPA 72 8.16.1.1.2.1 Sprinkler system, known, valves are under water and not marked.	1			0

Total Individual Violation Codes for Occupancy: 11

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30294 Mattress Firm 845 Shugart RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/15/2019	2011 NFPA 25 7.3.2 Fire hydrant, no annual	1		0
Notes: Un	known			
	2012 NFPA 101 7.9.3.1.1 Emergency light,	1		0
Notes: Re	pair or replace emergency lighting.			

Total Individual Violation Codes for Occupancy: 2

40079 O'Charley's

1520 Walnut (West) AVE Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/23/2019	2011 NFPA 96 6.2.3.3 Kitchen hood, grease	1		0
Notes: Re	check violation record automatically created from	a recheck reques	st.	
Or	iginal Violation Remarks: Install missing grease f	Eilter.		
01/23/2019	2011 NFPA 96 8.1.1.1 Kitchen hood, Exhaust fan	1		0
Notes: Re	check violation record automatically created from	a recheck reques	st.	
Or	iginal Violation Remarks: Exhaust fans not hinged.			
01/23/2019	2012 IFC 506.1 Knox Box, requirements	1		0
Notes: Re	check violation record automatically created from	a recheck reques	st.	
Or	riginal Violation Remarks: Install Knox Box on buil	ding. Order at		
WW	w.knoxbox.com select Dalton Fire Department. Shou	ald be installed	near front	
do	or at a maximum height of 6 feet from ground. Mak	ce sure to put th	he sticker or	ı
th	ne door. Ensure proper key is in place to access bu	uilding.Install H	Knox Box on	
bu	uilding.			
01/23/2019	2012 IMC 507.12 Cooking equipment, Proper	1		0
Notes: Re	check violation record automatically created from	a recheck reques	st.	
Or	iginal Violation Remarks: Move equipment inside ho	ood.		
01/23/2019	2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1		0
Notes: Re	check violation record automatically created from	a recheck reques	st.	
Or	riginal Violation Remarks: Email a copy of the curr	ent inspection i	report.	

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40079 O'Charley's

1520 Walnut (West) AVE

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
Reported	code/ Description			Page

Total Individual Violation Codes for Occupancy: 5

20318 One Source Sample LLC.

950 Riverbend DR Dalton, GA 30720

* Denotes Violations Corrected or Variance Issued

04/09/2019 06:56

10/26/2018 2011 NFPA 25 4.3.6.1 Sprinkler system, Annual 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Email report once Carpet Capital has finished their inspection. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building.	Reported Code/	Description	Count	Article	Division	Page
request. Original Violation Remarks: Email report once Carpet Capital has finished their inspection. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building.	10/26/2018 2011	NFPA 25 4.3.6.1 Sprinkler system, Annual	1			
Original Violation Remarks: Email report once Carpet Capital has finished their inspection. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building.	Notes: Recheck v	violation record auto-generated from ManageN	MyInspect	tions.com	recheck	
inspection. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building.	request.					
Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building.	Original	Violation Remarks: Email report once Carpet	Capita:	l has fin	ished their	
Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building.	inspection	on.				
request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	10/26/2018 2012	IFC 506.1 Knox Box, requirements	1			
Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building.	Notes: Recheck v	violation record auto-generated from ManageM	MyInspect	tions.com	recheck	
<pre>www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements</pre>	request.					
door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	Original	Violation Remarks: Install Knox Box on buil	lding. (Order at		
the door.Install Knox Box on building. 10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building.	www.knoxk	pox.com select Dalton Fire Department. Show	ıld be in	nstalled :	near front	
10/26/2018 2012 IFC 506.1 Knox Box, requirements 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	door at a	a maximum height of 6 feet from ground. Mak	ke sure	to put th	e sticker on	
Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	the door.	.Install Knox Box on building.				
request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	10/26/2018 2012	IFC 506.1 Knox Box, requirements	1			
Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	Notes: Recheck v	violation record auto-generated from ManageN	MyInspect	tions.com	recheck	
<pre>www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1</pre>	request.					
door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	Original	Violation Remarks: Install Knox Box on buil	lding. (Order at		
the door.Install key once box is installed. 10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	www.knoxk	oox.com select Dalton Fire Department. Show	ıld be in	nstalled :	near front	
<pre>10/26/2018 2012 NFPA 101 7.10.1.8 Exit sign, not visible 1 Notes:Recheck violation record auto-generated from ManageMyInspections.com recheck</pre>	door at a	a maximum height of 6 feet from ground. Mak	ke sure t	to put th	e sticker on	
Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	the door.	Install key once box is installed.				
Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	10/26/2018 2012	NFPA 101 7.10.1.8 Exit sign, not visible	1			(
request. Original Violation Remarks: Ensure exit signage is visible from all areas of building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	Notes: Recheck v	violation record auto-generated from ManageN	MyInspect	tions.com	recheck	
building. 10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1						
10/26/2018 2012 NFPA 101 7.9.2.1 Emergency light, none 1	Original	Violation Remarks: Ensure exit signage is v	visible :	from all	areas of	
	building.	•				
	10/26/2010 2012	NEDN 101 7 0 2 1 Emorgongy light none	1			
Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck			_			,

Page

2

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

20318 One Source Sample LLC.

950 Riverbend DR Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
re	equest.				
Or	riginal Violation Remarks: Ensure all areas are cov	vered by	emergency	lighting.	
10/26/2018	2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1			0
Notes: Re	check violation record auto-generated from ManageM	MyInspec	tions.com	recheck	
re	equest.				
Or	riginal Violation Remarks: Email a copy of the curr	ent ins	pection.		
10/26/2018	DFDFMO AHJ, Requirement	1			0
	echeck violation record auto-generated from ManageMequest.	MyInspec	tions.com	recheck	
Or	riginal Violation Remarks: Install Knox Box at the	guard s	hack for g	gate access.	
Total Indiv	ridual Violation Codes for Occupancy: 7				

30293 Petco

841 Shugart RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/15/2019	2011 NFPA 25 7.3.2 Fire hydrant, no annual	1		0
Notes: Un	known.			
	2012 IFC 605.5 Extension cord, Improper use nnot use temporary cords for permanent wiring.	1		0
	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access st have clear path to building cit	1		0

Total Individual Violation Codes for Occupancy: 3

40114 Pine Needle Gift Shoppe

1319 Dug Gap RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

40114 Pine Needle Gift Shoppe

> 1319 Dug Gap RD Dalton, GA 30720

Count Article Reported Code/Description Division Page 01/16/2019 * 2012 IFC 906.2 Fire extinguisher, Properly Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Have extinguishers inspected.

Total Individual Violation Codes for Occupancy: 1

30016 Preferred Cherokee Dalton 1506 Thornton (North) AVE

Dalton, GA 30720

Reported Code/Description Count Article Division Page 10/29/2018 * 2012 IFC 506.1 Knox Box, requirements 1 0

Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request.

Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Install Knox Box on building.

10/29/2018 2012 IFC 506.1 Knox Box, requirements

3

Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request.

Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Install key once box is installed.

Total Individual Violation Codes for Occupancy: 2

30212 PS Nails

785 Shugart RD

Dalton, GA 30720

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

Reported	Code/Description	Count	Article	Division	Page
03/14/2019	2011 NFPA 25 13.7.1 FDC, caps missing	1			0
Notes: Ad	d caps.				
03/14/2019	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1			0
Notes: Ha	ve inspection performed.				
03/14/2019	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: In	stall Knox Box on building. Order at				
ht	<pre>tps://www.knoxbox.com/store/selectProduct.cfm?fdID=</pre>	=7992.	It should	d be	
in	stalled near front door at a maximum height of 6 f ϵ	eet fro	m ground.	Make sure	
to	put the sticker on the door. Ensure proper key is	in pla	ce to acce	ess	
bu	ilding.Add Knox Box to building.				
03/14/2019	2012 IFC 509.1 Riser room not marked	1			0
Notes: Ma	rk riser room.				
03/14/2019	2012 IFC 912.2.1 FDC, location not signed	1			0
Notes: Ad	ld signage.				
03/14/2019	2012 IFC 912.2.1 / ORD 7L FDC, blocked/obstructed	1			0
Notes: Ra	ise FDC to appropriate height.				
03/14/2019	2013 NFPA 72 8.16.1.1.2.1 Sprinkler system,	1			0
Notes: Un	known, valves are underwater and not marked.				

Total Individual Violation Codes for Occupancy: 7

20015 PSG Functional Materials 2200 Abutment RD Dalton, GA 30720

Reported	Code/Description Count Article Division	Page
03/13/2019	2012 IFC 506.1 Knox Box, requirements 1	0
Notes: In	stall Knox Box on building. Order at	
ht	tps://www.knoxbox.com/store/selectProduct.cfm?fdID=7992. It should be	
in	stalled near front door at a maximum height of 6 feet from ground. Make sure	
to	put the sticker on the door. Ensure proper key is in place to access	
bu	ilding.	
03/13/2019	2012 IFC 605.1 Electrical panel, abatement of 1	0
Notes: Re	place wiring as discussed.	

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

20015 PSG Functional Materials

2200 Abutment RD Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
03/13/2019	2012 IFC 605.6 Electrical panel, cover not	1			0
Notes: In	stall missing covers on junction boxes.				
03/13/2019	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access	1			0
Notes: Re	move trip hazards from egress path as discussed.				
03/13/2019	2012 NFPA 101 7.2.1.5.1 Exit, while building	1			0
Notes: Re	move slide lock from exit door as discussed.				
03/13/2019	2012 NFPA 101 7.9.2.1 Emergency light, none	1			0
Notes: Ad	ditional emergency lights are needed. Test all eme	ergency	lights m	onthly.	
03/13/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional	1			0
Notes: Re	place or repair exit signage. Check exit signage o	on a mo	nthly bas	is.	
03/13/2019	2013 NFPA 10 7.3.2.1 Extinguisher damaged/6yr	1			0
	ve the CO fire extinguisher to a place where debri	will n	ot build	up on it,	
an	d remove debri from it.				

Total Individual Violation Codes for Occupancy: 8

40118 Pulmanary & Sleep Medicine 1420 Mineral Springs RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/21/2019	*2012 IFC 506.1 Knox Box, requirements	1		0
O: w d tl	echeck violation record automatically created friginal Violation Remarks: Install Knox Box on know.knoxbox.com select Dalton Fire Department. Soor at a maximum height of 6 feet from ground. the door. Ensure proper key is in place to accessuilding.	ouilding. Order at Should be installed Make sure to put th	near front ne sticker on	
Notes: R	*2012 NFPA101 7.10.5.1 Exit sign, non function echeck violation record automatically created friginal Violation Remarks: Repair or replace exi	rom a recheck reques	st.	0

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

40118 Pulmanary & Sleep Medicine

1420 Mineral Springs RD

Dalton, GA 30720

Code/Description Count Article Division Reported Page

Total Individual Violation Codes for Occupancy: 2

40082 Red Lobster

> 901 West Bridge RD Dalton, GA 30720

Reported Code/Description Count Article Division Page

01/24/2019 2012 IFC 506.1 Knox Box, requirements

Notes: Recheck violation record automatically created from a recheck request.

Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box on building.

Total Individual Violation Codes for Occupancy: 1

40065 Reflexology

1323 Walnut (West) AVE

Suite 1

Dalton, GA 30720

Reported Code/Description Count Article Division Page

01/08/2019 * 2012 IFC 605.3 Electrical panel, obstructed

Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck

request.

Original Violation Remarks: Remove combustibles around electrical panel.

Total Individual Violation Codes for Occupancy: 1

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

20771 Salon Garibaldi

1309 Morris (East) ST Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/23/2019	*2012 NFPA 101 7.2.1.7.1 Exit, panic hardware	1		0
Notes: Re	check violation record auto-generated from inspec	ction on 01/23/2019).	
In	stall panic hardware on secondary exit.			

Total Individual Violation Codes for Occupancy: 1

40186 Schlotzsky's

1325 Walnut (West) AVE Dalton, GA 30720

Reported Cod	de/Description	Count Article	Division	Page
02/04/2019 * 201	.1 NFPA 96 10.9.1 Kitchen hood suppression	1		0
Notes: Rechec	k violation record automatically created from a	a recheck reques	st.	
Origin	al Violation Remarks: Inspection past due.			
02/04/2019 * 201	.2 IFC 506.1 Knox Box, requirements	1		0
Notes: Rechec	k violation record automatically created from a	a recheck reques	st.	
Origin	al Violation Remarks: Install Knox Box on build	ding. Order at		
www.kn	oxbox.com select Dalton Fire Department. Shoul	ld be installed	near front	
	t a maximum height of 6 feet from ground. Make	_		
	or. Ensure proper key is in place to access bui	ilding.Add Knox	Box to	
buildi	ng.			
02/04/2019 * 201	.2 NFPA 101 7.9.3.1.1 Emergency light,	1		0
Notes: Rechec	k violation record automatically created from a	a recheck reques	st.	
Origin	al Violation Remarks: Repair or replace emerger	ncy lights.		
02/04/2019 * 201	3 NFPA 10 6.6.1 Class K fire extinguisher	1		0
Notes: Rechec	k violation record automatically created from a	a recheck reques	st.	
Origin	al Violation Remarks: Add Class K extinguisher	to kitchen.		
02/04/2019 * 201	3 NFPA 96 10.2.2 Class K placard required	1		0
Notes: Rechec	k violation record automatically created from a	a recheck reques	st.	
Origin	al Violation Remarks: See Annex A NFPA 10Add co	orrect placard a	at time of	
additi	on of Class K extinguisher.			

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

40186 Schlotzsky's

1325 Walnut (West) AVE

Dalton, GA 30720

Reported Code/Description Count Article Division Page

Total Individual Violation Codes for Occupancy: 5

30215 Seasons Hibachi & Sushi

785 Shugart RD

9

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/14/2019	2011 NFPA 25 13.7.1 FDC, caps missing	1		0
Notes: Ad	d caps			
03/14/2019	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1		0
Notes: Ha	ve system inspected.			
03/14/2019	2012 IFC 506.1 Knox Box, requirements	1		0
Notes: In	stall Knox Box on building. Order at			
ht	tps://www.knoxbox.com/store/selectProduct.cfm?fdID	=7992. It shoul	ld be	
	stalled near front door at a maximum height of 6 f			
	_	_		
	put the sticker on the door. Ensure proper key is	in place to acc	cess	
bu	ilding.Add Knox Box to building.			
03/14/2019	2012 IFC 509.1 Riser room not marked	1		0
Notes: Ma	rk riser room.			
03/14/2019	2012 IFC 605.3 Electrical panel, obstructed	1		0
Notes: Mo	ve storage from in front of panels.			
03/14/2019	2012 IFC 912.2.1 FDC, location not signed	1		0
Notes: Ad	ld signage.			
03/14/2019	2012 IFC 912.2.1 / ORD 7L FDC, blocked/obstructed	l 1		0
Notes: Ra	ise FDC to appropriate height.			
03/14/2019	2013 NFPA 72 8.16.1.1.2.1 Sprinkler system,	1		0
Notes: Un	known, under water and not marked.			

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

30215 Seasons Hibachi & Sushi

785 Shugart RD

Dalton, GA 30720

Reported Code/Description Count Article Division Page

Total Individual Violation Codes for Occupancy: 8

20101 Servicios Latinos

908 Elk ST

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
09/24/2018	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1		C
	check violation record auto-generated from ManageN quest.	MyInspections.co	m recheck	
	iginal Violation Remarks: Last inspection shows 20 spection.	015, should have	a annual	
09/24/2018	2012 IFC 505.1 Address, no suite	1		C
re	check violation record auto-generated from Manage Quest. iginal Violation Remarks: Add address signage.	MyInspections.co	m recheck	
09/24/2018	2012 IFC 506.1 Knox Box, requirements	1		0
	check violation record auto-generated from ManageNquest.	MyInspections.co	m recheck	
	iginal Violation Remarks: Install Knox Box on builwww.knoxbox.com select Dalton Fire Department. Show	_		
	or at a maximum height of 6 feet from ground. Make door.Add Knox Box to building. Order at www.kno			ı
Dei	partment.			

0

1

Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck

Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Install key once Box is in.

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

20101 Servicios Latinos 908 Elk ST Dalton, GA 30720

* Denotes Violations Corrected or Variance Issued

04/09/2019 06:56

Reported	Code/Description	Count Article	Division	Page
09/24/2018	2012 IFC 509.1 Riser room not marked	1		C
	echeck violation record auto-generated from Mar	nageMyInspections.com	recheck	
	equest.			
Or	riginal Violation Remarks: Mark riser room.			
09/24/2018	2012 IFC 605.1 Electrical panel, abatement o	f 1		0
Notes: Re	echeck violation record auto-generated from Mar	nageMyInspections.com	recheck	
	equest.			
Or	riginal Violation Remarks: Remove exposed wiring	ng.		
09/24/2018	2012 IFC 605.5 Extension cord, Improper use	1		0
Notes: Re	echeck violation record auto-generated from Man	nageMyInspections.com	recheck	
	equest.			
	riginal Violation Remarks: Extension cords show	uld only be used for	temporary	
po	ower.			
09/24/2018	2012 IFC 605.6 Electrical panel, cover not	1		0
Notes: Re	echeck violation record auto-generated from Mar	nageMyInspections.com	recheck	
	equest.			
Or	riginal Violation Remarks: Replace junction box	x covers.		
09/24/2018	2012 IFC 906.1 Fire extinguisher, none in	1		0
Notes: Re	echeck violation record auto-generated from Man	nageMyInspections.com	recheck	
	equest.			
Or	riginal Violation Remarks: Extinguisher needed	in church area.		
09/24/2018	2012 IFC 906.2 Fire extinguisher, Properly	1		0
Notes: Re	echeck violation record auto-generated from Man	nageMyInspections.com	recheck	
	equest.			
	riginal Violation Remarks: Have fire extinguish	hers serviced by a St	ate licensed	i.
CC	ontractor.			
09/24/2018	2012 IFC 906.3 Fire extinguisher, incorrect	1		0
Notes: Re	echeck violation record auto-generated from Mar	nageMyInspections.com	recheck	
	equest.			
Or	riginal Violation Remarks: Additional fire ext	inguishers needed.		
09/24/2018	2012 IFC 912.2.1 FDC, location not signed	1		0
Notes: Re	echeck violation record auto-generated from Mar	nageMyInspections.com	recheck	
re	equest.			

Page

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

20101 Servicios Latinos 908 Elk ST Dalton, GA 30720

* Denotes Violations Corrected or Variance Issued

04/09/2019 06:56

Reported	Code/Description	Count Article	Division	Page
0:	riginal Violation Remarks: Add FDC signage.			
09/24/2018	2012 NFPA 101 7.4.1.2 Exit, number required	1		0
Notes: Re	echeck violation record auto-generated from ManageM	MyInspections.com	recheck	
	equest.			
0:	riginal Violation Remarks: Area used for church req	quires additional	exit.	
09/24/2018	2012 NFPA 101 7.3.4.1 (2 MOE, widths	1		0
Notes: Re	echeck violation record auto-generated from $ exttt{ManageM}$	MyInspections.com	recheck	
	equest.			
0:	riginal Violation Remarks: Multiple exits needed.			
09/24/2018	2012 NFPA 101 7.2.1.4.2 Exit, door swing	1		0
Notes: Re	echeck violation record auto-generated from $ exttt{ManageM}$	MyInspections.com	recheck	
	equest.			
O:	riginal Violation Remarks: Exit doors from sanctuar	ry should swing or	ut.	
09/24/2018	2012 NFPA 101 7.2.2.2.1 MOE, stairs (existing)	1		0
	echeck violation record auto-generated from ManageM	MyInspections.com	recheck	
	equest.			
O:	riginal Violation Remarks: Stairs will be approved	once completed.		
09/24/2018	2012 NFPA 101 7.2.2.4.4 MOE, handrails	1		0
	echeck violation record auto-generated from ManageM	MyInspections.com	recheck	
	equest. riginal Violation Remarks: Same as above.			
0.	riginal violation kemarks. Same as above.			
09/24/2018	, 5	1		0
	echeck violation record auto-generated from ManageM	MyInspections.com	recheck	
	equest. riginal Violation Remarks: Same as above.			
0.	riginal violation kemarks. Same as above.			
09/24/2018	·	1		0
	echeck violation record auto-generated from ManageM	MyInspections.com	recheck	
	equest. riginal Violation Remarks: Additional exits needed.			
0.	riginal violation kemarks. Additional exits needed.			
09/24/2018	·	1		0
	echeck violation record auto-generated from ManageM	MyInspections.com	recheck	
	equest. riginal Violation Remarks: Additional exits needed.			
0.				

Page

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

20101 Servicios Latinos 908 Elk ST Dalton, GA 30720

* Denotes Violations Corrected or Variance Issued

04/09/2019 06:56

Reported	Code/Description	Count	Article	Division	Page
09/24/2018	2012 NFPA 101 7.9.2.1 Emergency light, none	1			0
	echeck violation record auto-generated from Manage equest.	MyInspec	tions.co	m recheck	
Or	riginal Violation Remarks: Need emergency lighting	through	out.		
09/24/2018	2012 NFPA 101 9.6.1.1 Fire alarm , not installed	l 1			0
	echeck violation record auto-generated from Manage equest.	MyInspec	tions.co	m recheck	
	riginal Violation Remarks: Additional devices need onstruction.	ed upon	approval	of new	
09/24/2018	2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1			0
	echeck violation record auto-generated from Manage equest.	MyInspec	tions.co	m recheck	
	riginal Violation Remarks: Fire alarm showing superodated inspection report.	rvisory	alarm.	Need to see	
09/24/2018	2012 NFPA 101 9.7.1.1 Sprinkler system, no	1			0
re	echeck violation record auto-generated from Manage equest.				
Or	riginal Violation Remarks: Multiple areas througho	ut not p	roperly	sprinkled.	
09/24/2018	5 .	1			0
re	echeck violation record auto-generated from Manage		tions.co	m recheck	
Or	riginal Violation Remarks: Need exit signage throu	gnout.			
09/24/2018	± ' '				0
re	echeck violation record auto-generated from Manage	MyInspec	tions.com	m recheck	
Or	riginal Violation Remarks: System in supervisory.				
09/24/2018 Notes: Re	2013 NFPA 72 17.14.8.2 Fire alarm, pull station echeck violation record auto-generated from Manage	1 MyInspec		m recheck	0
Or	equest. riginal Violation Remarks: Additional devices need onstruction.	ed upon	approval	of new	
09/24/2018 Notes:Re	2013 NFPA 72 18.5.2.2 Horn/strobe obstructed echeck violation record auto-generated from Manage	1 MyInspec		m recheck	0

Page

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

20101 Servicios Latinos

908 Elk ST

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
r	equest.			
0:	riginal Violation Remarks: Same as above.			
09/24/2018	2013 NFPA 72 18.5.5.4.2 Horns/strobe not	1		(
	echeck violation record auto-generated from Manago	eMyInspections.com	recheck	
0:	riginal Violation Remarks: Will test once project	is complete.		
09/24/2018	2013 NFPA 72 8.16.1.1.2.1 Sprinkler system,	1		(
r	echeck violation record auto-generated from Manago equest. riginal Violation Remarks: Control valves not acco	-	recheck	
09/24/2018	DFDFMO AHJ, Requirement	1		(
	echeck violation record auto-generated from Manago	eMyInspections.com	recheck	
	riginal Violation Remarks: Sprinkler heads coated ffected heads.	with overspray.	Replace all	
u: ac C:	tems were seen in the assembly area in which the osed. The owner advised he had used the space for dvised that this space was not to be occupied at a corrections were made and approved. The owner was f the space prior to approval will result in the pace.	a few events. Th any time until pro advised that any	e owner was per future use	:
09/24/2018	ORD 54-1 Fire hydrant, City ordinance	1		(
Notes: R	echeck violation record auto-generated from Manage	eMyInspections.com	recheck	
	equest.			
O:	riginal Violation Remarks: No exit signage.			
Total Indi	vidual Violation Codes for Occupancy: 32			

40062 Shoney's

1302 Walnut (West) AVE

Dalton, GA 30720

Reported Code/Description Count Article Division Page

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40062 Shoney's

1302 Walnut (West) AVE Dalton, GA 30720

* Denotes Violations Corrected or Variance Issued

04/09/2019 06:56

Reported	Code/Description	Count	Article	Division	Page
Notes: Re re Or	*2011 NFPA 96 11.7.1 Cooking equipment, In proper echeck violation record auto-generated from ManageMy equest. riginal Violation Remarks: on't over fill deep fryers.	1 yInspec		recheck	0
Notes:Re re Or	*2011 NFPA 96 11.7.2 Cooking equipment, echeck violation record auto-generated from ManageMy equest. riginal Violation Remarks: Lean around cooking equipment on a regular basis.	1 yInspec		recheck	0
Notes:Re re Or	*2011 NFPA 96 6.2.3.3 Kitchen hood, grease echeck violation record auto-generated from ManageMy equest. riginal Violation Remarks: Lean grease filters daily.	1 yInspec		recheck	0
re Or ww do th	2012 IFC 506.1 Knox Box, requirements echeck violation record auto-generated from ManageMy equest. riginal Violation Remarks: Install Knox Box on build www.knoxbox.com select Dalton Fire Department. Show our at a maximum height of 6 feet from ground. Make the door. Ensure proper key is in place to access but astall Knox Box on building.	ding. ld be i	tions.com Order at nstalled a	near front	0
re Or Er	2012 IMC 507.12 Cooking equipment, Proper echeck violation record auto-generated from ManageMy equest. riginal Violation Remarks: nsure cooking equipment is at least 6 inches inside yens should be installed under a proper hood.			recheck	0
re Or	2012 NFPA 101 7.9.3.1.1 Emergency light, echeck violation record auto-generated from ManageMy equest. riginal Violation Remarks: epair or replace emergency light.	1 yInspec		recheck	0

Page

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

40062 Shoney's

1302 Walnut (West) AVE

Dalton, GA 30720

Code/Description Count Article Reported Division Page

Total Individual Violation Codes for Occupancy: 6

40115 Simply Delightful Consignment

> 1407 Dug Gap RD Dalton, GA 30720

Code/Description Count Article Division Reported Page 01/16/2019 * 2012 IFC 906.2 Fire extinguisher, Properly 0 Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck

Original Violation Remarks: Need to add extinguishers.

01/16/2019 * DFDFMO AHJ, Requirement

0

1

Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck

Original Violation Remarks: Add exit signage.

Total Individual Violation Codes for Occupancy: 2

40168 Sport Clips

1323 Walnut (West) AVE

Suite 4

Dalton, GA 30720

Reported	Code/Description	Count Article	Division Page
02/04/2019	*2012 IFC 506.1 Knox Box, requirements	1	0

Notes: Recheck violation record automatically created from a recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. No key in Knox Box.

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

40168 Sport Clips

1323 Walnut (West) AVE

Suite 4

Dalton, GA 30720

Reported Code/Description Count Article Division Page

Total Individual Violation Codes for Occupancy: 1

40044 SPRINT PCS

1333 Walnut (West) AVE

Dalton, GA 30720

Reported Code/Description Count Article Division Page
01/08/2019 2012 NFPA101 7.10.5.1 Exit sign, non functional 1 0
Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request.
Original Violation Remarks: Repair or replace exit signage.

Total Individual Violation Codes for Occupancy: 1

40038 Stadium BBQ

1001 Market ST

Suite 14

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/04/2019	DFDFMO AHJ, Requirement	1		0

Notes: The following is a list of issues found during the sight inspection brought on by a complaint.

Kitchen hood exhuast fan not working. This shall be corrected by 3/5/19.

Open flame cooking device not properly separated from the deep fryers.

Kitchen hood needs to be resealed.

Reseal stainless sheeting behind cooking equipment.

Cooking equipment should be at least 6 inches inside of the hood.

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

40038 Stadium BBO

1001 Market ST

Suite 14

Dalton, GA 30720

Reported Code/Description Count Article Division Page

Electrical outlets should be covered properly.

Extension cords being used as permanent power sources should be removed immediately, and electrical issues corrected.

03/18/2019 DFDFMO AHJ, Requirement

1

Notes: Recheck violation record automatically created from a recheck request.

Original Violation Remarks: Repairs to the electrical system are in progress.

Hood system is scheduled to be done by Wednesday. The owner Gary Woods was advised via phone that all work must be completed by Wednesday March 20th.

The work required on the hood system was not completed, and the owner Gary Woods was advised that the business is to stay closed until repairs are made.

03/18/2019 DFDFMO AHJ, Requirement

0

Λ

Notes: Repairs to the electrical system are in progress. Hood system is scheduled to be done by Wednesday. The owner Gary Woods was advised via phone that all work must be completed by Wednesday March 20th.

Total Individual Violation Codes for Occupancy: 3

40036 Stadium BBQ Pool

1001 Market ST

Suite 13

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/04/2019	DFDFMO AHJ, Requirement	1		0

Notes: Issues found during a site visit include the following.

Emergency lights not working.

Drop cords used as permanent wiring should be removed immediatly.

Exitnguishers need to be serviced.

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

40036 Stadium BBQ Pool

1001 Market ST

Suite 13

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
	Remove items in egress path.			

Total Individual Violation Codes for Occupancy: 1

10201 The Paper Princess

238 Hamilton (North) ST

Suite 2

Dalton, GA 30720

NFPA 25 4.3.6.1 Sprinkler system, Annual crinkler system serviced. 2 IFC 605.5 Extension cord, Improper use	1		0
2 IFC 605.5 Extension cord, Improper use	1		
	1		
diam monda and considerable from the continue			0
drop cords are unplugged from the outlet when only be used for temporary power.	not in use.	Drop cords	
2 IFC 906.2 Fire extinguisher, Properly	1		0
tinguishers need to be tagged by a GA licensed tor.	d fire extir	nguisher	
2 IFC 912.2.1 FDC, location not signed Signage.	1		0
2 NFPA101 7.10.5.1 Exit sign, non functional	1		0
all exit signage is working properly.			
FMO AHJ, Requirement	1		0
	pied space w	hich has exposed	i
	2 IFC 906.2 Fire extinguisher, Properly stinguishers need to be tagged by a GA licensed tor. 2 IFC 912.2.1 FDC, location not signed Signage. 2 NFPA101 7.10.5.1 Exit sign, non functional all exit signage is working properly. FMO AHJ, Requirement	2 IFC 906.2 Fire extinguisher, Properly 1 2 tinguishers need to be tagged by a GA licensed fire extinguisher. 2 IFC 912.2.1 FDC, location not signed 1 2 Signage. 2 NFPA101 7.10.5.1 Exit sign, non functional 1 3 all exit signage is working properly. 5 FMO AHJ, Requirement 1 5 tracade to keep customers from entering unoccupied space were	2 IFC 906.2 Fire extinguisher, Properly 1 2 tinguishers need to be tagged by a GA licensed fire extinguisher stor. 2 IFC 912.2.1 FDC, location not signed 1 2 Signage. 2 NFPA101 7.10.5.1 Exit sign, non functional 1 3 all exit signage is working properly. 5 FMO AHJ, Requirement 1 5 tracade to keep customers from entering unoccupied space which has exposed

Total Individual Violation Codes for Occupancy: 6

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40084 Thompson Energy 745 College DR A

Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/29/2019	2012 IFC 506.1 Knox Box, requirements	1		0
Notes: Re	check violation record automatically created fro	om a recheck reques	st.	
Or	iginal Violation Remarks: Install Knox Box on bu	ilding. Order at		
ww	w.knoxbox.com select Dalton Fire Department. Sh	ould be installed	near front	
do	or at a maximum height of 6 feet from ground. M	Make sure to put th	ne sticker on	
th	e door. Ensure proper key is in place to access	building.Install a	Knox Box on	
th	e building.			
01/29/2019	2012 IFC 906.2 Fire extinguisher, Properly	1		0
	check violation record automatically created fro	om a recheck reques	st.	
	iginal Violation Remarks: Fire extinguishers sho	_		
01/29/2019	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit acce	ess 1		0
Notes: Re	check violation record automatically created fro	om a recheck reques	st.	
Or	iginal Violation Remarks: Remove items blocking	the exit door.		
St	orage is not allowed in exit stairwells.			
01/29/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional	l 1		0
Notes: Re	check violation record automatically created fro	om a recheck reques	st.	
Or	iginal Violation Remarks: Repair or replace exit	signage.		
Total India	idual Violation Codes for Occupancy: 4			
TOTAL INGIV	idual violation codes for occupancy: 4			

40112 Timothy Q. Rushing, D.M.D.
1400 Dug Gap RD
Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/21/2019	*2012 IFC 906.2 Fire extinguisher, Properly	1		0
	Recheck violation record automatically created fro Original Violation Remarks: Must have extinguisher	-		

Total Individual Violation Codes for Occupancy: 1

^{*} Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

40167 TJ Maxx

1327 Walnut (West) AVE Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/04/2019	*2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1	-		0
Notes: Re	echeck violation record automatically created fro	om a reche	ck reques	t.	
Oı	riginal Violation Remarks: Have sprinkler system	inspectio	n perform	ed by a GA	
13	icensed contractor.				
02/04/2019	*2013 NFPA 72 17.14.8.2 Fire alarm, pull statio	n 1			0
Notes: Re	echeck violation record automatically created from	om a reche	ck reques	t.	
O	riginal Violation Remarks: Do not block pull stat	cions.			

Total Individual Violation Codes for Occupancy: 2

40047 Tobacco Outlet

1339 Walnut (West) AVE Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
01/08/2019	2012 IFC 506.1 Knox Box, requirements	1		0
Notes: Re	check violation record auto-generated from Mana	geMyInspections.com	recheck	
re	equest.			
Or	riginal Violation Remarks: Install Knox Box on b	uilding. Order at		
WW	w.knoxbox.com select Dalton Fire Department. Si	hould be installed m	near front	
do	or at a maximum height of 6 feet from ground.	Make sure to put the	e sticker on	
th	ne door. Ensure proper key is in place to access	building.Install Kr	nox Box on	
bu	ilding.			
01/08/2019	*2012 IFC 605.3 Electrical panel, obstructed	1		0
Notes: Re	check violation record auto-generated from Mana	geMyInspections.com	recheck	
re	equest.			
Or	riginal Violation Remarks: Remove combustibles a	round electrical par	nel.	

Total Individual Violation Codes for Occupancy: 2

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between {03/01/2019} And {03/31/2019}

30297 Verizon

> 853 Shugart RD Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
03/15/2019	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: In	stall Knox Box on building. Order at				
ht	<pre>tps://www.knoxbox.com/store/selectProduct.cfm?fd</pre>	ID=7992.	It should	d be	
in	stalled near front door at a maximum height of 6	feet fro	m ground.	Make sure	
to	put the sticker on the door. Ensure proper key	is in pla	ce to acce	ess	
bu	ilding.Replace key.				
03/15/2019	2012 IFC 906.1 Fire extinguisher, none in	1			0
Notes: Ad	d extinguisher.				
03/15/2019	DFDFMO AHJ, Requirement	1			0
Notes: Un	known sprinkler system status.				

Total Individual Violation Codes for Occupancy: 3

40163 Verizon Wireless

1516 Walnut (West) AVE

Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/06/2019	*2012 IFC 506.1 Knox Box, requirements	1			0
Notes: Re	echeck violation record automatically created from	a reche	ck request	.	
O	riginal Violation Remarks: Install Knox Box on build	ding.	Order at		
WV	ww.knoxbox.com select Dalton Fire Department. Shou	ld be i	nstalled r	near front	
do	oor at a maximum height of 6 feet from ground. Mak	e sure	to put the	e sticker or	ı
tl	ne door. Ensure proper key is in place to access bu	ilding.	Add Knox E	Box to	

Total Individual Violation Codes for Occupancy: 1

30222 Village Podiatry

building.

1505 Professional CT

Dalton, GA 30720

	Reported	Code/Description	Count Article	Division	Page
--	----------	------------------	---------------	----------	------

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30222 Village Podiatry 1505 Professional CT

Dalton, GA 30720

Reported Code/Description Count Article Division Page 02/05/2019 *2012 IFC 906.3 Fire extinguisher, incorrect 1 0 Notes: Recheck violation record automatically created from a recheck request.

Original Violation Remarks: Install fire extinguisher throughout building. Fire extinguishers must be tagged by a GA licensed contractor.

Total Individual Violation Codes for Occupancy: 1

30252 Waffle House

1912 Chattanooga RD Dalton, GA 30720

Reported	Code/Description	Count Articl	e Division	Page
02/20/2019	*2011 NFPA 96 10.9.1 Kitchen hood suppression	1		0
Notes: Re	echeck violation record automatically created from a	a recheck requ	est.	
Or	riginal Violation Remarks: Out of date.			
02/20/2019	*2011 NFPA 96 11.4 Kitchen hood,	1		0
	echeck violation record automatically created from a riginal Violation Remarks: No paperwork available.	a recheck requ	est.	
02/20/2019	*2012 IFC 906.2 Fire extinguisher, Properly	1		0
Notes: Re	echeck violation record automatically created from a	a recheck requ	est.	
Or	riginal Violation Remarks: Out of date.			
02/20/2019	* DFDFMO AHJ, Requirement	1		0
Notes: Re	echeck violation record automatically created from a	a recheck requ	est.	
Or	riginal Violation Remarks: Class K needs to be inspe	ected		

Total Individual Violation Codes for Occupancy: 4

30205 Wal-Mart

815 Shugart RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
----------	------------------	---------------	----------	------

* Denotes Violations Corrected or Variance Issued

Monthly Prevention Violations by Occupancy

Inspection Date Completed Between $\{03/01/2019\}$ And $\{03/31/2019\}$

30205 Wal-Mart

815 Shugart RD Dalton, GA 30720

Reported	Code/Description	Count Article	Division	Page
03/19/2019	2012 IFC 509.1 Riser room not marked	1		0
Notes: Add	d signage for riser room. In lawn and garden area.			
03/19/2019	2012 IFC 605.6 Electrical panel, cover not	1		0
Notes: Re	place cover			

Total Individual Violation Codes for Occupancy: 2

Grand Total Violations: 295