

DALTON

Incident Type Report (Monthly Summary)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident Type	Count	Pct of Incidents	Total Est Loss	Pct of Losses
1 Fire				
111 Building fire	3	0.88%	\$15,100	31.07%
113 Cooking fire, confined to container	2	0.59%	\$500	1.02%
131 Passenger vehicle fire	2	0.59%	\$5,000	10.28%
132 Road freight or transport vehicle fire	1	0.29%	\$26,000	53.49%
137 Camper or recreational vehicle (RV) fire	1	0.29%	\$2,000	4.11%
140 Natural vegetation fire, Other	1	0.29%	\$0	0.00%
143 Grass fire	1	0.29%	\$0	0.00%
151 Outside rubbish, trash or waste fire	1	0.29%	\$0	0.00%
	12	3.55%	\$48,600	100.00%
2 Overpressure Rupture, Explosion, Overheat(no fire)				
251 Excessive heat, scorch burns with no	1	0.29%	\$0	0.00%
	1	0.29%	\$0	0.00%
3 Rescue & Emergency Medical Service Incident				
311 Medical assist, assist EMS crew	187	55.32%	\$0	0.00%
322 Motor vehicle accident with injuries	8	2.36%	\$0	0.00%
324 Motor Vehicle Accident with no injuries	9	2.66%	\$0	0.00%
352 Extrication of victim(s) from vehicle	1	0.29%	\$0	0.00%
	205	60.65%	\$0	0.00%
4 Hazardous Condition (No Fire)				
411 Gasoline or other flammable liquid spill	2	0.59%	\$0	0.00%
412 Gas leak (natural gas or LPG)	1	0.29%	\$0	0.00%
413 Oil or other combustible liquid spill	1	0.29%	\$0	0.00%
421 Chemical hazard (no spill or leak)	1	0.29%	\$0	0.00%
441 Heat from short circuit (wiring),	1	0.29%	\$0	0.00%
444 Power line down	3	0.88%	\$0	0.00%
445 Arcing, shorted electrical equipment	4	1.18%	\$0	0.00%
461 Building or structure weakened or collapsed	1	0.29%	\$0	0.00%
463 Vehicle accident, general cleanup	1	0.29%	\$0	0.00%
	15	4.43%	\$0	0.00%
5 Service Call				
510 Person in distress, Other	1	0.29%	\$0	0.00%
551 Assist police or other governmental agency	2	0.59%	\$0	0.00%
552 Police matter	1	0.29%	\$0	0.00%

DALTON

Incident Type Report (Monthly Summary)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident Type	Count	Pct of Incidents	Total Est Loss	Pct of Losses
5 Service Call				
553 Public service	2	0.59%	\$0	0.00%
555 Defective elevator, no occupants	1	0.29%	\$0	0.00%
	7	2.07%	\$0	0.00%
6 Good Intent Call				
611 Dispatched & cancelled en route	38	11.24%	\$0	0.00%
622 No Incident found on arrival at dispatch	3	0.88%	\$0	0.00%
631 Authorized controlled burning	1	0.29%	\$0	0.00%
651 Smoke scare, odor of smoke	5	1.47%	\$0	0.00%
671 HazMat release investigation w/no HazMat	1	0.29%	\$0	0.00%
	48	14.20%	\$0	0.00%
7 False Alarm & False Call				
715 Local alarm system, malicious false alarm	2	0.59%	\$0	0.00%
733 Smoke detector activation due to	1	0.29%	\$0	0.00%
735 Alarm system sounded due to malfunction	5	1.47%	\$0	0.00%
736 CO detector activation due to malfunction	1	0.29%	\$0	0.00%
742 Extinguishing system activation	1	0.29%	\$0	0.00%
743 Smoke detector activation, no fire -	18	5.32%	\$0	0.00%
744 Detector activation, no fire -	4	1.18%	\$0	0.00%
745 Alarm system activation, no fire -	16	4.73%	\$0	0.00%
746 Carbon monoxide detector activation, no CO	2	0.59%	\$0	0.00%
	50	14.79%	\$0	0.00%

Total Incident Count: 338

Total Est Loss:

\$48,600

DALTON

Incident Type Period Comparisons

Alarm Date Between {11/01/2018} and {11/30/2018}

Incident Type	11/01/2018	11/01/2017	11/01/2016	11/01/2015
	to	to	to	to
	11/30/2018	11/30/2017	11/30/2016	11/30/2015
111 Building fire	3	5	8	3
113 Cooking fire, confined to container	2	1	0	1
131 Passenger vehicle fire	2	1	5	1
132 Road freight or transport vehicle fire	1	0	0	0
137 Camper or recreational vehicle (RV) fire	1	0	0	0
140 Natural vegetation fire, Other	1	0	0	0
141 Forest, woods or wildland fire	0	1	5	1
142 Brush or brush-and-grass mixture fire	0	2	6	1
143 Grass fire	1	0	0	0
150 Outside rubbish fire, Other	0	0	1	0
151 Outside rubbish, trash or waste fire	1	2	3	1
154 Dumpster or other outside trash receptacle fire	0	0	1	0
162 Outside equipment fire	0	0	1	0
170 Cultivated vegetation, crop fire, Other	0	0	1	0
251 Excessive heat, scorch burns with no ignition	1	0	1	2
311 Medical assist, assist EMS crew	187	183	180	119
322 Motor vehicle accident with injuries	8	1	7	10
323 Motor vehicle/pedestrian accident (MV Ped)	0	0	0	1
324 Motor Vehicle Accident with no injuries	9	1	7	9
351 Extrication of victim(s) from building/structure	0	0	1	0
352 Extrication of victim(s) from vehicle	1	0	0	1
357 Extrication of victim(s) from machinery	0	0	1	0
410 Combustible/flammable gas/liquid condition,	0	1	0	0
411 Gasoline or other flammable liquid spill	2	1	0	2
412 Gas leak (natural gas or LPG)	1	0	4	3
413 Oil or other combustible liquid spill	1	0	0	0
421 Chemical hazard (no spill or leak)	1	0	0	0

DALTON

Incident Type Period Comparisons

Alarm Date Between {11/01/2018} and {11/30/2018}

Incident Type	11/01/2018	11/01/2017	11/01/2016	11/01/2015
	to	to	to	to
	11/30/2018	11/30/2017	11/30/2016	11/30/2015
424 Carbon monoxide incident	0	0	1	1
441 Heat from short circuit (wiring), defective/worn	1	3	0	0
442 Overheated motor	0	0	0	1
443 Breakdown of light ballast	0	0	0	1
444 Power line down	3	0	1	3
445 Arcing, shorted electrical equipment	4	1	1	0
451 Biological hazard, confirmed or suspected	0	1	0	0
461 Building or structure weakened or collapsed	1	0	0	0
463 Vehicle accident, general cleanup	1	0	1	0
500 Service Call, other	0	1	0	0
510 Person in distress, Other	1	0	1	0
511 Lock-out	0	1	0	0
512 Ring or jewelry removal	0	1	0	0
531 Smoke or odor removal	0	1	1	2
542 Animal rescue	0	1	0	0
550 Public service assistance, Other	0	0	1	0
551 Assist police or other governmental agency	2	0	1	1
552 Police matter	1	0	0	0
553 Public service	2	7	2	3
555 Defective elevator, no occupants	1	0	0	0
561 Unauthorized burning	0	2	12	7
611 Dispatched & cancelled en route	38	27	19	16
622 No Incident found on arrival at dispatch address	3	5	14	5
631 Authorized controlled burning	1	0	1	0
651 Smoke scare, odor of smoke	5	3	8	2
652 Steam, vapor, fog or dust thought to be smoke	0	0	0	1
653 Smoke from barbecue, tar kettle	0	0	1	0

DALTON

Incident Type Period Comparisons

Alarm Date Between {11/01/2018} and {11/30/2018}

Incident Type	11/01/2018	11/01/2017	11/01/2016	11/01/2015
	to	to	to	to
	11/30/2018	11/30/2017	11/30/2016	11/30/2015
671 HazMat release investigation w/no HazMat	1	3	3	0
713 Telephone, malicious false alarm	0	0	1	0
715 Local alarm system, malicious false alarm	2	2	1	0
721 Bomb scare - no bomb	0	1	0	1
731 Sprinkler activation due to malfunction	0	1	1	0
732 Extinguishing system activation due to	0	1	0	0
733 Smoke detector activation due to malfunction	1	4	7	7
734 Heat detector activation due to malfunction	0	0	0	1
735 Alarm system sounded due to malfunction	5	4	0	2
736 CO detector activation due to malfunction	1	1	0	1
741 Sprinkler activation, no fire - unintentional	0	2	0	0
742 Extinguishing system activation	1	0	0	0
743 Smoke detector activation, no fire -	18	16	13	7
744 Detector activation, no fire - unintentional	4	3	3	4
745 Alarm system activation, no fire - unintentional	16	10	8	12
746 Carbon monoxide detector activation, no CO	2	0	0	0
Totals	<u>338</u>	<u>301</u>	<u>334</u>	<u>233</u>

DALTON

Dollar Value Saved & Loss Analysis (Monthly)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident Type	Count	Total Values	Total Losses	Total Saved	Percent Lost	Percent Saved
111 Building fire	2	\$578,500	\$15,100	\$563,400	2.61%	97.39%
113 Cooking fire, confined	1	\$151,000	\$500	\$150,500	0.33%	99.67%
131 Passenger vehicle fire	2	\$6,450	\$5,000	\$1,450	77.52%	22.48%
132 Road freight or	1	\$35,000	\$26,000	\$9,000	74.29%	25.71%
137 Camper or recreational	1	\$200,000	\$2,000	\$198,000	1.00%	99.00%
Grand Totals	7	\$970,950	\$48,600	\$922,350		

Total Percent Lost: 5.01 %

Total Percent Saved: 94.99 %

DALTON

Monthly Unit Response Time Analysis

Alarm Date Between {11/01/2018} And {11/30/2018}
and Response Code = "1 " (Emergency)

Response		Count	Percentage
Hrs	Mins		
<	01	14	3.5%
	01	62	15.7%
	02	83	21.1%
	03	116	29.5%
	04	69	17.5%
	05	23	5.8%
	06	16	4.0%
	07	4	1.0%
	08	4	1.0%
	09	1	0.2%
	10	1	0.2%

Overall Average Response Time: 00:03:25

DALTON

Monthly Unit Response Time Analysis

Alarm Date Between {11/01/2018} And {11/30/2018}
and Response Code = "2 " (Non-Emergency)

Response		Count	Percentage
Hrs	Mins		
<	01	7	9.8%
	01	6	8.4%
	02	5	7.0%
	03	11	15.4%
	04	14	19.7%
	05	11	15.4%
	06	9	12.6%
	07	3	4.2%
	08	2	2.8%
	10	2	2.8%
	14	1	1.4%

Overall Average Response Time: 00:04:26

**Dalton Fire Department
Medical Incident Study
EMS On scene/Not on scene Prior to DFD Comparison
11/1/18 –11/30/18**

Total incidents in time period – 213

EMS on-scene prior to DFD – 56

EMS not on-scene prior – 157

During the month of November, Dalton Fire Department arrived on-scene prior to Hamilton EMS on 74% of medical responses.

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003220	0	11/01/2018	01:41:08	404 Esther	311 Medical assist, assist EMS crew	
18-0003221	0	11/01/2018	09:05:54	610 Dantzler	311 Medical assist, assist EMS crew	
18-0003222	0	11/01/2018	11:14:18	1504 Anthony	611 Dispatched & cancelled en route	
18-0003223	0	11/01/2018	12:33:07	215 Matilda. (West)	311 Medical assist, assist EMS crew	
18-0003224	0	11/01/2018	15:35:19	1523 Morris (East)	745 Alarm system activation, no fire -	
18-0003225	0	11/01/2018	15:53:27	Chattanooga	611 Dispatched & cancelled en route	
18-0003226	0	11/01/2018	16:55:56	1130 Applewood	113 Cooking fire, confined to	\$500
18-0003227	0	11/01/2018	20:31:24	2225 Walnut (East)	611 Dispatched & cancelled en route	
18-0003228	0	11/01/2018	20:51:43	922 Stoneleigh	744 Detector activation, no fire -	
18-0003229	0	11/01/2018	22:41:37	I-75 S. Bound	622 No Incident found on arrival at	
18-0003230	0	11/02/2018	07:35:12	1105 Brookwood	311 Medical assist, assist EMS crew	
18-0003231	0	11/02/2018	07:36:29	710 Fifth	311 Medical assist, assist EMS crew	
18-0003232	0	11/02/2018	07:38:41	1320 Winton	743 Smoke detector activation, no fire	
18-0003233	0	11/02/2018	08:36:09	1018 Ponderosa	311 Medical assist, assist EMS crew	
18-0003234	0	11/02/2018	14:49:14	609 Thornton (South)	311 Medical assist, assist EMS crew	
18-0003235	0	11/02/2018	16:05:04	I-75 S. Bound	611 Dispatched & cancelled en route	
18-0003236	0	11/02/2018	18:23:50	744 Jackson	311 Medical assist, assist EMS crew	
18-0003237	0	11/03/2018	01:25:35	109 Edgewood	311 Medical assist, assist EMS crew	
18-0003238	0	11/03/2018	04:42:02	805 Professional	611 Dispatched & cancelled en route	
18-0003239	0	11/03/2018	08:24:50	2312 Morris (East)	311 Medical assist, assist EMS crew	
18-0003240	0	11/03/2018	08:31:51	Franklin (West)	445 Arcing, shorted electrical	
18-0003241	0	11/03/2018	09:38:42	Marble	444 Power line down	
18-0003242	0	11/03/2018	10:18:37	1404 Heather	311 Medical assist, assist EMS crew	
18-0003243	0	11/03/2018	10:42:26	1901 Wycliffe	611 Dispatched & cancelled en route	
18-0003244	0	11/03/2018	12:48:10	Thornton (South)	324 Motor Vehicle Accident with no	
18-0003245	0	11/03/2018	13:06:20	1955 Sourwood	311 Medical assist, assist EMS crew	
18-0003246	0	11/03/2018	13:17:40	900 Roan	743 Smoke detector activation, no fire	
18-0003247	0	11/03/2018	13:27:12	1102 Burleyson	733 Smoke detector activation due to	
18-0003248	0	11/03/2018	17:10:30	1115 Professional	311 Medical assist, assist EMS crew	
18-0003249	0	11/04/2018	01:37:33	933 Market	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003250	0	11/04/2018	03:51:42	1418 Burgess	311 Medical assist, assist EMS crew	
18-0003251	0	11/04/2018	06:59:47	MM I-75 S. Bound	324 Motor Vehicle Accident with no	
18-0003252	0	11/04/2018	08:52:58	408 Sixth	311 Medical assist, assist EMS crew	
18-0003253	0	11/04/2018	13:58:33	I-75 S. Bound	611 Dispatched & cancelled en route	
18-0003254	0	11/04/2018	15:31:14	620 Emmons	311 Medical assist, assist EMS crew	
18-0003255	0	11/04/2018	17:24:27	938 Market	311 Medical assist, assist EMS crew	
18-0003256	0	11/05/2018	06:42:47	Veterans	322 Motor vehicle accident with	
18-0003257	0	11/05/2018	10:34:19	602 Main	311 Medical assist, assist EMS crew	
18-0003258	0	11/05/2018	10:53:36	2305 Abutment	611 Dispatched & cancelled en route	
18-0003259	0	11/05/2018	11:51:52	604 Boundary (west)	311 Medical assist, assist EMS crew	
18-0003260	0	11/05/2018	13:04:50	1601 Mockingbird Hill	311 Medical assist, assist EMS crew	
18-0003261	0	11/05/2018	13:27:17	1644 Old Haig Mill	743 Smoke detector activation, no fire	
18-0003262	0	11/05/2018	14:41:18	1304 May	745 Alarm system activation, no fire -	
18-0003263	0	11/05/2018	14:47:52	201 Hamilton (South)	311 Medical assist, assist EMS crew	
18-0003264	0	11/05/2018	16:00:23	1325 Walnut (West)	745 Alarm system activation, no fire -	
18-0003265	0	11/05/2018	22:40:39	1501 Augusta	311 Medical assist, assist EMS crew	
18-0003266	0	11/05/2018	22:53:37	1102 Burleyson	742 Extinguishing system activation	
18-0003267	0	11/06/2018	07:03:18	1407 Thornton (North)	743 Smoke detector activation, no fire	
18-0003268	0	11/06/2018	08:19:07	1619 Beechland	445 Arcing, shorted electrical	
18-0003269	0	11/06/2018	10:45:41	715 Happy	743 Smoke detector activation, no fire	
18-0003270	0	11/06/2018	11:55:45	402 Sixth	311 Medical assist, assist EMS crew	
18-0003271	0	11/06/2018	13:14:17	2021 Shields	311 Medical assist, assist EMS crew	
18-0003272	0	11/06/2018	13:49:33	1306 Underwood	311 Medical assist, assist EMS crew	
18-0003273	0	11/06/2018	14:26:55	I-75 N. Bound	137 Camper or recreational vehicle	\$2,000
18-0003274	0	11/06/2018	16:15:16	Walnut (West)	322 Motor vehicle accident with	
18-0003275	0	11/06/2018	17:36:09	123 Fairway	311 Medical assist, assist EMS crew	
18-0003276	0	11/06/2018	20:09:07	907 Liddell	311 Medical assist, assist EMS crew	
18-0003277	0	11/07/2018	05:21:29	1116 Willowdale	311 Medical assist, assist EMS crew	
18-0003278	0	11/07/2018	09:24:30	1004 Richards	552 Police matter	
18-0003279	0	11/07/2018	09:25:57	1114 Professional	611 Dispatched & cancelled en route	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003280	0	11/07/2018	09:54:44	2121 Walnut (East)	611 Dispatched & cancelled en route	
18-0003281	0	11/07/2018	10:15:34	1002 Linden	311 Medical assist, assist EMS crew	
18-0003282	0	11/07/2018	11:22:25	1200 Memorial	611 Dispatched & cancelled en route	
18-0003283	0	11/07/2018	11:52:18	510 Tibbs (South)	611 Dispatched & cancelled en route	
18-0003284	0	11/07/2018	13:14:29	205 Selvidge St. (North)	311 Medical assist, assist EMS crew	
18-0003285	0	11/07/2018	13:33:34	136 Nickie	744 Detector activation, no fire -	
18-0003286	0	11/07/2018	16:38:13	1010 Lavert	311 Medical assist, assist EMS crew	
18-0003287	0	11/07/2018	18:38:12	1008 Alabama	311 Medical assist, assist EMS crew	
18-0003288	0	11/08/2018	00:58:52	807 Redwine	311 Medical assist, assist EMS crew	
18-0003289	0	11/08/2018	04:55:41	906 MLK Jr.	311 Medical assist, assist EMS crew	
18-0003290	0	11/08/2018	06:21:31	300 Waugh (West)	735 Alarm system sounded due to	
18-0003291	0	11/08/2018	07:44:24	136 Nickie	745 Alarm system activation, no fire -	
18-0003292	0	11/08/2018	08:40:20	416 Cedar	311 Medical assist, assist EMS crew	
18-0003293	0	11/08/2018	09:00:13	1896 Summit House	311 Medical assist, assist EMS crew	
18-0003294	0	11/08/2018	11:08:58	1250 Cross Plains	311 Medical assist, assist EMS crew	
18-0003295	0	11/08/2018	11:44:52	1320 Winton	743 Smoke detector activation, no fire	
18-0003296	0	11/08/2018	12:28:17	422 Sassafras	611 Dispatched & cancelled en route	
18-0003297	0	11/08/2018	12:40:08	233 Brickyard	611 Dispatched & cancelled en route	
18-0003298	0	11/08/2018	12:58:38	607 Greenwood	746 Carbon monoxide detector	
18-0003299	0	11/08/2018	14:16:01	2738 Underwood	311 Medical assist, assist EMS crew	
18-0003300	0	11/08/2018	15:02:29	1109 Burleyson	311 Medical assist, assist EMS crew	
18-0003301	0	11/08/2018	17:18:44	Veterans	131 Passenger vehicle fire	\$2,800
18-0003302	0	11/08/2018	22:08:30	1601 MLK Jr.	151 Outside rubbish, trash or waste	
18-0003303	0	11/08/2018	22:55:27	1222 MLK Jr.	311 Medical assist, assist EMS crew	
18-0003304	0	11/09/2018	04:56:07	1904 Tibbs	311 Medical assist, assist EMS crew	
18-0003305	0	11/09/2018	08:26:43	North Bypass	611 Dispatched & cancelled en route	
18-0003306	0	11/09/2018	09:01:48	I-75 N. Bound	611 Dispatched & cancelled en route	
18-0003307	0	11/09/2018	09:15:34	800 Red Clay	311 Medical assist, assist EMS crew	
18-0003308	0	11/09/2018	12:31:17	I-75 S. Bound	311 Medical assist, assist EMS crew	
18-0003309	0	11/09/2018	13:33:55	419 Fields	611 Dispatched & cancelled en route	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003310	0	11/09/2018	15:10:15	519 Hawthorne (West)	743 Smoke detector activation, no fire	
18-0003311	0	11/09/2018	15:52:47	415 Vann	311 Medical assist, assist EMS crew	
18-0003312	0	11/09/2018	16:13:55	1250 Walnut (West)	611 Dispatched & cancelled en route	
18-0003313	0	11/09/2018	16:27:50	North Bypass	324 Motor Vehicle Accident with no	
18-0003314	0	11/09/2018	16:30:22	607 Greenwood	746 Carbon monoxide detector	
18-0003315	0	11/09/2018	17:08:48	1000 Brown	311 Medical assist, assist EMS crew	
18-0003316	0	11/09/2018	18:02:27	607 Greenwood	736 CO detector activation due to	
18-0003317	0	11/09/2018	18:22:48	609 Thornton (South)	311 Medical assist, assist EMS crew	
18-0003318	0	11/09/2018	19:17:03	1306 Felice	311 Medical assist, assist EMS crew	
18-0003319	0	11/09/2018	19:21:18	2517 Underwood	311 Medical assist, assist EMS crew	
18-0003320	0	11/09/2018	19:40:03	817 Hamilton (South)	743 Smoke detector activation, no fire	
18-0003321	0	11/10/2018	01:16:16	2220 Chattanooga	311 Medical assist, assist EMS crew	
18-0003322	0	11/10/2018	01:31:20	908 Vernon	311 Medical assist, assist EMS crew	
18-0003323	0	11/10/2018	02:46:40	2220 Chattanooga	311 Medical assist, assist EMS crew	
18-0003324	0	11/10/2018	04:18:08	I-75 S. Bound	324 Motor Vehicle Accident with no	
18-0003325	0	11/10/2018	10:45:11	715 Gist	311 Medical assist, assist EMS crew	
18-0003326	0	11/10/2018	15:06:44	I-75 S. Bound	140 Natural vegetation fire, Other	
18-0003327	0	11/10/2018	15:39:34	815 Shugart	311 Medical assist, assist EMS crew	
18-0003328	0	11/10/2018	17:25:45	1105 Brookwood	311 Medical assist, assist EMS crew	
18-0003329	0	11/10/2018	18:50:27	1369 Walnut (West)	311 Medical assist, assist EMS crew	
18-0003330	0	11/10/2018	21:18:48	389 Castle	311 Medical assist, assist EMS crew	
18-0003331	0	11/10/2018	22:48:37	2220 Chattanooga	311 Medical assist, assist EMS crew	
18-0003332	0	11/10/2018	22:56:59	1520 Walnut (West)	611 Dispatched & cancelled en route	
18-0003333	0	11/11/2018	01:51:01	800 Judd	311 Medical assist, assist EMS crew	
18-0003334	0	11/11/2018	03:02:08	1527 Waring	311 Medical assist, assist EMS crew	
18-0003335	0	11/11/2018	05:04:18	I-75 S. Bound	324 Motor Vehicle Accident with no	
18-0003336	0	11/11/2018	05:50:47	1518 Walnut (West)	311 Medical assist, assist EMS crew	
18-0003337	0	11/11/2018	08:28:23	1104 Willowdale	611 Dispatched & cancelled en route	
18-0003338	0	11/11/2018	10:32:52	519 Hawthorne (West)	743 Smoke detector activation, no fire	
18-0003339	0	11/11/2018	16:06:33	1002 Foster	131 Passenger vehicle fire	\$2,200

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
18-0003340	0	11/11/2018	21:48:18	500	Bluff Hill	311 Medical assist, assist EMS crew	
18-0003341	0	11/11/2018	23:03:57	443	Thornton (North)	311 Medical assist, assist EMS crew	
18-0003342	0	11/12/2018	06:49:56		Abutment	322 Motor vehicle accident with	
18-0003343	0	11/12/2018	07:53:53	407	Vann	311 Medical assist, assist EMS crew	
18-0003344	0	11/12/2018	08:42:01	818	Shugart	311 Medical assist, assist EMS crew	
18-0003345	0	11/12/2018	10:45:25	604	Lenna	311 Medical assist, assist EMS crew	
18-0003346	0	11/12/2018	10:57:36	319	Glenwood (North)	322 Motor vehicle accident with	
18-0003347	0	11/12/2018	11:03:43	1420	Burgess	111 Building fire	\$5,100
18-0003348	0	11/12/2018	12:04:59	1225	Broadrick	311 Medical assist, assist EMS crew	
18-0003349	0	11/12/2018	12:07:02	719	Betty	311 Medical assist, assist EMS crew	
18-0003350	0	11/12/2018	14:04:20		North Bypass	324 Motor Vehicle Accident with no	
18-0003351	0	11/12/2018	15:23:35	1300	Waugh (West)	311 Medical assist, assist EMS crew	
18-0003352	0	11/12/2018	15:39:56		Tibbs (South)	322 Motor vehicle accident with	
18-0003353	0	11/12/2018	15:48:56	100	Thornton (South)	311 Medical assist, assist EMS crew	
18-0003354	0	11/12/2018	15:58:13	1200	Ashford	311 Medical assist, assist EMS crew	
18-0003355	0	11/12/2018	16:08:38	1741	Brighton	611 Dispatched & cancelled en route	
18-0003356	0	11/12/2018	18:51:05	701	Miller	311 Medical assist, assist EMS crew	
18-0003357	0	11/12/2018	19:27:41	243	Hamilton (North)	651 Smoke scare, odor of smoke	
18-0003358	0	11/12/2018	20:02:22	1115	Avenue A	311 Medical assist, assist EMS crew	
18-0003359	0	11/12/2018	20:09:42	2230	Hamilton Extension	311 Medical assist, assist EMS crew	
18-0003360	0	11/12/2018	20:55:31	407	Vann	311 Medical assist, assist EMS crew	
18-0003361	0	11/12/2018	20:57:49	1808	Dug Gap	553 Public service	
18-0003362	0	11/12/2018	22:54:35	2505	Walnut (East)	611 Dispatched & cancelled en route	
18-0003363	0	11/13/2018	03:28:50	1807	Beechland	311 Medical assist, assist EMS crew	
18-0003364	0	11/13/2018	07:30:06	881	College	132 Road freight or transport vehicle	\$26,000
18-0003365	0	11/13/2018	09:04:45	307	Emery (West)	743 Smoke detector activation, no fire	
18-0003366	0	11/13/2018	09:46:38	389	Castle	311 Medical assist, assist EMS crew	
18-0003367	0	11/13/2018	10:35:11	1250	Cross Plains	311 Medical assist, assist EMS crew	
18-0003368	0	11/13/2018	11:39:59	2125	Arbordale	611 Dispatched & cancelled en route	
18-0003369	0	11/13/2018	13:00:34	416	Cedar	611 Dispatched & cancelled en route	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003370	0	11/13/2018	16:48:04	1917 Brady	113 Cooking fire, confined to	
18-0003371	0	11/13/2018	17:39:30	1300 Waugh (West)	311 Medical assist, assist EMS crew	
18-0003372	0	11/13/2018	20:40:14	Walnut (West)	324 Motor Vehicle Accident with no	
18-0003373	0	11/14/2018	00:17:12	1115 Professional	311 Medical assist, assist EMS crew	
18-0003374	0	11/14/2018	06:46:03	Thornton (South)	352 Extrication of victim(s) from	
18-0003375	0	11/14/2018	07:21:59	1035 Abutment	745 Alarm system activation, no fire -	
18-0003376	0	11/14/2018	08:48:12	2211 Dug Gap Battle	510 Person in distress, Other	
18-0003377	0	11/14/2018	09:16:38	1000 V.D.Parrott	311 Medical assist, assist EMS crew	
18-0003378	0	11/14/2018	10:20:14	1903 Coventry	743 Smoke detector activation, no fire	
18-0003379	0	11/14/2018	11:07:11	612 Stone	311 Medical assist, assist EMS crew	
18-0003380	0	11/14/2018	11:38:54	900 Shugart	311 Medical assist, assist EMS crew	
18-0003381	0	11/14/2018	12:47:22	Thornton (North)	322 Motor vehicle accident with	
18-0003382	0	11/14/2018	13:43:44	1320 Winton	743 Smoke detector activation, no fire	
18-0003383	0	11/14/2018	13:51:16	865 Holiday Inn	611 Dispatched & cancelled en route	
18-0003384	0	11/14/2018	14:42:04	1116 Willowdale	311 Medical assist, assist EMS crew	
18-0003385	0	11/14/2018	15:41:35	7 Brothers	311 Medical assist, assist EMS crew	
18-0003386	0	11/14/2018	15:47:30	100 Bogle (South)	311 Medical assist, assist EMS crew	
18-0003387	0	11/14/2018	16:01:23	1320 Winton	311 Medical assist, assist EMS crew	
18-0003388	0	11/14/2018	17:08:26	612 Maney	311 Medical assist, assist EMS crew	
18-0003389	0	11/14/2018	22:32:04	I-75 S. Bound	611 Dispatched & cancelled en route	
18-0003390	0	11/14/2018	23:21:35	1906 Cascade	461 Building or structure weakened or	
18-0003391	0	11/14/2018	23:23:22	1621 Beechland	311 Medical assist, assist EMS crew	
18-0003392	0	11/15/2018	02:08:56	1000 Brown	311 Medical assist, assist EMS crew	
18-0003393	0	11/15/2018	06:17:34	519 Hawthorne (West)	311 Medical assist, assist EMS crew	
18-0003394	0	11/15/2018	08:47:36	98 Walnut (West)	411 Gasoline or other flammable liquid	
18-0003395	0	11/15/2018	11:33:44	1320 Winton	743 Smoke detector activation, no fire	
18-0003396	0	11/15/2018	11:36:22	1325 Walnut (West)	745 Alarm system activation, no fire -	
18-0003397	0	11/15/2018	14:13:43	708 Trammell	671 HazMat release investigation w/no	
18-0003398	0	11/15/2018	19:47:42	1808 Shadow	311 Medical assist, assist EMS crew	
18-0003399	0	11/16/2018	00:36:27	1101 Nelson	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003400	0	11/16/2018	08:59:35	1205 Walnut (West)	651 Smoke scare, odor of smoke	
18-0003401	0	11/16/2018	09:28:01	1320 Winton	743 Smoke detector activation, no fire	
18-0003402	0	11/16/2018	10:53:14	801 Katlau	311 Medical assist, assist EMS crew	
18-0003403	0	11/16/2018	12:16:46	1300 Waugh (West)	311 Medical assist, assist EMS crew	
18-0003404	0	11/16/2018	13:50:11	1325 Walnut (West)	745 Alarm system activation, no fire -	
18-0003405	0	11/16/2018	14:01:40	1104 Willowdale	735 Alarm system sounded due to	
18-0003406	0	11/16/2018	15:30:05	I-75 N. Bound	311 Medical assist, assist EMS crew	
18-0003407	0	11/16/2018	18:32:57	1907 Chattanooga	311 Medical assist, assist EMS crew	
18-0003408	0	11/16/2018	18:39:37	816 Walnut Square	311 Medical assist, assist EMS crew	
18-0003409	0	11/16/2018	20:27:11	2220 Chattanooga	553 Public service	
18-0003410	0	11/16/2018	21:22:50	421 Claude	311 Medical assist, assist EMS crew	
18-0003411	0	11/16/2018	23:11:20	1601 Mockingbird Hill	311 Medical assist, assist EMS crew	
18-0003412	0	11/17/2018	00:02:14	Valley	651 Smoke scare, odor of smoke	
18-0003413	0	11/17/2018	00:31:59	1520 Walnut (West)	745 Alarm system activation, no fire -	
18-0003414	0	11/17/2018	00:44:47	519 Hawthorne (West)	311 Medical assist, assist EMS crew	
18-0003415	0	11/17/2018	16:01:01	621 Hannah	311 Medical assist, assist EMS crew	
18-0003416	0	11/17/2018	16:11:39	1302 Moice	311 Medical assist, assist EMS crew	
18-0003417	0	11/17/2018	19:06:51	1218 Broadrick	311 Medical assist, assist EMS crew	
18-0003418	0	11/17/2018	19:33:37	1305 Walnut (West)	445 Arcing, shorted electrical	
18-0003419	0	11/17/2018	20:46:53	815 Shugart	311 Medical assist, assist EMS crew	
18-0003420	0	11/17/2018	21:03:39	1369 Walnut (West)	311 Medical assist, assist EMS crew	
18-0003421	0	11/17/2018	21:23:31	865 Holiday Inn	311 Medical assist, assist EMS crew	
18-0003422	0	11/18/2018	01:31:36	818 J & J	311 Medical assist, assist EMS crew	
18-0003423	0	11/18/2018	01:46:51	Chattanooga	611 Dispatched & cancelled en route	
18-0003424	0	11/18/2018	04:03:41	1915 Heathcliff	311 Medical assist, assist EMS crew	
18-0003425	0	11/18/2018	06:23:03	1200 Memorial	745 Alarm system activation, no fire -	
18-0003426	0	11/18/2018	07:34:46	415 Vann	311 Medical assist, assist EMS crew	
18-0003427	0	11/18/2018	10:55:44	928 Avenue F	311 Medical assist, assist EMS crew	
18-0003428	0	11/18/2018	14:32:22	309 Bowen	311 Medical assist, assist EMS crew	
18-0003429	0	11/18/2018	15:00:47	1104 Walston	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003430	0	11/18/2018	18:52:21	203 Mountain View	611 Dispatched & cancelled en route	
18-0003431	0	11/18/2018	19:28:33	303 Tibbs (South)	311 Medical assist, assist EMS crew	
18-0003432	0	11/18/2018	19:50:50	608 MLK Jr.	311 Medical assist, assist EMS crew	
18-0003433	0	11/18/2018	22:22:44	1701 Rio Vista	311 Medical assist, assist EMS crew	
18-0003434	0	11/18/2018	23:58:04	1500 Manly	745 Alarm system activation, no fire -	
18-0003435	0	11/18/2018	23:59:12	200 Bryant	745 Alarm system activation, no fire -	
18-0003436	0	11/19/2018	05:16:41	518 Parkside	311 Medical assist, assist EMS crew	
18-0003437	0	11/19/2018	08:49:03	1300 Autumn	611 Dispatched & cancelled en route	
18-0003438	0	11/19/2018	09:32:15	415 Vann	311 Medical assist, assist EMS crew	
18-0003439	0	11/19/2018	09:43:48	806 Harris	745 Alarm system activation, no fire -	
18-0003440	0	11/19/2018	10:53:23	612 Bryan	311 Medical assist, assist EMS crew	
18-0003441	0	11/19/2018	11:23:30	900 Shugart	311 Medical assist, assist EMS crew	
18-0003442	0	11/19/2018	12:37:57	1915 Abutment	311 Medical assist, assist EMS crew	
18-0003443	0	11/19/2018	13:16:03	Emery (West)	622 No Incident found on arrival at	
18-0003444	0	11/19/2018	13:32:40	1200 Memorial	745 Alarm system activation, no fire -	
18-0003445	0	11/19/2018	13:34:08	900 Shugart	311 Medical assist, assist EMS crew	
18-0003446	0	11/19/2018	16:00:49	1000 Brown	311 Medical assist, assist EMS crew	
18-0003447	0	11/19/2018	19:15:08	I-75 S. Bound	143 Grass fire	
18-0003448	0	11/19/2018	19:41:23	2220 Chattanooga	311 Medical assist, assist EMS crew	
18-0003449	0	11/19/2018	23:40:30	2214 Walnut (East)	611 Dispatched & cancelled en route	
18-0003450	0	11/20/2018	00:53:02	518 Parkside	311 Medical assist, assist EMS crew	
18-0003451	0	11/20/2018	04:32:59	1510 Walnut (West)	311 Medical assist, assist EMS crew	
18-0003452	0	11/20/2018	09:04:04	1114 Professional	611 Dispatched & cancelled en route	
18-0003453	0	11/20/2018	09:05:18	1300 Desota	311 Medical assist, assist EMS crew	
18-0003454	0	11/20/2018	15:49:43	109 Henderson (South)	745 Alarm system activation, no fire -	
18-0003455	0	11/20/2018	17:01:34	406 Virgil	111 Building fire	
18-0003456	0	11/20/2018	22:51:18	1899 Grand Summit	311 Medical assist, assist EMS crew	
18-0003457	0	11/20/2018	22:51:58	1906 Meadowbrook	311 Medical assist, assist EMS crew	
18-0003458	0	11/21/2018	04:24:49	1907 Chattanooga	411 Gasoline or other flammable liquid	
18-0003459	0	11/21/2018	08:42:55	1320 Winton	743 Smoke detector activation, no fire	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003460	0	11/21/2018	08:57:48	1801 Shadow	311 Medical assist, assist EMS crew	
18-0003461	0	11/21/2018	11:21:12	815 Shugart	311 Medical assist, assist EMS crew	
18-0003462	0	11/21/2018	12:34:33	1017 Delaware	111 Building fire	\$10,000
18-0003463	0	11/21/2018	14:05:46	900 Shugart	311 Medical assist, assist EMS crew	
18-0003464	0	11/21/2018	17:28:36	1983 Sourwood	631 Authorized controlled burning	
18-0003465	0	11/21/2018	17:33:23	875 Shugart	311 Medical assist, assist EMS crew	
18-0003466	0	11/22/2018	00:01:18	104 Goose Hill (North)	611 Dispatched & cancelled en route	
18-0003467	0	11/22/2018	07:06:26	818 J & J	715 Local alarm system, malicious	
18-0003468	0	11/22/2018	15:02:02	110 Sioux	311 Medical assist, assist EMS crew	
18-0003469	0	11/22/2018	16:20:24	Walnut (West)	311 Medical assist, assist EMS crew	
18-0003470	0	11/22/2018	17:07:00	2007 Southview	311 Medical assist, assist EMS crew	
18-0003471	0	11/22/2018	17:39:20	500 Autumn	311 Medical assist, assist EMS crew	
18-0003472	0	11/22/2018	18:26:08	Burchfield	322 Motor vehicle accident with	
18-0003473	0	11/22/2018	21:41:41	306 Hightower	311 Medical assist, assist EMS crew	
18-0003474	0	11/22/2018	21:52:02	1300 Waugh (West)	311 Medical assist, assist EMS crew	
18-0003475	0	11/23/2018	01:59:57	335 Goodwill	311 Medical assist, assist EMS crew	
18-0003476	0	11/23/2018	02:26:19	311 Meeting	311 Medical assist, assist EMS crew	
18-0003477	0	11/23/2018	03:03:26	625 Virginia	311 Medical assist, assist EMS crew	
18-0003478	0	11/23/2018	03:59:10	1203 Georgian	311 Medical assist, assist EMS crew	
18-0003479	0	11/23/2018	05:38:39	906 Dug Gap Mtn. (West)	311 Medical assist, assist EMS crew	
18-0003480	0	11/23/2018	09:13:51	310 Sycamore	311 Medical assist, assist EMS crew	
18-0003481	0	11/23/2018	10:38:56	1000 Brown	311 Medical assist, assist EMS crew	
18-0003482	0	11/23/2018	11:31:26	800 Red Clay	311 Medical assist, assist EMS crew	
18-0003483	0	11/23/2018	12:26:22	903 Hamilton (South)	311 Medical assist, assist EMS crew	
18-0003484	0	11/23/2018	13:20:56	607 Audubon	743 Smoke detector activation, no fire	
18-0003485	0	11/23/2018	17:07:11	I-75 S. Bound	413 Oil or other combustibile liquid	
18-0003486	0	11/23/2018	17:22:54	I-75 S. Bound	551 Assist police or other	
18-0003487	0	11/24/2018	01:15:32	236 Depot	311 Medical assist, assist EMS crew	
18-0003488	0	11/24/2018	08:57:40	800 Red Clay	311 Medical assist, assist EMS crew	
18-0003489	0	11/24/2018	10:54:25	1000 Brown	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003490	0	11/24/2018	16:35:29	1309 Applewood	651 Smoke scare, odor of smoke	
18-0003491	0	11/24/2018	21:57:14	1120 Riverbend	311 Medical assist, assist EMS crew	
18-0003492	0	11/25/2018	01:18:39	2220 Chattanooga	311 Medical assist, assist EMS crew	
18-0003493	0	11/25/2018	01:32:19	2315 Sir Lancelot	311 Medical assist, assist EMS crew	
18-0003494	0	11/25/2018	07:33:09	703 Hampton	311 Medical assist, assist EMS crew	
18-0003495	0	11/25/2018	09:43:43	1001 Thornton (South)	311 Medical assist, assist EMS crew	
18-0003496	0	11/25/2018	10:16:58	2313 Dalton Industrial	311 Medical assist, assist EMS crew	
18-0003497	0	11/25/2018	10:30:37	1000 Vista	251 Excessive heat, scorch burns with	
18-0003498	0	11/25/2018	11:35:13	1891 Crow Valley	311 Medical assist, assist EMS crew	
18-0003499	0	11/25/2018	11:37:24	916 Vernon	311 Medical assist, assist EMS crew	
18-0003500	0	11/25/2018	13:11:28	806 Harris	611 Dispatched & cancelled en route	
18-0003501	0	11/25/2018	13:29:15	1104 Walston	311 Medical assist, assist EMS crew	
18-0003502	0	11/25/2018	18:17:11	817 Hamilton (South)	744 Detector activation, no fire -	
18-0003503	0	11/25/2018	19:09:59	2012 Kingsridge	611 Dispatched & cancelled en route	
18-0003504	0	11/25/2018	21:22:47	1300 Waugh (West)	311 Medical assist, assist EMS crew	
18-0003505	0	11/25/2018	22:28:26	1000 Brown	311 Medical assist, assist EMS crew	
18-0003506	0	11/26/2018	00:22:17	707 Gist	311 Medical assist, assist EMS crew	
18-0003507	0	11/26/2018	01:51:24	1030 Willowdale	651 Smoke scare, odor of smoke	
18-0003508	0	11/26/2018	09:40:43	1600 MLK Jr.	743 Smoke detector activation, no fire	
18-0003509	0	11/26/2018	10:13:48	222 Hamilton (North)	735 Alarm system sounded due to	
18-0003510	0	11/26/2018	10:26:23	310 Cappes	555 Defective elevator, no occupants	
18-0003511	0	11/26/2018	10:31:08	900 Shugart	311 Medical assist, assist EMS crew	
18-0003512	0	11/26/2018	11:50:06	MLK Jr.	311 Medical assist, assist EMS crew	
18-0003513	0	11/26/2018	12:47:33	1309 Applewood	311 Medical assist, assist EMS crew	
18-0003514	0	11/26/2018	13:42:21	Maddox Chapel	324 Motor Vehicle Accident with no	
18-0003515	0	11/26/2018	13:48:29	416 Cedar	551 Assist police or other	
18-0003516	0	11/26/2018	14:44:17	1205 Glenwood (North)	412 Gas leak (natural gas or LPG)	
18-0003517	0	11/26/2018	15:07:53	416 Cedar	311 Medical assist, assist EMS crew	
18-0003518	0	11/26/2018	15:29:19	1010 Ponderosa	311 Medical assist, assist EMS crew	
18-0003519	0	11/27/2018	00:26:10	904 Valentine	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
18-0003520	0	11/27/2018	06:00:35	205 Industrial (West)	735 Alarm system sounded due to	
18-0003521	0	11/27/2018	08:13:45	122 Huntington	611 Dispatched & cancelled en route	
18-0003522	0	11/27/2018	10:32:41	705 Burchfield	444 Power line down	
18-0003523	0	11/27/2018	11:35:48	800 Professional	715 Local alarm system, malicious	
18-0003524	0	11/27/2018	13:05:56	1322 Walnut (West)	311 Medical assist, assist EMS crew	
18-0003525	0	11/27/2018	14:42:41	1012 Burleyson	611 Dispatched & cancelled en route	
18-0003526	0	11/27/2018	14:58:25	1250 Cross Plains	743 Smoke detector activation, no fire	
18-0003527	0	11/27/2018	17:32:19	414 Barbara	311 Medical assist, assist EMS crew	
18-0003528	0	11/27/2018	21:05:23	411 North Park	744 Detector activation, no fire -	
18-0003529	0	11/27/2018	21:27:49	1801 Dug Gap	311 Medical assist, assist EMS crew	
18-0003530	0	11/28/2018	02:29:45	712 Skylark	441 Heat from short circuit (wiring),	
18-0003531	0	11/28/2018	08:57:02	705 College	611 Dispatched & cancelled en route	
18-0003532	0	11/28/2018	09:45:03	1110 Burleyson	611 Dispatched & cancelled en route	
18-0003533	0	11/28/2018	11:28:28	2300 Botany Woods	622 No Incident found on arrival at	
18-0003534	0	11/28/2018	14:03:25	606 Olivia	311 Medical assist, assist EMS crew	
18-0003535	0	11/28/2018	14:31:23	2107 Walnut (East)	421 Chemical hazard (no spill or leak)	
18-0003536	0	11/28/2018	15:59:40	1306 Underwood	745 Alarm system activation, no fire -	
18-0003537	0	11/28/2018	16:59:46	610 Dantzler	311 Medical assist, assist EMS crew	
18-0003538	0	11/29/2018	01:02:37	707 Gist	311 Medical assist, assist EMS crew	
18-0003539	0	11/29/2018	08:27:22	405 Matilda. (West)	445 Arcing, shorted electrical	
18-0003540	0	11/29/2018	09:21:18	1320 Winton	311 Medical assist, assist EMS crew	
18-0003541	0	11/29/2018	11:57:02	1218 Broadrick	311 Medical assist, assist EMS crew	
18-0003542	0	11/29/2018	12:57:47	Walnut (West)	463 Vehicle accident, general cleanup	
18-0003543	0	11/29/2018	13:02:12	Waugh (West)	324 Motor Vehicle Accident with no	
18-0003544	0	11/29/2018	14:24:26	1116 Willowdale	311 Medical assist, assist EMS crew	
18-0003545	0	11/29/2018	15:31:19	1300 Waugh (West)	311 Medical assist, assist EMS crew	
18-0003546	0	11/29/2018	22:02:03	306 Hightower	311 Medical assist, assist EMS crew	
18-0003547	0	11/29/2018	22:28:38	1310 Woodsdale	311 Medical assist, assist EMS crew	
18-0003548	0	11/30/2018	08:04:02	1104 Walston	311 Medical assist, assist EMS crew	
18-0003549	0	11/30/2018	10:53:57	2659 Abutment	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2018} And {11/30/2018}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
18-0003550	0	11/30/2018	11:51:46	1111	Brookwood	311 Medical assist, assist EMS crew	
18-0003551	0	11/30/2018	11:54:09		Legion	444 Power line down	
18-0003552	0	11/30/2018	11:55:02		Chattanooga	322 Motor vehicle accident with	
18-0003553	0	11/30/2018	16:24:39	104	Fort Hill	735 Alarm system sounded due to	
18-0003554	0	11/30/2018	16:51:49	519	Hawthorne (West)	311 Medical assist, assist EMS crew	
18-0003555	0	11/30/2018	18:00:12	1917	Heathcliff	745 Alarm system activation, no fire -	
18-0003556	0	11/30/2018	18:14:26	1703	Willow Oak	311 Medical assist, assist EMS crew	
18-0003557	0	11/30/2018	22:32:02	210	Easterling (North)	311 Medical assist, assist EMS crew	
Total Incident Count							338
Total Est Loss							\$48,600

Training Division Monthly Report

November 2018

Overview

The department hosted a course entitled Pipeline Emergencies: Command Officer Strategies which was delivered in partnership between Georgia Pipeline Emergency Response Initiative (GPERI) and Georgia Public Safety Training Center (GPSTC). Attendees included personnel from Dalton Utilities, Whitfield County Fire Department, Hamilton EMS, and DFD. Annual hazardous materials refresher training was completed for all personnel. Monthly training included territory familiarization, pre-fire training, core competency check-offs, special operations training, and company level drills chosen by company officers. Training hours during the month of November totaled 1,624.

Outside Schools

One of the department's SCBA mechanics attended air supply technician recertification training in Decatur, Alabama.

Three of the department's EMT Instructors attended a course on emergency pediatric care delivered by National Association of Emergency Medical Technicians (NAEMT).

Three DFD personnel attended National Incident Management System (NIMS) 300 and 400 level training hosted by Whitfield County EMA and delivered by Texas A&M Engineering Extension Service.

Additional off-campus training included:

Politics and the White Helmet	GPSTC	1
Chief Fire Officer Orientation – Day 3	GPSTC	1
Chief Fire Officer Orientation – Day 4	GPSTC	1
Rescue Systems 1 – Fundamentals of Heavy Rescue	GPSTC	1

Support Functions

- 216 hours were spent completing apparatus checks and equipment replenishment
- Cleaning and maintenance activities accounted for 689 hours in November
- 9 hours were committed to fall hydrant detail
- 4 hours were dedicated to fire investigation and related activities

Prevention Division Monthly Report

November 2018

Inspections

Annual Inspections	Total:	59
Site Inspections	Total:	19
New Kitchen Hood Inspections	Total:	3
Knox Box Installation	Total:	5
Occupational Tax Certificate Inspections	Total:	15
Pre-Incident Surveys	Total:	19
Total Inspections		120

Public Relations

Fire Safety Education	
10	Events
27	Staff Members Participated
75	Staff Hours
155	Total Number of Adults Reached
413	Total Number of Children Reached
568	Residents Received Fire Safety Education

Dalton Fire Department

Monthly Prevention Inspections by Type

**Date Completed Between {11/01/2018} And
{11/30/2018}**

Date	Time	Occupancy	Hrs	Fee
200 INSPECTION - Annual				
11/05/2018	11:01	50145 Sonic 1201 Glenwood (North) AVE	0.13	
11/05/2018	10:07	50149 Starbuck's 1305 Glenwood (North) AVE	0.32	
11/05/2018	09:47	50124 Signs by Ink Fish 601 Flemming ST /Suite D	0.10	
11/05/2018	09:37	50125 1st Franklin Financial 601 Flemming ST /Suite A	0.12	
11/05/2018	09:22	50107 Herbalife 307 Smith Industrial BLVD /Suite E & F	0.11	
11/06/2018	10:20	50099 J&J Industries - Southcreek 1605 Underwood ST	0.43	
11/06/2018	15:02	50009 Ace Transporation 815 Legion DR	0.01	
11/06/2018	11:27	50148 Hardee's 1301 Glenwood (North) AVE	0.21	
11/06/2018	09:02	50150 Circle K 1200 Glenwood (North) AVE	0.24	
11/06/2018	09:33	50121 Audibel Hearing Aid 601 Flemming ST /Suite B	0.14	
11/06/2018	10:48	50122 Mattress Connection 601 Flemming ST /Suite C	0.13	
11/06/2018	09:46	50123 Dr. Micheal Vitkin 601 Flemming ST /Suite E	0.20	
11/06/2018	11:03	50126 Gio's 603 Flemming ST /Suite F	0.13	
11/06/2018	13:23	50063 Whitfield Nails 1231 Glenwood (North) AVE	0.11	
11/06/2018	11:15	50109 D.T. Nails 307 Smith Industrial BLVD /Suite G	0.11	
11/07/2018	10:01	50132 Dalton Airport 4483 Airport RD	0.16	
11/07/2018	10:28	50133 Dalton Aircraft 4465 Airport RD	0.05	
11/08/2018	09:12	50102 SHAW INDUSTRIES PLANT #63 1401 Underwood ST	0.65	
11/08/2018	09:31	50116 Whitfield/Murray Early Headstart 2738 Underwood RD	0.15	

Dalton Fire Department

Monthly Prevention Inspections by Type

**Date Completed Between {11/01/2018} And
{11/30/2018}**

Date	Time	Occupancy	Hrs	Fee
200 INSPECTION - Annual				
11/09/2018	10:40	50005 DALTON GOLF AND COUNTRY CLUB MAINT.BDLG. 403 Flemming ST	0.22	
11/09/2018	10:19	50049 Apex Spine Center 1716 Cleveland RD /700	0.01	
11/09/2018	10:28	50046 Dental Arts of Dalton 1716 Cleveland HWY /400	0.07	
11/09/2018	09:44	50036 Lowe's Home Center 1212 Glenwood (North) AVE	0.17	
11/09/2018	10:06	50043 Rite-Aid 1320 Glenwood (North) AVE	0.03	
11/09/2018	10:14	50044 STATE FARM INSURANCE 1716 Cleveland HWY /100	0.08	
11/09/2018	10:36	50050 Vacant 1716 Cleveland RD /800	0.01	
11/09/2018	09:16	50096 Iglesia De Dios Pentecostal Fuente Agua 1007 Underwood ST	0.34	
11/09/2018	13:58	50083 ZAXBY'S 352 Northgate DR	0.04	
11/08/2018	10:10	50035 Jack's 1202 Glenwood (North) AVE	0.10	
11/08/2018	10:20	50038 McDonalds 1210 Glenwood (North) AVE	0.10	
11/13/2018	08:27	50076 Food City 1287 Glenwood (North) AVE	0.04	
11/14/2018	13:06	50097 VFW 618 Veterans DR	0.65	
11/15/2018	10:41	30074 Avanti Enviromental Group, Inc. 1406 Coronet DR	0.21	
11/27/2018	13:05	50001 U.S FLOORS 1301 C & L DR	0.13	
11/27/2018	13:06	50044 STATE FARM INSURANCE 1716 Cleveland HWY /100	0.01	
11/27/2018	08:55	30020 Benchmark Physical Therapy 1508 Thornton (North) AVE /106,108,110	0.56	
11/27/2018	09:45	20768 Highland Rivers 1011 Abutment RD	0.17	
11/28/2018	10:12	50040 CAPTAIN D's SEAFOOD 1236 Glenwood (North) AVE	0.08	

Dalton Fire Department

Monthly Prevention Inspections by Type

**Date Completed Between {11/01/2018} And
{11/30/2018}**

Date	Time	Occupancy	Hrs	Fee
200 INSPECTION - Annual				
11/28/2018	08:43	50053 Kroger 1205 Glenwood (North) AVE	0.46	
11/28/2018	10:20	50037 Taco Bell 1242 Glenwood (North) AVE	0.08	
11/29/2018	10:31	50112 Cross Pointe Christian Center 2681 Underwood ST	0.44	
11/29/2018	10:11	40001 Vacant 705 Conway ST	0.02	
11/29/2018	14:17	40019 DEMOLISHED 925 Market ST	0.00	
11/29/2018	14:18	40020 DEMOLISHED 934 Market ST	0.01	
11/29/2018	14:18	40021 DEMOLISHED 936 Market ST	0.01	
11/29/2018	10:28	40032 Vacant 1001 Market ST /Suite 10	0.00	
11/29/2018	15:26	40033 Vacant 1001 Market ST /Suite 11	0.04	
11/29/2018	15:03	40035 Oyster Pub 933 Market ST /Suite 12 B	0.25	
11/29/2018	15:28	40036 Vacant 1001 Market ST /Suite 13	0.03	
11/29/2018	14:20	40037 See suite 14 1001 Market ST /Suite 14 A	0.01	
11/29/2018	14:35	40038 Stadium BBQ 1001 Market ST /Suite 14	0.30	
11/28/2018	10:05	50039 GooGoo Express Wash 1234 Glenwood (North) AVE	0.07	
11/28/2018	09:54	50081 Popeyes 1247 Glenwood (North) AVE	0.10	
11/28/2018	09:46	50080 Atlantic Capital 1237 Glenwood (North) AVE	0.04	
11/28/2018	09:02	20101 Servicios Latinos 908 Elk ST	0.04	
11/28/2018	09:59	50150 Circle K 1200 Glenwood (North) AVE	0.01	
11/30/2018	09:29	20731 Park View Apartments 214 Easterling ST	0.49	

Dalton Fire Department

Monthly Prevention Inspections by Type

**Date Completed Between {11/01/2018} And
{11/30/2018}**

Date	Time	Occupancy	Hrs	Fee
200 INSPECTION - Annual				
11/30/2018	11:26	40106 Mermaid Mattress 920 Market ST /Suite F	0.13	
11/30/2018	10:58	40140 Subway 920 Market ST /Suite G	0.21	
Total Activities for Type: 59			9.26	
210 INSPECTION - Site				
11/30/2018		40069 Vacant 1513 Walnut (West) AVE /SUITE 1	0.00	
11/30/2018		40071 Vacant 1513 Walnut (West) AVE /SUITE 3	0.00	
11/30/2018		40070 Vacant 1513 Walnut (West) AVE /SUITE4	0.00	
11/30/2018		20504 Dalton Mall 816 Walnut Square BLVD	0.00	
11/23/2018		20278 City of Refuge 120 Morris (East) ST	0.00	
11/30/2018		20278 City of Refuge 120 Morris (East) ST	0.00	
11/28/2018		40136 BP Gas station 1522 Walnut (West) AVE	1.00	
11/28/2018		10070 City Park School 405 School ST	0.00	
11/28/2018	09:05	20091 Brookwood Elementary School 501 Central AVE	0.01	
11/16/2018	08:02	20504 Dalton Mall 816 Walnut Square BLVD	0.02	
11/19/2018		40167 TJ Maxx 1327 Walnut (West) AVE	0.00	
11/26/2018		10704 Strawberry Commons 1420 Burgess DR /39	0.00	
11/13/2018		20504 Dalton Mall 816 Walnut Square BLVD	1.00	
11/13/2018		20052 Cargill Chemical 208 Brookhollow Ind. BLVD	2.00	
11/05/2018		20054 Plaze Georgia 310 Brookhollow Ind. BLVD	0.00	

Dalton Fire Department

Monthly Prevention Inspections by Type

Date Completed Between {11/01/2018} And
{11/30/2018}

Date	Time	Occupancy	Hrs	Fee
210 INSPECTION - Site				
11/05/2018		20246 SHAW INDUSTRIES 2305 Abutment RD	0.00	
11/09/2018		40104 Waffle House 1531 Walnut (West) AVE	0.00	
11/01/2018		40002 NW Gerogia Trade and Convention Center 2211 Dug Gap Battle RD	6.00	
11/06/2018	09:17	30003 WOOD DALE HEATH CARE 1102 Burleyson RD	0.02	
Total Activities for Type: 19			10.05	
250 INSPECTION - New Kitchen Hood Installation				
11/05/2018	12:19	10399 El Ranchero 1523 Morris (East) ST	0.89	
11/09/2018		10769 Dago's Grocery 1525 Morris (East) ST	0.00	
11/12/2018	09:00	40104 Waffle House 1531 Walnut (West) AVE	0.75	
Total Activities for Type: 3			1.64	
251 INSPECTION - Knox Box Installation				
11/05/2018		50102 SHAW INDUSTRIES PLANT #63 1401 Underwood ST	0.00	
11/09/2018		50083 ZAXBY'S 352 Northgate DR	0.00	
11/09/2018		20619 ZAXBY'S 2710 Airport RD	0.00	
11/05/2018	11:40	20701 Groomingtails 801 Walnut (East) AVE /Suite H	0.01	
11/27/2018	13:09	50044 STATE FARM INSURANCE 1716 Cleveland HWY /100	0.01	
Total Activities for Type: 5			0.02	

Dalton Fire Department

Monthly Prevention Inspections by Type

**Date Completed Between {11/01/2018} And
{11/30/2018}**

Date	Time	Occupancy	Hrs	Fee
261 INSPECTION - OTC				
11/26/2018	10:28	40181 Real Food 1327 Dug Gap RD /Suite 1	0.04	
11/26/2018	10:15	10765 Mr. Appliance of Dalton 207 Easterling (North) ST /Suite 5	0.04	
11/30/2018	14:20	10764 A-1 Transport/D-1 Motors Inc. 527 Elm ST	0.07	
11/05/2018	10:59	10399 El Ranchero 1523 Morris (East) ST	0.11	
11/07/2018	12:48	20543 CHIC-FIL-A 816 Walnut Square BLVD /59/59	0.10	
11/07/2018	13:34	10771 American Import Auto Parts LLC. 412 Hamilton (North) ST	0.17	
11/07/2018	14:55	30288 BP Food Mart Inc. 2201 Chattanooga RD	0.16	
11/07/2018	09:01	10028 Cross Ins. Co 101 Crawford (East) ST /suite 102	0.34	
11/07/2018	14:20	40182 Chic-Fil-A 1517 Walnut (West) AVE	0.21	
11/08/2018	10:51	40180 McDonalds 1523 Walnut (West) AVE	0.05	
11/14/2018	12:15	10448 Paula Plott Gregg Art Studio 310 Selvidge St. (North)	0.07	
11/14/2018	09:51	30286 Northwest Georgia Home Health LLC 1008 Professional BLVD /4B	0.01	
11/16/2018	09:51	40117 Restoration Recovery 1500 Dug Gap RD	0.02	
11/14/2018	12:06	10764 A-1 Transport/D-1 Motors Inc. 527 Elm ST	0.31	
11/14/2018	10:02	10022 B & B Wings and Grill Inc. 1218 Thornton (North) AVE	0.33	
Total Activities for Type: 15			2.03	

Dalton Fire Department

Monthly Prevention Inspections by Type

**Date Completed Between {11/01/2018} And
{11/30/2018}**

Date	Time	Occupancy	Hrs	Fee
501 PRE-INCIDENT SURVEY				
11/12/2018	13:00	50094 Christian Heritage School 1600 MLK Jr. BLVD	0.00	
11/12/2018	14:00	50137 Christian Heritage High School 1601 MLK Jr. BLVD	0.00	
11/12/2018	09:00	50010 DALTON UTILITIES WATER TREATMENT PLANT 4410 Mitchell Bridge RD	0.00	
11/26/2018		50026 Tandus / COLLINS AND AIKMAN 1000 Vista DR	0.00	
11/26/2018		50140 Cook Out 1257 Glenwood (North) AVE	0.00	
11/26/2018	10:00	20359 Atlantic Capital Bank (First Bank) 401 Thornton (South) AVE	0.00	
11/26/2018	10:00	20365 Budgetel 609 Thornton (South) AVE	0.00	
11/26/2018	09:00	20159 DALTON PUBLIC SCHOOL MIANT. 412 Hamilton (South) ST	1.00	
11/26/2018	10:00	30089 Advanced Color Technologies 1727 Kimberly Park DR	0.00	
11/19/2018	13:30	50112 Cross Pointe Christian Center 2681 Underwood ST	0.00	
11/19/2018	10:00	40003 Vertex Investment Partners 2201 Executive Park DR	0.00	
11/19/2018	10:30	40006 Belhaven University 2103 Fiber Park DR	0.00	
11/05/2018		50088 Vacant 101 North Oaks DR /Suite 1	0.00	
11/05/2018		50115 Integrity Risk Advisors 101 North Oaks DR /Suite 5	0.00	
11/05/2018		50114 Paula Plott Gregg Design 101 North Oaks DR /Suite 2	0.00	
11/05/2018		50141 Eagle Properties 101 North Oaks DR /3	0.00	
11/05/2018		50142 Eagle Properties 101 North Oaks DR /4	0.00	
11/05/2018		50005 DALTON GOLF AND COUNTRY CLUB MAINT.BDLG. 403 Flemming ST	0.00	
11/05/2018		30117 Berry Plastics 1009 Poly Pac DR	0.00	

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

10764 **A-1 Transport/D-1 Motors Inc.**
 527 Elm ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/14/2018	* 2012 IFC 505.1 Address, no suite	1			0
	Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Add address signage at least 4 inches tall and 1/2 inch wide that's visible from the road.				
11/14/2018	* 2012 IFC 505.1 Address, no suite	1			0
	Notes: Add address signage at least 4 inches tall and 1/2 inch wide that's visible from the road.				
11/14/2018	* 2012 IFC 605.1 Electrical panel, abatement of	1			0
	Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install blanks in electrical panel.				
11/14/2018	* 2012 IFC 605.1 Electrical panel, abatement of	1			0
	Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Exposed wiring should be in conduit.				
11/14/2018	* 2012 IFC 605.1 Electrical panel, abatement of	1			0
	Notes: Exposed wiring should be in conduit.				
11/14/2018	* 2012 IFC 605.1 Electrical panel, abatement of	1			0
	Notes: Install blanks in electrical panel.				
11/14/2018	* 2012 IFC 605.5 Extension cord, Improper use	1			0
	Notes: Unplug extension cords when not using.				

* Denotes Violations Corrected or Variance Issued

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

**10764 A-1 Transport/D-1 Motors Inc.
 527 Elm ST
 Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/14/2018	* 2012 IFC 605.5 Extension cord, Improper use Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Unplug extension cords when not using.	1			0
11/14/2018	* 2012 IFC 906.2 Fire extinguisher, Properly Notes: Annual inspection needed on fire extinguishers.	1			0
11/14/2018	* 2012 IFC 906.2 Fire extinguisher, Properly Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Annual inspection needed on fire extinguishers.	1			0
11/14/2018	* 2012 IFC 906.3 Fire extinguisher, incorrect Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Fire extinguisher needed in work bay.	1			0
11/14/2018	* 2012 IFC 906.3 Fire extinguisher, incorrect Notes: Fire extinguisher needed in work bay.	1			0
11/14/2018	* 2012 NFPA 101 7.9.2.1 Emergency light, none Notes: Install emergency lighting in work bays.	1			0
11/14/2018	* 2012 NFPA 101 7.9.2.1 Emergency light, none Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Install emergency lighting in work bays.	1			0

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

10764 **A-1 Transport/D-1 Motors Inc.**
 527 Elm ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/14/2018	* 2012 NFPA101 7.10.5.1 Exit sign, non functional	1			0
	Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Repair or replace exit signage.				
11/14/2018	* 2012 NFPA101 7.10.5.1 Exit sign, non functional	1			0
	Notes: Repair or replace exit signage.				
11/14/2018	* 2013 NFPA 10 6.1.3.8.1 Fire extinguisher,	1			0
	Notes: Mount fire extinguishers.				
11/14/2018	* 2013 NFPA 10 6.1.3.8.1 Fire extinguisher,	1			0
	Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Mount fire extinguishers.				
11/14/2018	* DFDFMO AHJ, Requirement	1			0
	Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Used fluids should be properly stored. Properly secure compressed gas cylinders.				
11/14/2018	* DFDFMO AHJ, Requirement	1			0
	Notes: Used fluids should be properly stored. Properly secure compressed gas cylinders.				

Total Individual Violation Codes for Occupancy: 20

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

**10771 American Import Auto Parts LLC.
 412 Hamilton (North) ST
 Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/07/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Install Knox Box on building.	1			0
11/07/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Install key once box is installed.	1			0
11/07/2018	2012 IFC 605.1 Electrical panel, abatement of Notes: Install blanks in electrical panel.	1			0
11/07/2018	2012 IFC 605.3 Electrical panel, obstructed Notes: Remove combustibles around electrical panel.	1			0
11/07/2018	2012 IFC 906.2 Fire extinguisher, Properly Notes: Have Fire extinguishers serviced.	1			0
11/07/2018	2012 NFPA 101 7.9.2.1 Emergency light, none Notes: Install emergency lighting.	1			0

Total Individual Violation Codes for Occupancy: 6

**50121 Audibel Hearing Aid
 601 Flemming ST
 Suite B
 Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Add Knox Box to building.	1			0

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

50121 **Audibel Hearing Aid**
 601 Flemming ST
 Suite B
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2012 IFC 605.3 Electrical panel, obstructed	1			0
	Notes: Move cabinet.				

Total Individual Violation Codes for Occupancy: 2

10022 **B & B Wings and Grill Inc.**
 1218 Thornton (North) AVE
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/14/2018	2011 NFPA 96 11.4 Kitchen hood,	1			0
	Notes: Hood system needs to be inspected and cleaned.				
11/14/2018	2012 IFC 505.1 Address, no suite	1			0
	Notes: Install address numbers at least 4 inches tall and 1/2 inch wide.				
11/14/2018	2012 IFC 506.1 Knox Box, requirements	1			0
	Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Install Knox Box on building.				
11/14/2018	2012 IFC 506.1 Knox Box, requirements	1			0
	Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Install key once box is installed.				
11/14/2018	2012 IFC 605.3 Electrical panel, obstructed	1			0
	Notes:				

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

**10022 B & B Wings and Grill Inc.
 1218 Thornton (North) AVE
 Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

Do not store combustibles within 3 feet of electrical panel.

11/14/2018	2012 IFC 605.5 Extension cord, Improper use	1			0
------------	---	---	--	--	---

Notes:

Use extension cords for temporary power only.

11/14/2018	2012 IFC 605.6 Electrical panel, cover not	1			0
------------	--	---	--	--	---

Notes:

Install cover on light switch.

11/14/2018	2012 IFC 906.2 Fire extinguisher, Properly	1			0
------------	--	---	--	--	---

Notes:

Current inspection needed on fire extinguisher.

11/14/2018	2013 NFPA 10 6.1.3.8.1 Fire extinguisher,	1			0
------------	---	---	--	--	---

Notes:

Mount extinguishers as discussed.

Total Individual Violation Codes for Occupancy: 9

**30020 Benchmark Physical Therapy
 1508 Thornton (North) AVE
 106,108,110
 Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

11/27/2018	2012 IFC 305.1 Combustibles, to close to heat	1			0
------------	---	---	--	--	---

Notes: Remove combustibles near dryer.

11/27/2018	2012 IFC 506.1 Knox Box, requirements	1			0
------------	---------------------------------------	---	--	--	---

Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Install Knox Box on

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

**30020 Benchmark Physical Therapy
1508 Thornton (North) AVE
106,108,110
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
	building.				
11/27/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Install key once box is installed.	1			0
11/27/2018	2012 IFC 605.1 Electrical panel, abatement of Notes: Install blanks in electrical panel.	1			0
11/27/2018	2012 IFC 605.1 Electrical panel, abatement of Notes: Exposed wiring should be in conduit.	1			0
11/27/2018	2012 IFC 605.3.1 Electrical panel, concealed Notes: Add signage on electrical room.	1			0
11/27/2018	2012 IFC 605.6 Electrical panel, cover not Notes: Install cover on electrical panel.	1			0
11/27/2018	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access Notes: Remove items in doorway.	1			0
11/27/2018	2012 NFPA 101 7.2.1.5.1 Exit, while building Notes: Marked exit must remain unlocked during business hours.	1			0
11/27/2018	2012 NFPA 101 7.9.3.1.1 Emergency light, Notes: Emergency light not working. Recommend adding additional emergency lights.	1			0

Total Individual Violation Codes for Occupancy: 10					

**30288 BP Food Mart Inc.
2201 Chattanooga RD
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
-----------------	-------------------------	--------------	----------------	-----------------	-------------

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

**30288 BP Food Mart Inc.
2201 Chattanooga RD
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/07/2018	2012 IFC 605.1 Electrical panel, abatement of Notes: Install blanks in electrical panel.	1			0
11/07/2018	2012 IFC 605.3 Electrical panel, obstructed Notes: Remove combustibles near electrical panel.	1			0
11/07/2018	2012 IFC 605.4 Multi outlet adaptor Notes: Multi plugs should not be connected to another multi plug.	1			0
11/07/2018	2012 IFC 605.5 Extension cord, Improper use Notes: Remove extension cords and replace with permanent wiring.	1			0
11/07/2018	2012 IFC 906.3 Fire extinguisher, incorrect Notes: Install 10lb extinguisher at gas pumps.	1			0
11/07/2018	2012 NFPA 101 7.9.3.1.1 Emergency light, Notes: Repair or replace emergency light.	1			0
11/07/2018	2012 NFPA101 7.10.5.1 Exit sign, non functional Notes: Repair or replace exit sign.	1			0

Total Individual Violation Codes for Occupancy: 7

**40182 Chic-Fil-A
1517 Walnut (West) AVE
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/07/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building.	1			0
11/07/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is	1			0

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

**40182 Chic-Fil-A
1517 Walnut (West) AVE
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
	installed.				
11/07/2018	2012 IFC 605.3 Electrical panel, obstructed Notes: Remove combustibles near electrical panel.	1			0

Total Individual Violation Codes for Occupancy: 3

**50150 Circle K
1200 Glenwood (North) AVE
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	* 2012 IFC 605.3 Electrical panel, obstructed Notes: Move boxes from in front electrical panel. Keep on the outside of line.	1			0
11/06/2018	* 2012 IFC 605.3 Electrical panel, obstructed Notes: Recheck violation record auto-generated from ManageMyInspections.com recheck request. Original Violation Remarks: Move boxes from in front electrical panel. Keep on the outside of line.	1			0

Total Individual Violation Codes for Occupancy: 2

**50109 D.T. Nails
307 Smith Industrial BLVD
Suite G
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Add Knox Box to building.	1			0

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

50109 D.T. Nails
 307 Smith Industrial BLVD
 Suite G
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access	1			0
Notes: Must keep door unobstructed.					

Total Individual Violation Codes for Occupancy: 2

50133 Dalton Aircraft
 4465 Airport RD
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/07/2018	2012 NFPA101 7.10.5.1 Exit sign, non functional	1			0
Notes: Repair or replace exit signs.					

Total Individual Violation Codes for Occupancy: 1

50123 Dr. Micheal Vitkin
 601 Flemming ST
 Suite E
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Add Knox Box to building.					

11/06/2018	2012 NFPA101 7.10.5.1 Exit sign, non functional	1			0
Notes: Repair or replace exit signs.					

Total Individual Violation Codes for Occupancy: 2

* Denotes Violations Corrected or Variance Issued

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

50126 **Gio's**
 603 Flemming ST
 Suite F
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2011 NFPA 96 11.7.2 Cooking equipment, Notes: Clean under deep fryer.	1			0
11/06/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Add Knox Box to building.	1			0

Total Individual Violation Codes for Occupancy: 2

50148 **Hardee's**
 1301 Glenwood (North) AVE
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Add Knox Box to building.	1			0

Total Individual Violation Codes for Occupancy: 1

50107 **Herbalife**
 307 Smith Industrial BLVD
 Suite E & F
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/05/2018	2012 IFC 505.1 Address, no suite Notes: We will issue a new suite number.	1			0
11/05/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet	1			0

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

50107 **Herbalife**
 307 Smith Industrial BLVD
 Suite E & F
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
	from ground. Make sure to put the sticker on the door.Add Knox Box				
11/05/2018	2012 IFC 906.2 Fire extinguisher, Properly Notes: Need extinguisher serviced.	1			0

Total Individual Violation Codes for Occupancy: 3

20768 **Highland Rivers**
 1011 Abutment RD
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/27/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building.	1			0
11/27/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is installed.	1			0
11/27/2018	2012 NFPA101 7.10.5.1 Exit sign, non functional Notes: Exit signage not illuminated on back up battery.	1			0

Total Individual Violation Codes for Occupancy: 3

50096 **Iglesia De Dios Pentecostal Fuente Agua**
 1007 Underwood ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

50096 Iglesia De Dios Pentecostal Fuente Agua
1007 Underwood ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/09/2018	2011 NFPA 96 10.9.1 Kitchen hood suppression	1			0
Notes:					
Kitchen hood system needs to be inspected.					
11/09/2018	2011 NFPA 96 11.4 Kitchen hood,	1			0
Notes:					
Hood system needs to be inspected for grease buildup.					
11/09/2018	2011 NFPA 96 6.2.3.3 Kitchen hood, grease	1			0
Notes:					
Clean grease filters on a consistent basis.					
11/09/2018	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.					
Install Knox Box on building.					
11/09/2018	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.					
Install key once box is installed.					
11/09/2018	2012 IFC 906.2 Fire extinguisher, Properly	1			0
Notes:					
Have Fire extinguishers serviced.					
11/09/2018	2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
Notes:					
Ensure emergency lighting is working properly.					

* Denotes Violations Corrected or Variance Issued

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

50096 **Iglesia De Dios Pentecostal Fuente Agua**
 1007 Underwood ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/09/2018	2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1			0
Notes:					
Email a copy of the current fire alarm inspection report.					
11/09/2018	2012 NFPA101 7.10.5.1 Exit sign, non functional	1			0
Notes:					
Ensure all exit signs are working properly.					
11/09/2018	2013 NFPA 72 17.14.8.2 Fire alarm, pull station	1			0
Notes:					
Pull station needed in fellowship hall.					

Total Individual Violation Codes for Occupancy: 10

50099 **J&J Industries - Southcreek**
 1605 Underwood ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2011 NFPA 25 7.3.2 Fire hydrant, no annual	1			0
Notes: Email a copy of the current inspection report.					
11/06/2018	2012 IFC 505.1 Address, no suite	1			0
Notes: Install address numbers at least 4 inches tall and 1/2 inch wide at the road.					
11/06/2018	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install Knox Box on building.					
11/06/2018	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Install key once box is					

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

**50099 J&J Industries - Southcreek
 1605 Underwood ST
 Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
	installed.				
11/06/2018	2012 IFC 912.2.1 FDC, location not signed Notes: Install FDC signage.	1			0
11/06/2018	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access Notes: Rack is blocking egress path.	1			0
11/06/2018	2012 NFPA 101 7.10.1.8 Exit sign, not visible Notes: Exit signage should be visible from all areas of the building.	1			0
11/06/2018	2012 NFPA 101 7.9.3.1.1 Emergency light, Notes: Emergency light in stairwell is out. Ensure emergency lighting is working properly.	1			0
11/06/2018	2012 NFPA 101 9.7.1.1 Sprinkler system, no Notes: Ensure all areas of the building are properly sprinklered.	1			0
11/06/2018	2012 NFPA101 7.10.5.1 Exit sign, non functional Notes: Check all exit signs and ensure they are working properly.	1			0
11/06/2018	2013 NFPA 8.6.5.3.1 Storage with 18" of sprinkler Notes: Ensure storage is at least 18 inches below sprinkler heads.	1			0
11/06/2018	DFDFMO AHJ, Requirement Notes: Replace hydraulic calc stickers with metal stamped or engraved plates.	1			0

Total Individual Violation Codes for Occupancy: 12

**50122 Mattress Connection
 601 Flemming ST
 Suite C
 Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Add Knox Box to building.	1			0

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

Violation Date Reported Between {11/01/2018} And {11/30/2018}

50122 Mattress Connection
601 Flemming ST
Suite C
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

Total Individual Violation Codes for Occupancy: 1

40106 Mermaid Mattress
920 Market ST
Suite F
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

11/30/2018	2012 IFC 506.1 Knox Box, requirements	1			0
------------	---------------------------------------	---	--	--	---

Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.

Add Knox Box.

Total Individual Violation Codes for Occupancy: 1

40035 Oyster Pub
933 Market ST
Suite 12 B
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

11/29/2018	2012 IFC 506.1 Knox Box, requirements	1			0
------------	---------------------------------------	---	--	--	---

Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Add Knox Box

Total Individual Violation Codes for Occupancy: 1

* Denotes Violations Corrected or Variance Issued

Dalton Fire Department

Inspection Violations by Occupancy

Violation Date Reported Between {11/01/2018} And
{11/30/2018}

50102 SHAW INDUSTRIES PLANT #63
1401 Underwood ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/08/2018	2012 IFC 605.1 Electrical panel, abatement of Notes: Cover exposed electrical wiring.	1			0
11/08/2018	2012 IFC 605.1 Electrical panel, abatement of Notes: Wiring should be concealed or in conduit.	1			0
11/08/2018	2012 IFC 901.7 System red tagged, fire watch Notes: Systems that fed racks have been shut down and is red tagged. We need to determine what action if any is needed.	1			0
11/08/2018	2012 NFPA 101 7.10.1.8 Exit sign, not visible Notes: Make sure exit signage is in place throughout building.	1			0
11/08/2018	DFDFMO AHJ, Requirement Notes: Replace calc plates with metal stamped or engraved plates. Ceiling tiles missing upstairs could cause tremendous heat buildup prior to activating the sprinkler system.	1			0

Total Individual Violation Codes for Occupancy: 5

50145 Sonic
1201 Glenwood (North) AVE
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/05/2018	2011 NFPA 96 11.7.2 Cooking equipment, Notes: Clean around equipment.	1			0
11/05/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Add Knox Box	1			0

Total Individual Violation Codes for Occupancy: 2

* Denotes Violations Corrected or Variance Issued

Dalton Fire Department

Inspection Violations by Occupancy

**Violation Date Reported Between {11/01/2018} And
{11/30/2018}**

**40038 Stadium BBQ
1001 Market ST
Suite 14
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/29/2018	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual Notes: Needs inspection	1			0
11/29/2018	2011 NFPA 96 10.9.1 Kitchen hood suppression Notes: Need inspection.	1			0
11/29/2018	2011 NFPA 96 11.4 Kitchen hood, Notes: Have inspected.	1			0
11/29/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Add Knox Box.	1			0

Total Individual Violation Codes for Occupancy: 4

**50149 Starbuck's
1305 Glenwood (North) AVE
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
11/05/2018	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.Add Knox Box to building.	1			0

Total Individual Violation Codes for Occupancy: 1

**40140 Subway
920 Market ST
Suite G
Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
-----------------	-------------------------	--------------	----------------	-----------------	-------------

*** Denotes Violations Corrected or Variance Issued**

Dalton Fire Department

Inspection Violations by Occupancy

Violation Date Reported Between {11/01/2018} And
{11/30/2018}

40140 Subway
 920 Market ST
 Suite G
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/30/2018	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door.					
Add Knox Box					
11/30/2018	2012 NFPA 101 7.10.8.31 Exit, no exit	1			0
Notes:					
Mark door as no exit.					

Total Individual Violation Codes for Occupancy: 2

50063 Whitfield Nails
 1231 Glenwood (North) AVE
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/06/2018	2012 IFC 506.1 Knox Box, requirements	1			0
Notes: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Add Knox Box to building.					

Total Individual Violation Codes for Occupancy: 1

Grand Total Violations: 113

* Denotes Violations Corrected or Variance Issued