



# CITY COUNCIL AGENDA REQUEST

## MEETING TYPE

Mayor & Council Meeting

## MEETING DATE

12/15/2025

## AGENDA ITEM

Change Order 003 with Cherokee Mechanical for City Hall HVAC Project

## DEPARTMENT

Administration

## REQUESTED BY

Todd Pangle

## REVIEWED/APPROVED BY CITY ATTORNEY?

Yes

## COST

\$3,475.00

## FUNDING SOURCE IF NOT IN BUDGET

N/A

## PLEASE PROVIDE A SUMMARY OF YOUR REQUEST, INCLUDING BACKGROUND INFORMATION TO EXPLAIN THE REQUEST:

City Hall HVAC Project Change Order 003 with Cherokee Mechanical to Insulate Buffer Tank by stripping existing insulation and fab cloth from tank and re-insulate with 1" elastomeric foam (Armaflex).

## PHONE

706-278-9500

## WEBSITE

[www.daltonga.gov](http://www.daltonga.gov)

## ADDRESS

300 W Waugh Street  
PO Box 1205 Dalton,  
Georgia 30722